

TABLE 4.8.1.1.2-1

DIESEL GENERATOR TEST SCHEDULE

<u>NUMBER OF FAILURES IN LAST 20 VALID TESTS*</u>	<u>NUMBER OF FAILURES IN LAST 100 VALID TESTS*</u>	<u>TEST FREQUENCY</u>
$\leq 1$	$\leq 4$	Once per 31 days
$> 1^{**}$	$> 4$	Once per 7 days

Note: Valid failures greater than the number indicated in either the 20 valid test column or the 100 valid test column will require accelerated testing frequency. The criteria in the 20 valid test column, 100 valid test column and the \*\* footnote must be satisfied prior to a reduction in test frequency.

\*Criteria for determining number of failures and number of valid tests shall be in accordance with Regulatory Position C.2.e of Regulatory Guide 1.108, Revision 1, August 1977, where the last 100 tests are determined on a per diesel generator basis.

\*\*If increased frequency testing is required due to exceeding one failure in the last 20 valid tests, then in addition to the requirements of this table, the last seven consecutive valid tests must be successful in order to return to a 31 day test frequency.