



**Northeast  
Nuclear Energy**

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385-0128  
(860) 447-1791  
Fax (860) 444-4277

The Northeast Utilities System

SEP 2 1998

Docket No. 50-336  
B17215

Re: 10 CFR 50.73(a)(2)(iv)

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Millstone Nuclear Power Station Unit No. 2  
Licensee Event Report 95-032-02  
Manual Reactor Trip Due to Unisolable Secondary Steam Leakage

This letter forwards Licensee Event Report (LER) 95-032-02, documenting a condition that was discovered at Millstone Nuclear Power Station, Unit No. 2, on August 8, 1995. This LER supplement provides an update on the corrective action for this condition. This LER is being submitted pursuant to 10 CFR 50.73(a)(2)(iv).

LER 50-336/95-032-00<sup>(1)</sup> contained the following commitment for Millstone Unit No. 2:

"A design review of the Heater Drain System to verify adequacy for all operational conditions, update design documents, and propose design changes as applicable will be performed before revising OP 2320, 'Feedwater Heater Drains and Vents,' to allow securing two heater drains pumps at greater than 50% power. After completing the design review, Operations and Engineering should review the Alarm Response and Abnormal Operating Sections of this procedure (Long-term)."

1/  
1/  
T  
e22

Although the above commitment was not completed, Northeast Nuclear Energy Company (NNECO) reported the completion of the short term and long term corrective actions associated with the pipe rupture in the secondary system within the turbine building in a letter dated October 30, 1997 (LER 50-336/95-032-01)<sup>(2)</sup>

<sup>(1)</sup> LER 50-336/95-032-00, "Manual Reactor Trip Due to Unisolable Secondary Steam Leakage," reported on September 7, 1995.

<sup>(2)</sup> LER 50-336/95-032-01, "Manual Reactor Trip Due to Unisolable Secondary Steam Leakage," reported on October 30, 1997.

9809090354 980902  
PDR ADOCK 05000336  
S PDR


The purpose of this supplement is to reinstate and clarify the above corrective action as follows:

"A design review of the Heater Drains System will be performed to verify adequacy of the plant design. If appropriate, based on the review, applicable Operating Procedures, Abnormal Operating Procedures and Alarm Response Procedures will be revised. This work will be completed prior to entering Mode 2 from the present outage."

The NNECO commitments made within this letter are included in Attachment 1.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

  
\_\_\_\_\_  
J. A. Price  
Director - Millstone Unit No. 2

Attachments: 1. List of Regulatory Commitments  
2. LER 95-032-02

cc: H. J. Miller, Region I Administrator  
D. G. McDonald, Jr., NRC Senior Project Manager, Millstone Unit No. 2  
D. P. Beaulieu, Senior Resident Inspector, Millstone Unit No. 2  
E. V. Imbro, Director, Millstone ICAVP Inspections

Docket No. 50-336  
B17215

Attachment 1

Millstone Nuclear Power Station, Unit No. 2

Commitments

September 1998

Attachment 1

Regulatory Commitment Enclosure  
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document:

<b>REGULATORY COMMITMENT</b>	<b>COMMITTED DATE OR OUTAGE</b>
B17215.01: A design review of the Heater Drains System will be performed to verify adequacy of the plant design. If appropriate, based on the review, applicable Operating Procedures, Abnormal Operating Procedures and Alarm Response Procedures will be revised. This work will be completed prior to entering Mode 2 from the present outage.	Prior to entering Mode 2 from present outage

Docket No. 50-336  
B17215

Attachment 2

Millstone Nuclear Power Station, Unit No. 2

LER 95-032-02

September 1998