

SMB

Docket No. 50-440
Docket No. 50-441

The Cleveland Electric Illuminating
Company

ATTN: Mr. Murray R. Edelman
Vice President
Nuclear Group
Post Office Box 5000
Cleveland, OH 44101

Gentlemen:

This letter refers to our earlier Confirmatory Action Letter, CAL-RIII-86-01, dated January 31, 1986. Item 5 of that letter states that all affected equipment will be maintained in the "as found" condition but allowed routine maintenance to be performed. As a result of the inspections by our Augmented Investigation Team (AIT) and the subsequent conversations between the AIT leader, Dr. C. J. Paperiello, and Mr. M. D. Lyster, of your staff, we are amending and clarifying Item 5 as follows. It is our understanding, with regard to this matter, that you will:

1. Maintain all seismic monitoring instrumentation in the "as found" condition. Take no action such as removing, repairing, calibrating or replacing instrumentation which would destroy or cause to be lost, any evidence which would be needed to investigate the event. Maintenance, surveillance, and calibration will be performed only with the prior concurrence of NRC Region III management.
2. Resume all other activities including work such as, but not limited to, maintenance, training, surveillance, operations and calibrations under the following conditions:
 - A. All off normal conditions identified during these activities will be documented in accordance with CEI's programs and procedures.
 - B. Off normal conditions will be evaluated to determine if they were potentially earthquake related.

B602100352 B60204
PDR ADOCK 05000440
G PDR

1/0
1E01

CONFIRMATORY ACTION LETTER

The Cleveland Electric Illuminating Company 2

- C. Equipment identified in an off normal condition will be maintained "as found" until evaluated. Equipment determined to be potentially earthquake affected will be maintained in an "as found" condition until released by the NRC.
- D. The NRC will be notified of all off normal potentially earthquake related conditions within 24 hours.

3. Develop special procedures to implement Item 2.

Please let us know immediately if your understanding differs from that set out above.

Sincerely,

Original signed by
James G. Keppler

James G. Keppler
Regional Administrator

cc: J. J. Waldron, Manager, Perry
Plant Technical Department
M. D. Lyster, Manager, Perry Plant
Operations Department
L. O. Reck, General Supervising
Fuel Management Section
DCS/RSB (RIDS)
Licensing Fee Management Branch
Resident Inspector, RIII
Harold W. Kohn, Ohio EPA
Terry J. Lodge, Esq.
James W. Harris, State of Ohio
Robert H. Quillin, Ohio
Department of Health

RIII *yes*
RCA
Knop/pd
2/4/86

RIII *yes*
RFW
Warnick
2/4/86

RIII
Cyt
Paperiello
2/4/86

RIII
BDH
Norelius
2/4/86

RIII
D
Davis
3/4/86

RIII
JGK
Keppler
2/4/86

yes