



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

TOLEDO EDISON COMPANY

CENTERIOR SERVICE COMPANY

AND

THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

DOCKET NO. 50-346

DAVIS-BESSE NUCLEAR POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 226
License No. NPF-3

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Toledo Edison Company, Centerior Service Company, and The Cleveland Electric Illuminating Company (the licensees) dated December 23, 1997, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-3 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 226, are hereby incorporated in the license. The Toledo Edison Company shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented not later than 120 days after issuance.

FOR THE U.S. NUCLEAR REGULATORY COMMISSION



Allen G. Hansen, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of issuance: September 2, 1998

ATTACHMENT TO LICENSE AMENDMENT NO. 226

FACILITY OPERATING LICENSE NO. NPF-3

DOCKET NO. 50-346

Replace the following page of the Appendix A Technical Specifications with the attached page. The revised page is identified by amendment number and contains a vertical line indicating the area of change.

Remove

TS 3/4 4-10a

Insert

TS 3/4 4-10a

REACTOR COOLANT SYSTEM

SURVEILLANCE REQUIREMENTS (Continued)

the upper tube sheet and the 15th tube support plate. The tubes selected for inspection shall represent the entire circumference of the steam generator and shall total at least 150 peripheral tubes.

4.4.5.8 Visual inspections of the secured internal auxiliary feedwater header, header to shroud attachment welds, and the external header thermal sleeves shall be performed on each steam generator through the auxiliary feedwater injection penetrations.

These inspections of the secured internal auxiliary feedwater header, header to shroud attachment welds, and the external header thermal sleeves shall be performed during the third period of each ten-year Inservice Inspection Interval (ISI).

4.4.5.9 When steam generator tube inspection is performed as per Section 4.4.5.2, an additional but totally separate inspection shall be performed on special interest tubes that have been repaired by the repair roll process. This inspection shall be performed on 100% of the tubes that have been repaired by the repair roll process. The inspection shall be limited to the repair roll joint and the roll transitions of the repair roll. Defective or degraded tubes found in the repair roll region as a result of the inspection need not be included in determining the Inspection Results Category for the general steam generator inspection.