

AUG 12 1988

Docket/License Nos.: 50-334/DPR-66
50-412/NPF-73

Duquesne Light Company
ATTN: Mr. J. D. Sieber
Vice President, Nuclear Group
Post Office Box 4
Shippingport, Pennsylvania 15077

Gentlemen:

Subject: Combined Inspection Report Nos. 50-334/88-22 and 50-412/88-16

This refers to the routine resident safety inspection by Messrs. J. Beall and S. Pindale at the Beaver Valley Power Station in Shippingport, Pennsylvania. The reporting period covers the time from June 1 - July 15, 1988. The inspection consisted of document reviews, interviews and observation of activities. The findings were summarized and discussed with you and other members your staff at the conclusion of the inspection.

Based on the results of this inspection, it appears that activities associated with cable routing and separation were not conducted in compliance with NRC requirements. Please respond to these matters in accordance with the enclosed Appendix A. A licensee identified violation involving the failure to verify diesel generator operability is discussed in the enclosed report details. Please also describe the results of your evaluation of this event including root cause(s) and final corrective actions in your written response to this letter.

The responses directed by this letter and the accompanying Notice are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

Your cooperation with us is appreciated.

Sincerely,

Original Signed by
James T. Wiggins
James T. Wiggins, Chief
Reactor Projects Branch No. 3
Division of Reactor Projects

Enclosures:

1. Notice of Violation, Appendix A
2. NRC Region I Combined Inspection Report Nos. 50-334/88-22 and 50-412/88-16

OFFICIAL RECORD COPY

CIR BV 88-22/16 - 0001.0.0
08/11/88

88 08/19 0167
PDR ABOC/C
880812
05000334
PDC

11
JEO/

AUG 12 1988

cc w/encls:

J. J. Carey, Executive Vice President, Operations
J. O. Crockett, General Manager, Corporate Nuclear Services
W. S. Lacey, General Manager, Nuclear Operations
N. R. Tonet, Manager, Nuclear Engineering
T. P. Noonan, Plant Manager
C. E. Ewing, QA Manager
K. D. Grada, Manager, Nuclear Safety
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
Commonwealth of Pennsylvania

bcc w/encls:

Region I Docket Room (with concurrences)
Management Assistant, DRMA (w/o enclosures)
J. Wiggins, DRP
L. Tripp, DRP
D. Limroth, DRP
P. Wilson, DRP
R. Bores, DRSS
P. Tam, NRR
C. Anderson, DRS (See Sections 7, 8, 9 and 10)

[Signature]
RI:DRP
Beall/mjd

8/11/88

[Signature]
RI:DRP
L. Tripp

8/11/88

[Signature]
RI:DRP
Wiggins

8/12/88

OFFICIAL RECORD COPY

CIR BV 88-22/16 - 0002.0.0
08/09/88