

APPENDIX A

NOTICE OF VIOLATION

Public Service Electric and Gas Company
Hope Creek Unit 1 Nuclear Plant

Docket No. 50-354
License No. NPF-57

As a result of the equipment qualification inspection of January 26-29, 1988 and in accordance with NRC Enforcement Policy (10 CFR 2, Appendix C) the following violation has been identified:

10 CFR 50, Appendix B, Criterion V states, in part, that: "Activities affecting quality shall be accomplished in accordance with instructions, procedures..."

Procedure number VPN-NSP-07, Section 8.2.1 states, in part, that: "The use of whiteout and/or obliteration is not permitted on Quality Assurance records. Changes shall be made by a single line drawn through the item with new information written in, initialed and dated."

Contrary to the above, on January 29, EQ file numbers J-601, J-313 and E-171 contained deletions, whiteout changes of the original text that had not been initialed or dated.

This is a Severity Level V violation. (Supplement I)

Pursuant to the provisions of 10 CFR 2.201, Public Service Electric & Gas Company is hereby required to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

OFFICIAL RECORD COPY

IR HC 88-03 - 0004.0.0
04/20/88

8805030315 880427
PDR ADOCK 05000354
D DCD