Transmitted via by 5520 By Melba Hawkes.

April 26, 1988

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-11-88-28

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region II staff on this date.

FACILITY:	Georgia Power Company	Licensee Emergency Classification:
	Vogtle Unit 1	Notification of Unusual Event
	Docket No. 50-424	Alert
	Waynesboro, Georgia	Site Area Emergency
		General Emergency
		X Not Applicable
		Real Property in the second seco

SUCJECT: OUTAGE LASTING MORE THAN 48 HOURS

Vogtle Unit 1 has extended its outage, in order to complete repairs on the Main Feedwater Isolation Valve (MFIV) for loop 4, replace a 4160V transformer due to burnt windings, and investigate a safety injection line weld leak. The unit was manually tripped from 100 percent power at 10:22 a.m. (EST) on April 24, 1988, due to MFIV No. 4 drifting closed and the impending loss of water level in steam generator No. 4. (Refer to REN No. 12104.)

The NRC Resident Inspectors will monitor licensee actions as they progress.

Region II will perform routine follow up.

The State of Georgia will be informed.

The NRC received initial notification of this extended outage by telephone from C. Burger, Resident Inspector, at approximately 8:00 a.m. (EDT) on April 26, 1988.

This information is current as of 10:30 a.m. (EDT) on April 26, 1988.

CONTACT: Leigh Trocine - 242-2686

DISTRIBUTION

H. Street Chairman Zech Comm. Roberts Comm. Bernthal Comm. Carr	MNBB AEOD ARM EDO PA	Phillips NRR	E/W OIA OI	Willste NMSS	Regions Region I Region II Region III Region IV	2:31 2:32
Comm. Rogers SECY OGC-H	OGC	Air Rights SLITP			Region V —	2:44
CA GPA ACRS PDR	INPO - 2:33 NSAC LICENSEE - 2 RESIDENT IN			MAIL TO: DCS (Original) DOT (Trans. or		IESY Oli

8805030357 880426 PDR I&E PN0-II-88-028 DCD D.I.