UNITED STATES NUCLEAR REGULATORY COMMISSION DETROIT EDISON COMPANY WOLVERINE POWER SUPPLY COOPERATIVE, INCOPORATED DOCKET NO. 50-341 NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

7590-01

The United States Nuclear Regulatory Commission (the Commission) has issued Amendment No. 28 to Facility Operating License No. NPF-43, issued to the Detroit Edison Company and Wolverine Power Supply Cooperative, Inc. (the licensees), which revised the Technical Specifications (TSs) for operation of Fermi-2, located in Monroe County, Michigan. The amendment is effective as of the date of issuance.

The amendment changes the Technical Specifications to require two channels, instead of one, to be operable for the Standby Gas Treatment System Radiation Monitors. In addition, the amendment revises Action Statement 81 in Table 3.3.7.5-1 as recommended in NRC Generic Letter 83-36 and makes appropriate changes in the Technical Specification Bases as a result of the change.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings, as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Hearing in connection with this action was published in the FEDERAL REGISTER on March 10, 1988 (53 FR 7819). No

808250383 8808

request for hearing or petition to intervene was filed following this notice.

Also in connection with this action, the Commission prepared an Environmental Assessment and Finding of No Significant Impact which was published in the FEDERAL REGISTER on August 11, 1988, at 53 FR 30358

For further details with respect to this action, see (1) the application for amendment dated November 30, 1987, (2) Amendment No. 28 to License No. NPF-43, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Fublic Document Room, 1717 H Street, NW., Washington, DC 20555, and at the Monroe County Library System, 3700 South Custer Road, Monrce, Michigan 48161. A copy of items (2) and (3) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Director, Division of Reactor Projects - III, IV, V, and Special Projects.

Dated at Rockville, Maryland, this 19th day of August 1988.

FOR THE NUCLEAR REGULATORY COMMISSION

Theodore R. Quay

Theodore R. Quay, Project Manager Project Directorate III-1 Division of Reactor Projects - III, JV, V & Special Projects