



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ARKANSAS POWER AND LIGHT COMPANY

DOCKET NO. 50-313

ARKANSAS NUCLEAR ONE, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 110
License No. DPR-51

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Arkansas Power and Light Company (the licensee) dated May 16, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8808260010 880817
PDR ADOCK 05000313
P PNU


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. DPR-51 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 110, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Jose A. Calvo, Director
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 17, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 110

FACILITY OPERATING LICENSE NO. DPR-51

DOCKET NO. 50-313

Revise the following page of the Appendix "A" Technical Specifications with the attached page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change.

REMOVE PAGE

72a

INSERT PAGE

72a

TABLE 4.1-1 (Cont'd)

<u>Channel Description</u>	<u>Check</u>	<u>Test</u>	<u>Calibrate</u>	<u>Remarks</u>
36. Boric acid addition tank				
a. Level channel	NA	NA	R	
b. Temperature channel	M	NA	R	
37. Degraded voltage monitoring	W	R	R	
38. Sodium hydroxide tank level indicator	NA	NA	R	
39. Incore neutron detectors	M(1)	NA	NA	(1) Check functioning
40. Emergency plant radiation instruments	M(1)	NA	R	(1) Battery check
41. Reactor trip upon turbine trip circuitry	M	PC	R	
42. Strong motion acceleographs	Q(1)	NA	Q	(1) Battery check
43. ESAS manual trip functions				
a. Switches & logic	NA	R	NA	
b. Logic	NA	M	NA	
44. Reactor manual trip	NA	P	NA	
45. Reactor building sump level	NA	NA	R	
46. EFW flow indication	M	NA	R	