

UNITED STATES OF AMERICA
ATOMIC ENERGY COMMISSION

In the Matter of)
PACIFIC GAS AND ELECTRIC)
COMPANY)
(Diablo Canyon Nuclear Power)
Plant))

Docket No. 50-275

PROPOSED FINDINGS OF FACT AND
CONCLUSIONS OF LAW
SUBMITTED BY
THE AEC REGULATORY STAFF



The staff has reviewed the "Proposed Findings of Fact and Conclusions of Law Submitted by Pacific Gas and Electric Company", dated February 22, 1968, and has concluded that only the following additions need be proposed.

1. Add to paragraph 13 the following transcript references:

"Tr. pp. 351-354."

2. Add the following statement to paragraph 15:

Before operation at any power level in excess of 3250 MW(t) may be undertaken, the Commission will review the matter to assure that the facility can be operated safely at the higher power level and take appropriate licensing action.

3. Add the following transcript references to paragraph 16:

"Tr. pp. 522-535."

C-30 ✓

4. Add the following transcript reference to paragraph 17:
"Tr. p. 324."
5. Add to paragraph 18 the following transcript references:
"Tr. pp. 344-350, 362-364."
6. Insert "particulate" between "and" and "filters" at page 10, line 25, paragraph 20 to clarify the type of filters provided as one of the engineered safety features to minimize the consequences of the hypothetical "loss of coolant" accident. Add the following transcript references to paragraph 20:
"Tr. pp. 325, 467, 483-487."
7. Add to paragraph 22 the following transcript references:
"Tr. pp. 382-389, 396-410, 421 and 438."
8. Add to paragraph 23 the following transcript references:
"Tr. pp. 490-509."

Respectfully submitted,

Troy B. Conner, Jr.

Troy B. Conner, Jr.
Trial Counsel

Dated at Bethesda, Maryland,
this 28th day of February, 1968.

UNITED STATES OF AMERICA
ATOMIC ENERGY COMMISSION

In the Matter of)

PACIFIC GAS AND ELECTRIC COMPANY)

(Diablo Canyon Nuclear
Power Plant))

Docket No. 50-275

PROPOSED FINDINGS OF FACT AND
CONCLUSIONS OF LAW
SUBMITTED BY
PACIFIC GAS AND ELECTRIC COMPANY

PRELIMINARY STATEMENT

1. This proceeding involves the application of Pacific Gas and Electric Company (PG&E) dated January 16, 1967, as amended by nine amendments supplemental thereto (the application as amended is hereinafter referred to as the "Application"), for appropriate licenses under Section 104 b. of the Atomic Energy Act of 1954, as amended, to construct and operate a 3250 megawatt (thermal) pressurized water reactor nuclear power plant on a site on the Pacific Coast in San Luis Obispo County, California. (Safety Evaluation by Atomic Energy Commission (AEC) Division of Reactor Licensing, AEC Staff Exhibit 1 (S.E. 1) p. 1; Partial Summary of Application Prepared by Pacific Gas and Electric Company, Applicant's Exhibit 1 (A.E. 1) p. 1; Transcript (Tr.) pp. 4, 60, 149, 171.)

2. The Application was reviewed by the regulatory

1 staff (SAB) of the AEC which concluded that PG&E had
2 satisfied all AEC requirements for the issuance of a
3 construction permit. (S.E. 1 pp. 63, 64.) The Application
4 was also reviewed by the Advisory Committee on Reactor
5 Safeguards (ACRS) which concluded that the proposed facility
6 can be constructed with reasonable assurance that it can be
7 operated without undue risk to the health and safety of the
8 public. (S.E. 1 Appendix B; Tr. pp. 60, 61, 179, 180.)

9 3. On January 12, 1968 the AEC issued a "Notice
10 of Hearing on Application for Provisional Construction Permit"
11 in the matter of Pacific Gas and Electric Company (Diablo
12 Canyon Nuclear Power Plant), Docket No. 50-275, which sets
13 out the issues to be considered and initially decided by this
14 Atomic Safety and Licensing Board (Board), designated by the
15 AEC to conduct this proceeding, as a basis for determining
16 whether a provisional construction permit should be issued to
17 PG&E. This Notice of Hearing was published in the FEDERAL
18 REGISTER on January 13, 1968 (33 F.R. 516; Tr. p. 4.)

19 4. Petitions for Leave to Intervene in this matter
20 were filed by the following:

<u>Petitioner</u>	<u>Date Filed</u>
21 State of California	January 18, 1968
22 San Luis Obispo Bay 23 Properties, Inc.	January 26, 1968
24 International Brotherhood 25 of Electrical Workers, 26 Local 1245	January 30, 1968
Scenic Shoreline Preservation Conference, Inc.	January 30, 1968
Frederick Eissler	January 30, 1968

1 In an order dated February 2, 1968, the Board granted the
2 petition of the State of California for leave to intervene.
3 Pursuant to the Notice of Hearing and in accordance with the
4 requirements of the Act and the AEC's regulations, a prehearing
5 conference was held by the Board in San Luis Obispo,
6 California, on February 6, 1968. At the prehearing conference
7 the petitions of the Scenic Shoreline Preservation Conference,
8 Inc. and Frederick Eissler were stated to be in opposition to
9 the granting of a construction permit to PG&E. The
10 petitions of the above-named petitioners, with the exception
11 of Frederick Eissler, were granted by the Board at the
12 prehearing conference. The petition of Frederick Eissler was
13 deficient under the AEC rules of practice and he was given
14 until February 13, 1968 by the Board to cure the deficiency.
15 Nothing further being filed by Mr. Eissler, the Board, in an
16 order dated February 14, 1968, denied his petition for leave
17 to intervene. (Tr. pp. 114, 115, 129.)

18 5. This proceeding is a "contested proceeding"
19 within the meaning of 10 CFR 2.104. (Tr. pp. 118, 190.)

20 6. A public hearing was held by the Board on
21 February 20 and 21, 1968 to consider the issues specified for
22 a contested proceeding in the published Notice of Hearing.
23 (Tr. p. 122A.)

24 FINDINGS OF FACT

25 7. PG&E is a large operating public utility
26

1 engaged principally in the business of supplying electric and
2 natural gas service throughout most of northern and central
3 California. PGandE is soundly financed and has plentiful
4 resources at its command. PGandE plans to finance the cost
5 of the proposed facility, which it estimates will be approxi-
6 mately \$188,400,000, as a part of its continuing construction
7 program. (Lovejoy Testimony pp. 1-5 and Appendix A thereto;
8 Tr. 244ff.)

9 8. PGandE has had extensive experience in the
10 design, construction and operation of electric generating
11 plants. PGandE personnel have been involved with nuclear
12 power generation for a number of years, and its Humboldt Bay
13 reactor has been in operation since 1963. A number of its
14 personnel hold reactor operator licenses issued by the AEC.
15 The nuclear steam supply system supplier, Westinghouse
16 Electric Corporation, has designed and constructed a number
17 of pressurized water reactors which have been licensed by
18 AEC. (S.E. 1 p. 1; Joint Exhibit A, Vol. I, pp. 3-5.)

19 9. The site for the proposed plant is adjacent to
20 Diablo Creek on the Pacific Ocean in San Luis Obispo County,
21 California. The exclusion area distance from the reactor to
22 the nearest site boundary on land will be one-half mile. The
23 low population zone radius is six miles and the population
24 center distance is ten miles, which is the distance from the
25 site to the nearest boundary of San Luis Obispo. The site
26 consists of approximately 750 acres. The 595-acre portion

1 north of the creek is leased to PG&E for 25 years with an
2 option to renew for 25 years. PG&E has acquired title to
3 the land within the exclusion area lying north of Diablo
4 Creek and for the proposed switchyard. The deed to this land
5 conveying title in fee to PG&E has been deposited in escrow,
6 along with PG&E's consideration therefor, and the escrow
7 will be closed upon correction of certain descriptions in the
8 deed. (S.E. 1 pp. 3-4; A.E. 1 p. 2; Tr. pp. 287, 288, 482,
9 483.)

10 10. The climate of the area is typical of the
11 central California coastal region. The meteorological program
12 proposed by PG&E is adequate to provide a basis for the
13 development of a gaseous radioactive release limit and to
14 confirm the conservatism of diffusion parameters used in the
15 analysis of potential accidental releases. (S.E. 1 pp. 4, 5;
16 A.E. 1 pp. 2, 3.)

17 11. The plant will be founded on firm bedrock
18 fully capable of carrying the intended loads. The geologic
19 study of the site included excavation of about 2,400 feet of
20 trenches that were excavated through the terrace material a
21 minimum of three feet into bedrock. Several old, small
22 faults can be identified in the bedrock, but no indications
23 of major faulting were found. The evidence indicates there
24 has been no movement in the small bedrock faults at the site
25 for over 100,000 years, and probably much longer. Therefore,
26 the probability of surface fault rupture at the site is so
remote that it may be safely disregarded. (S.E. 1 pp. 5, 6;
A.E. 1 pp. 3-5.)

1 12. The plant has been designed to withstand the
2 largest earthquakes to be expected along the faults in the
3 general area. Of the possible earthquakes studied it was
4 determined that a magnitude 7-1/4 (Richter) earthquake along
5 the Nacimiento Fault, which is 20 miles from the site, and
6 an aftershock with a magnitude of 6-3/4 at the site resulting
7 from a magnitude 8-1/2 earthquake along the San Andreas
8 Fault, which is 48 miles from the site, produced the maximum
9 ground accelerations at the site. These were calculated to
10 be 0.12 g (adjusted to 0.15 g for design purposes) and 0.20 g,
11 respectively. When the response spectra of the two earth-
12 quakes were considered it was found that the hypothetical
13 earthquake along the Nacimiento Fault produced higher
14 accelerations in structures having longer natural periods
15 than the other earthquake. (S.E. 1 pp. 6-8; A.E. 1 pp. 5,
16 6.)

17 13. Structures and components important to nuclear
18 safety, failure of which might cause, or increase the severity
19 of, an accident, including structures and components vital to
20 safe shutdown and isolation of the reactor, are classified
21 as Class I. Structures and components important to reactor
22 operation but not essential to safe shutdown and isolation
23 of the reactor are considered as Class II. Structures and
24 components not related to reactor operation or containment
25 are considered as Class III. Class I structures will be
26 designed to withstand horizontal seismically induced loads

1 obtained by using response spectra of either of the two
2 design earthquakes, whichever controls. Vertical accelera-
3 tions will be taken as constant equal to two-thirds of the
4 maximum horizontal ground acceleration, and the resulting
5 stresses due to horizontal and vertical accelerations will
6 be considered to act simultaneously and will be added
7 directly. Conservative values of structural damping will be
8 used. After completion of the design a review will be made
9 to assure no loss of function for components necessary for a
10 safe shutdown using a combined response spectrum with
11 acceleration values twice those used in the design. Class II
12 structures and components will be designed on a static
13 analysis basis using a seismic horizontal coefficient of
14 0.20 g and stresses allowed by applicable codes. Class III
15 structures and components will be designed according to the
16 earthquake regulations of the Uniform Building Code. (S.B. 1
17 pp. 35, 47-50; A.E. 1 pp. 7, 8.)

18 14. The plant will be designed so that it will not
19 be subject to damage from either distantly or locally
20 generated seismic sea waves. Most of the plant will be
21 located at or above elevation 85 feet above sea level.
22 Cooling water for the plant will be taken from the Pacific
23 Ocean. Class I equipment located at the intake will be
24 protected by a wall or other suitable means to accommodate
25 a wave runup of 30 feet above mean lower low water. In the
26 event of a drawdown occurring with a seismic sea wave in

1 center of riser 12 feet below mean lower low water, the
2 inside structure is designed to provide a reservoir to
3 supply water to the auxiliary salt water cooling system.
4 (S.E. 1 p. 8; A.E. 1 pp. 8, 9.)

5 15. The proposed reactor is designed to operate at
6 3250 MWt with an expected ultimate capability of 3391 MWt.
7 PGandE has designed the major components including the con-
8 tainment structure and emergency cooling system for a power
9 level of 3391 MWt, and has used this power level in analyzing
10 postulated accidents in conformance with the guidelines of
11 10 CFR Part 100. (S.E. 1 p. 1; A.E. 1 p. 31; Tr. pp. 473,
12 474.)

13 16. The nuclear steam supply system, as designed
14 by Westinghouse, is similar to that of other PWR systems
15 that have been licensed by the AEC, such as the Indian Point
16 No. 2 Plant of the Consolidated Edison Company of New York.
17 The nuclear steam supply system consists of a light water
18 moderated pressurized water reactor (PWR) which transfers
19 reactor heat to four steam generators. Steam generated in
20 the secondary side of the steam generators passes to the
21 turbine generator. The fuel for the reactor is low enrich-
22 ment UO_2 pellets enclosed within Zircaloy tubes. There are
23 193 fuel assemblies, each made up in a 15 by 15 rod array.
24 Reactivity control is accomplished by 53 full-length control
25 rod assemblies, eight part-length control rod assemblies,
26 1144 fixed burnable poison rods and by liquid poison (boric
 acid) in the reactor coolant. The full-length control rod

1 assemblies provide reactivity control for fast shutdown and
2 changes in reactivity in going from hot zero power to full
3 operating power. The eight part-length control rod
4 assemblies are included for shaping the axial power distribu-
5 tion and controlling potential axial xenon oscillations. The
6 control rod drive mechanisms for this reactor are similar to
7 the drives provided on other Westinghouse-designed reactors.
8 Reactor coolant at 2235 psig is circulated through the core
9 by four centrifugal pumps. (S.E. 1 pp. 9-13, 18; A.E. 1
10 pp. 10-12; Tr. pp. 334-338, 479, 480.)

11 17. The core design for the reactor takes advantage
12 of reduced peaking factors made possible by the use of part-
13 length control rods. With reduced peaking factors it is pos-
14 sible to increase the average power of the core 18% compared
15 to previous designs, yet maintain the peak specific fuel
16 power in line with past designs. (S.E. 1 p. 15)

17 18. The reactor protection system monitors signals
18 from nuclear and process instrumentation which are indicative
19 of reactor plant conditions. Independent, redundant channels
20 are provided in the protection system so that a failure in
21 any given instrument channel would not prevent a safe shutdown
22 of the reactor. The reactor protection system for the pro-
23 posed Diablo Plant will differ from those previously described
24 for other Westinghouse-designed plants. Changes were made to
25 the system in accordance with the provisions of the proposed
26 Institute of Electrical and Electronic Engineers (IEEE)

1 Standard on Nuclear Power Plant Protection by ANSI. Other
2 changes were made as a result of the higher power density and
3 the use of part-length control rods. Circuits which actuate
4 engineered safety features will also be designed to the pro-
5 posed IEEE Standard. The same channelized approach will be
6 used for these circuits as is proposed for the reactor pro-
7 tection system. (S.E. 1 pp. 18-25; A.E. 1 pp. 16-19.)

8 19. The reactor containment structure consists of
9 a reinforced concrete vessel with a steel liner which encloses
10 the reactor and the reactor coolant system. The containment
11 structure is a flat-bottomed cylinder with a hemispherical
12 dome with an inside diameter of 140 feet and vertical side-
13 walls measuring 142 feet. The concrete sidewalls of the
14 cylinder and the dome will be approximately three feet six
15 inches and two feet six inches thick, respectively. The con-
16 tainment structure is designed for an internal pressure of
17 47 psig and a maximum leakage rate of 1/10th of one percent
18 of the containment volume per day at the design pressure.
19 Pipelines which penetrate the containment have provision for
20 isolation. (S.E. 1 pp. 32-40; A.E. 1 pp. 13-15.)

21 20. In addition to the containment system, other
22 engineered safety features will be provided to minimize the
23 consequences of the hypothetical "loss-of-coolant" accident.
24 These include a safety injection system, air recirculation
25 coolers and filters, and containment spray equipment.
26 Reliable on-site diesel emergency power is provided for the

engineered safety feature loads in the event of failure of normal station auxiliary power. The control room contains instrumentation and controls necessary for safe operation of the facility. Sufficient instrumentation and controls are available outside the control room to maintain the reactor in a hot standby condition. (S.E. 1 pp. 41-47; A.E. 1 pp. 15-16.)

21. Quality standards of material selection, design, fabrication and inspection will conform to the applicable provisions of recognized codes and good nuclear practice. Materials and components furnished for the work will be reviewed by Westinghouse or PGandE engineers. The construction work will be subject to the independent review of PGandE's Engineering Department. (S.E. 1 p. 51; A.E. 1 pp. 22-24.)

22. The waste disposal system collects, monitors and processes for safe disposal all liquid, solid and gaseous wastes. The system is designed to process fluid wastes for discharge to the environment within the radioactive level tolerances established by applicable governmental regulations. Experience with other similar plants indicates that liquid radioactive wastes will be a factor of about 1/100th of the permissible amount. The system is designed to be flexible to control waste releases as necessary to assure no adverse effects on the environment. Suitable facilities are provided for handling and on-site storage of solid wastes prior to disposal. The activity concentration of liquid and gaseous wastes will be determined prior to discharge to assure

1 compliance with 10 CFR Part 20. A suitable preoperational and
2 postoperational survey and environmental monitoring program
3 will be conducted by PGandE. (S.E. 1 pp. 53, 54; A.E. 1
4 pp. 21, 22; Tr. pp. 254-258, 288, 293, 294, 311-304, 403, 416,
5 417, 419, 422, 426, 430-436, 439, 544.)

6 23. A number of plant operating transients were
7 considered by PGandE in order to assess the safety margins
8 of the plant design. The criterion for detailed design of
9 the reactor control and protection system is to be able to
10 automatically take corrective action to cope with any of
11 these transients. Preliminary analyses will be recalculated
12 during detailed plant design to verify that transients are
13 within the capabilities of the reactor control and protection
14 systems. In addition, potential accidents which could result
15 in radioactive releases to the environment have been analyzed
16 by PGandE, and the resulting doses fall within the 10 CFR
17 Part 100 guideline dose levels. (S.E. 1 pp. 55-59; A.E. 1
18 pp. 28-31; Tr. pp. 480-484.)

19 24. Research and development work is being carried
20 out to develop and confirm (i) the design of the emergency
21 core cooling system, (ii) the final core thermal-hydraulic,
22 nuclear and mechanical design parameters, and (iii) the
23 details of the containment spray system. The information to
24 be developed under these programs will be submitted
25 periodically for review by the AEC Staff and it will be set
26 forth in the Final Safety Analysis Report, which will be

1 prepared and file. in support of PGandE's application for an
2 operating licence. All of the information to be developed
3 under these programs, except for the LORT test program on
4 blowdown forces, will be available in 1968 or 1969. This
5 will permit the safety questions these programs were designed
6 to resolve to be answered before completion of construction
7 of the Diablo Canyon Plant late in 1971. The results of the
8 LORT test program are expected to be available in 1971. These
9 results are desirable to show the amount of conservatism in
10 the design of the Diablo Plant to withstand accident blowdown
11 forces. However, these results are not necessary to complete
12 the design of the Plant. (S.E. 1 pp. 58-60; A.E. 1 pp. 24-27;
13 Tr. pp. 316-337, 445, 462, 466, 492-502, 504-520, 541-543.)

14 25. The principal architectural and engineering
15 criteria for the design of the proposed facility have been
16 described by PGandE. The ACRS report has identified certain
17 areas requiring further review by the AEC Staff as the plant
18 design details are developed or as the additional information
19 becomes available. These items will be reviewed with the
20 Staff and by the ACRS prior to issuance of an operating
21 licence. (S.E. 1 pp. 60-61; A.E. 1 pp. 31-46; Tr. pp. 339-348,
22 355-369.)

23 26. PGandE is a California corporation, and all of
24 its directors and officers are citizens of the United States.
25 It is not owned, controlled or dominated by an alien, a
26 foreign corporation or a foreign government. The Application

1 contains no restricted or other defense information, and
2 Pounds has agreed that it will not permit any individual to
3 have access to restricted data until a determination has been
4 made by the AEC that permitting access to such data by any
5 individual will not endanger the common defense and security.
6 Special nuclear material to be used in connection with the
7 proposed facility will be subject to AEC regulation. Safe-
8 guards exist against possible diversion from their intended
9 use of materials produced in the reactor or special nuclear
10 material. (S.E. 1 p. 62; A.E. 1 pp. 46-47; Tr. pp. 92,
11 447-450.)
12

13 CONCLUSIONS AND ORDER

14 Upon consideration of the entire record in this
15 proceeding, and in the light of the findings and discussions
16 set out above, this Atomic Safety and Licensing Board has
17 concluded that:

18 1. In accordance with the provisions of 10 CFR
19 50.35(a),

20 (a) Pounds has described the proposed design of
21 the facility adjacent to Diablo Creek, including the
22 principal architectural and engineering criteria for the
23 design, and has identified the major features or components
24 incorporated in the proposed facility for the protection of
25 the health and safety of the public;

26 (b) Such further technical or design information

1 as may be required to complete the safety analysis and which
2 can reasonably be left for later consideration, will be
3 supplied in the Final Safety Analysis Report;

4 (c) Safety features or components, which require
5 research and development have been described by PGandE and
6 PGandE has identified, and there will be conducted, a
7 research and development program reasonably designed to
8 resolve any safety questions associated with such features
9 or components; and

10 (d) On the basis of the foregoing, there is
11 reasonable assurance that (i) such safety questions will be
12 satisfactorily resolved at or before the latest date stated
13 in the Application for completion of construction of the
14 proposed facility and (ii) taking into consideration the site
15 criteria contained in 10 CFR 100, the proposed facility can
16 be constructed and operated at the proposed location without
17 undue risk to the health and safety of the public;

18 2. PGandE is technically qualified to design and
19 construct the proposed facility;

20 3. PGandE is financially qualified to design and
21 construct the proposed facility; and

22 4. The issuance of a permit for the construction
23 of the facility will not be inimical to the common defense
24 and security or to the health and safety of the public.

25 Pursuant to the Act and the AEC's regulations,
26

1 IS ORDERED THAT:

2 1. Subject to review by the Commission upon its
3 own motion or upon the filing of exceptions in accordance
4 with the "Rules of Practice," 10 CFR 2, Pacific Gas and
5 Electric Company is authorized to construct the facility in
6 accordance with the Application and with the evidence and
7 representations entered in the record at the hearing;

8 2. The Director of Regulation is directed to
9 issue a provisional construction permit pursuant to Section
10 104 b. of the Act substantially in the form of Appendix A to
11 the "Notice of Hearing on Application for Provisional
12 Construction Permit" in this proceeding, within 10 days from
13 the date of issuance of this decision; and

14 3. In accordance with 10 CFR 2.764, good cause
15 not having been shown to the contrary, this initial decision
16 shall be immediately effective.

17
18 ATOMIC SAFETY AND LICENSING BOARD

19
20 _____
Hugh C. Paxton

21
22 _____
Thomas H. Pigford

23
24 _____
Algie A. Wells, Chairman

25 Dated at

26 this day of

1968.