

Docket No. 50-341  
EA 88-104

APR 27 1988

The Detroit Edison Company  
ATTN: B. Ralph Sylvia  
Group Vice President  
Nuclear Operations  
6400 North Dixie Highway  
Newport, MI 48166

Gentlemen:

This confirms our plans as discussed on April 21, 1988, between R. W. Cooper, II of my staff and L. Goodman of your staff to conduct an Enforcement Conference at 9:30 a.m. (CDT) on Thursday, April 28, 1988, at the Region III office in Glen Ellyn, Illinois. The conference is to discuss two potential escalated enforcement issues. The first concerns the failure to enter appropriate action statements for LCOs associated with the Standby Gas Treatment and Control Center HVAC systems due to the inoperability of the Non-interruptible Control Air System. The second concerns the failure to evaluate the deviations between the as-built Primary Containment Radiation Monitor System and the UFSAR in accordance with 10 CFR 50.59.

We will gladly discuss any questions you may have concerning this matter.

Sincerely,

Original Signed by E.G. Greenman

Edward G. Greenman, Director  
Division of Reactor Projects

cc w/enclosure:

Patricia Anthony, Licensing  
P. A. Marquardt, Corporate  
Legal Department  
DCD/DCB (RIDS)  
Licensing Fee Management Branch  
Resident Inspector, RIII  
Ronald Callen, Michigan  
Public Service Commission  
Harry H. Voight, Esq.  
Michigan Department of  
Public Health  
Monroe County Office of  
Civil Preparedness  
J. R. Goldberg, OGC  
F. J. Miraglia, NRR  
J. Lieberman, OE

8805040375 880427  
PDR ADOCK 05000341  
Q PDR

RIII  
Pelke/pb  
4/24/88

RIII  
Grobe  
4/24/88

YES  
RIII  
Cooper  
4/24/88

YES  
RIII  
Knop  
4/25/88

RIII  
Virgilio  
4/25/88

RIII  
Greenman  
4/25/88

IEO/



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

APR 27 1988

NOTICE OF SIGNIFICANT LICENSEE MEETING

Name of Licensee: The Detroit Edison Company

Name of Facility: Fermi 2

Date and Time of Meeting: Thursday, April 28, 1988, at 9:30 a.m. (CDT)

Location of Meeting: U. S. Nuclear Regulatory Commission  
Region III Office  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Purpose of Meeting: Enforcement Conference to discuss: (1) the failure to enter appropriate action statements for LCOs associated with the Standby Gas Treatment and Control Center HVAC systems due to the inoperability of the Non-interruptible Control Air System and (2) the failure to evaluate the deviation between the as-built Primary Containment Radiation Monitor System and the UFSAR in accordance with 10 CFR 50.59.

Region III Attendees:

Dr. C. J. Paperiello, Deputy Regional Administrator  
E. G. Greenman, Director, Division of Reactor Projects  
M. J. Virgilio, Acting Deputy Director, Division of Reactor Projects  
R. C. Knop, Chief, Projects Branch 3, Division of Reactor Projects  
R. Cooper, Chief, Projects Section 3B, Division of Reactor Projects  
W. G. Rogers, Senior Resident Inspector  
Others as designated by Region III

NRR Attendees:

T. R. Quay, Licensing Project Manager

Licensee Attendees:

B. Ralph Sylvia, Group Vice President  
W. S. Orser, Vice President Nuclear Operations  
Others as designated by the licensee

Note: Attendance at this meeting by NRC personnel should be made known to P. Pelke via telephone call (FTS 388-5560) by COB April 27, 1988.

Distribution:

J. M. Taylor, Deputy Executive Director for Regional Operations  
T. E. Murley, Director, Office of Nuclear Reactor Regulation  
J. G. Partlow, Director, Division of Reactor Inspection and Safeguards  
D. M. Crutchfield, Director, Division of Reactor Projects III/IV/V, NRR  
F. Miraglia, Associate Director for Projects, NRR  
G. Holahan, Assistant Director for Region III and V, NRR  
M. Johnson, RIII Coordinator, EDO  
T. V. Wambach, Acting Director, Project Directorate III-1, NRR  
T. R. Quay, Licensing Project Manager, NRR  
J. Lieberman, Director, Office of Enforcement  
J. R. Goldberg, Office of General Counsel