

UNITED STATES NUCLEAR REGULATORY COMMISSIONKANSAS GAS AND ELECTRIC COMPANYKANSAS CITY POWER & LIGHT COMPANYKANSAS ELECTRIC POWER COOPERATIVE, INC.DOCKET NO. 50-482NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENTTO FACILITY OPERATING LICENSE ANDOPPORTUNITY FOR HEARING

The United States Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. WPF-42, issued to Kansas Gas and Electric Company, Kansas City Power & Light Company, and Kansas Electric Power Cooperative, Inc. (the licensees), for operation of the Wolf Creek Generating Station located in Coffey County, Kansas.

The amendment would revise three Technical Specifications; 3/4.7.6 (Control Room Emergency Ventilation System), 3/4.7.7 (Emergency Exhaust System), and 3/4.9.13 (Emergency Exhaust System). The changes in Technical Specification 3/4.7.6 consist of: 1) increasing the Control Room Pressurization System flow from 500 cfm +10% to 750 cfm +10% in all applicable portions of 4.7.6; 2) changing the Pressurization System dirty filter dp from 3.8" W.G. to 3.6" W.G. in all applicable portions of 4.7.6; 3) deleting the dirty filter dp requirements in 4.8.7.c.1; 4) adding a maximum allowable dp for the Pressurization System

filter unit in 4.7.6.e.1; 5) deleting the 0.05% in place penetration and bypass leakage test for charcoal filters in 4.7.6.f which tests HEPA filter integrity; and 6) deleting the 1% in place penetration and bypass leakage test for HEPA filters in 4.7.6.g which tests charcoal filter integrity.

The changes in Technical Specification 3/4.7.7 consist of: 1) adding Auxiliary Building in the identification title; 2) deleting all of 4.7.7 dealing with testing of the adsorber unit and fan flow rates and replacing with requirements to perform the same adsorber unit testing at the appropriate flow rates per 4.9.13; 3) in renumbered paragraph 4.7.7.b.1 changing "fuel" to "auxiliary" to correctly identify the appropriate building; and 4) renumbering as necessary due to deleted/transferred testing requirements.

The changes in Technical Specification 3/4.9.13 consist of: 1) adding Fuel Building in the identification title; 2) reducing the required fan flow from 9000 cfm +10% to 6500 cfm +10% for all applicable sections of 4.9.13; 3) changing the dirty filter dp from 7.2" W.G. to 4.7" W.G. in all applicable sections of 4.9.13; 4) deleting dirty filter requirement in 4.9.13.b.1; 5) transferring 4.9.13.d.2 and 4.9.13.d.3 to new section 4.9.13.g as 4.9.13.g.1 and 4.9.13.g.2 and renumbering 4.9.13.d as applicable; 6) deleting .05% in place penetration and bypass leakage testing for charcoal adsorbers in 4.9.13.e; and 7) deleting the 1% in place penetration and bypass leakage testing for HEPA filters in 4.9.13.f.

The change in the BASES consist of: 1) changes in the identification titles for 3/4.7.7 and 3/4.9.13 2) changing "pump room" to "auxiliary

building" in 3/4.7.7; and 3) adding that the surveillance requirements associated with the filtration unit for 3/4.7.7 are stated in Technical Specification 4.9.13.

Prior to issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

By September 26, 1988 , the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and petitions for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition, and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR §2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding;

(2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to fifteen (15) days prior to the first prehearing conference scheduled in the proceedings, but such an amended petition must satisfy the specificity requirements described above.

Not later than fifteen (15) days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter, and the bases for each contention set forth with reasonable specificity. Contentions shall be limited to matters within the scope of the amendment under consideration. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene shall be filed with the Secretary of the Commission, United States Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Branch, or may be delivered to the Commission's Public Document Room, 1717 H Street,

N.W., Washington, D.C. by the above date. Where petitions are filed during the last ten (10) days of the notice period, it is requested that the petitioner or representative for the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at 1-800-325-6000 (in Missouri 1-800-342-6700). The Western Union operator should be given Datagram identification Number 3737 and the following message addressed to Jose A. Calvo: petitioner's name and telephone number; date Petition was mailed; plant name; and publication date and page number of this FEDERAL REGISTER notice. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, and to Jay Silberg, Esq., Shaw, Pittman, Potts and Trowbridge, 2300 N Street N.W., Washington, D.C. 20037, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board, that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).


If a request for hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the application for amendment dated February 26, 1988, which is available for public inspection at

the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C.
and at the Emporia State University, William Allen White Library, 1200
Commercial Street, Emporia, Kansas 66801 and Washburn University School
of Law Library, Topeka, Kansas.

Dated at Rockville, Maryland this 19th day of August, 1988.

FOR THE NUCLEAR REGULATORY COMMISSION



David L. Wigginton, Acting Director
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation