

APPENDIX A

NOTICE OF VIOLATION

New York Power Authority
James A. FitzPatrick Nuclear Power Plant

Docket No. 50-333
License No. DPR-59

As a result of the inspection conducted on June 12, 1988 to August 7, 1988, and in accordance with NRC Enforcement Policy (10 CFR Part 2, Appendix C) the following violation was identified:

Technical Specification 4.0.B requires that surveillance requirements be performed within the specified time interval with an allowable variation of $\pm 25\%$ of the surveillance interval.

Technical Specification 4.6.D requires that reactor coolant leakage rate inside the primary containment shall be monitored and recorded once every four hours, utilizing the Primary Containment Sump Monitoring System.

Contrary to the above, on June 27, 1988, the reactor coolant leakage rate was not calculated and recorded between 4:00 a.m. and 12:00 p.m., missing the surveillance requirement once.

This is a Severity Level V Violation (Supplement I)

Pursuant to the provisions of 10 CFR 2.201, the New York Power Authority is hereby required to submit to this office within thirty days of the date of the letter transmitting this Notice, a written statement or explanation in reply including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the dates when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

OFFICIAL RECORD COPY

IR FITZ 88-12 - 0003.0.0
08/16/88

8808260395 880818
PDR ADOCK 05000333
Q PDC