

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

APR 28 1988

TVA-SQN-TS-88-07

10 CFR 50.90

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

SEQUOYAH NUCLEAR PLANT (SQN) - TECHNICAL SPECIFICATION CHANGE 88-07

In accordance with 10 CFR 50.90, we are enclosing a requested amendment to licenses DPR-77 and DPR-79 to change the technical specifications of SQN units 1 and 2. The proposed change deletes flow control valves (FCVs) 77-16 and 77-17 from Table 3.6-2, "Containment Isolation Valves." Table 3.6-1, "Bypass Leakage Paths to the Auxiliary Building," is also amended to delete penetration X-81 from the table.

The proposed technical specification change is identified in enclosure 1. The justification for the proposed technical specification change is provided in enclosure 2. A proposed determination of no significant hazards consideration performed pursuant to 10 CFR 50.92 is provided in enclosure 3.

Enclosed is a check for the \$150 amendment application fee required by 10 CFR 170.12.

Please direct questions you may have concerning this issue to Russell R. Thompson at (615) 870-7470.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

R. Gridley
R. Gridley, Director
Nuclear Licensing and
Regulatory Affairs

Sworn to and subscribed before me
this 28th day of April 1988

Roulette H. White
Notary Public
My Commission Expires 8-24-88

D030
w/check \$150
43255
11

Enclosures
cc: See page 2

8805050070 880428
PDR ADOCK 05000327
P DCD

U.S. Nuclear Regulatory Commission

APR 28 1988

cc (Enclosures):

Mr. Michael H. Mobley, Director (w/o enclosures)
Division of Radiological Health
T.E.R.R.A. Building
150 9th Avenue, N
Nashville, Tennessee 37203

Mr. K. P. Barr, Acting Assistant Director
for Projects
TVA Projects Division
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. G. G. Zech, Assistant Director
for Projects
TVA Projects Division
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Sequoyah Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy Daisy, Tennessee 37379

ENCLOSURE 1
PROPOSED TECHNICAL SPECIFICATION CHANGE
SEQUOYAH NUCLEAR PLANT (SQN) UNITS 1 AND 2
DOCKET NOS. 50-327 AND 50-328
(TVA-SQN-TS-88-07)

LIST OF AFFECTED PAGES

Unit 1

3/4 6-5
3/4 6-20

Unit 2

3/4 6-5
3/4 6-20