

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

February 6, 1986

W. L. STEWART
VICE PRESIDENT
NUCLEAR OPERATIONS

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Lester S. Rubenstein, Director
PWR Project Directorate #2
Division of PWR Licensing-A
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Serial No. 86-013
NO/ALM/acm
Docket Nos. 50-338
50-339
License Nos. NPF-4
NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNITS NO. 1 AND 2
PROPOSED TECHNICAL SPECIFICATION CHANGE

Pursuant to 10CFR50.90, the Virginia Electric and Power Company requests an amendment, in the form of changes to the Technical Specifications, to Operating License Nos. NPF-4 and NPF-7 for North Anna Power Station Unit Nos. 1 and 2.

The proposed changes are to Section 3/4.6.3, Table 3.6-1, Containment Isolation Valves, of the North Anna Unit 1 and 2 Technical Specifications (Attachment 1 and 2). These changes reflect the planned installation of new containment isolation valves in the letdown line on each unit. The new valve will function as the inside containment isolation valve and is designed to meet the operating criteria of the three (3) existing parallel isolation valves, an in-line relief valve, and a remote manual valve. The existing valves will not be physically removed and will no longer serve as containment isolation. We plan to install the new valves during the next refueling outage for each unit. Therefore, we request the approval of the proposed change prior to the completion of the outage in which the new valves will be installed.

This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control Staff. It has been determined that this change does not pose an unreviewed safety question as defined in 10CFR50.59 and does not pose a significant hazards consideration as defined in 10CFR50.92.

We have evaluated this request in accordance with the criteria in 10 CFR 170.12. A check in the amount of \$150 is enclosed as an application fee.

8602130124 860206
PDR ADOCK 05000338
P PDR

Rec'd w/ check #150.00
A001
1/1

VIRGINIA ELECTRIC AND POWER COMPANY TO Mr. Harold R. Denton

If you have any questions, or need additional information to process this request, please contact us.

Very truly yours,



W. L. Stewart

Attachments:

1. Proposed Technical Specification Changes-Unit 1
2. Proposed Technical Specification Changes-Unit 2
3. Discussion of Proposed Changes
4. Application Fee

cc: Dr. J. Nelson Grace
Regional Administrator
NRC Region II

Mr. Morris W. Branch
NRC Resident Inspector
North Anna Power Station

Mr. Charles Price
Department of Health
109 Governor Street
Richmond, Virginia 23219

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by W. L. Stewart who is Vice President - Nuclear Operations, of Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 6 day of February, 19 86.

My Commission expires: February 11, 19 89.

Carolee M. Moore
Notary Public

(SEAL)

S/001