



UNION ELECTRIC COMPANY
Callaway Plant

ULNRC 1251

January 31, 1986

SMB

Mr. James G. Keppler
Administrator, Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

right

PRIORITY ROUTING	
First	Second
PA	HC
RA	ETC
RP	SEA
ORS	WL
DRSS	DI
ORMA	DI
	PAO

FILE *ms*

Docket No. STN 50-483

Dear Mr. Keppler:

As required by Technical Specification 6.9.1.9, this Callaway Cycle 2 Radial Peaking Factor Limit Report is forwarded for your information. Included are the F_{xy} limits for rated thermal power (F_{xy}^{RTP}) for all core planes containing Bank D control rods and all unrodded core planes, and the plot of predicted ($F_{Tq}^{P_{Re1}}$) vs. axial core height with the limit envelope.

G. L. Randolph
G. L. Randolph
Manager, Callaway Plant

ROP/KRB
GLR/RDA/KRB/crc

Enclosures

cc: Director of Nuclear Reactor Regulation
Attention: Chief, Core Performance Branch
U. S. Nuclear Regulatory Commission
Washington, DC 20555

FEB 7 1986

8602130163 860131
PDR ADOCK 05000483
P PDR

2801

Radial Peaking Factor Limit Report

This Radial Peaking Factor Limit Report is provided in accordance with Paragraph 6.9.1.12 of the Callaway Nuclear Plant Technical Specifications.

The F_{xy} limits for RATED THERMAL POWER (3411 MWt) within specific core planes for Cycle 2 shall be:

1. F_{xy}^{RTP} less than or equal to 1.89 for all planes containing bank "D" control rods, and
2. F_{xy}^{RTP} less than or equal to 1.65 for all unrodded core planes.

These $F_{xy}(z)$ limits were used to confirm that the heat flux hot channel factor $F_Q(z)$ will be limited to the Technical Specification values of:

$$F_Q(z) \leq \left[\frac{2.32}{P} \right] [K(z)] \quad \text{for } P > 0.5 \text{ and,}$$

$$F_Q(z) \leq [4.64] [K(z)] \quad \text{for } P \leq 0.5$$

assuming the most limiting axial power distributions expected to result from the insertion and removal of control banks B, C and D during operation, including the accompanying variations in the axial xenon and power distributions as described in the "Power Distribution Control and Load Following Procedures", WCAP-8403, September, 1974. Therefore, these F_{xy} limits provide assurance that the initial conditions assumed in the LOCA analysis are met, along with the ECCS acceptance criteria of 10CFR50.46.

See Figure 1 for a plot of $[F_Q^T \cdot P_{rel}]$ vs. Axial Core Height.




Figure 1
Maximum $F_Q^T \cdot P_{REL}$ Versus Axial Height
During Normal Core Operation