



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ILLINOIS POWER COMPANY, ET AL

DOCKET NO. 50-461

CLINTON POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 8
License No. NPF-62

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Illinois Power Company* (IP), Soyland Power Cooperative, Inc. and Western Illinois Power Cooperative, Inc. (the licensees) dated October 30, 1987 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-62 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised

*Illinois Power Company is authorized to act as agent for Soyland Power Cooperative, Inc. and Western Illinois Power Cooperative, Inc. and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

8808270095 380815
PDR ADECK 05000461
PNU

through Amendment No. 8, are hereby incorporated into this license. IP shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

for William L. Stoner
Daniel R. Muller, Director
Project Directorate II-2
Division of Reactor Projects - III,
IV, V and Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 15, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 8

FACILITY OPERATING LICENSE NO. NPF-62

DOCKET NO. 50-461

Replace the following page of the Appendix "A" Technical Specifications with the attached page. The revised page is identified by amendment number and contains vertical lines indicating the area of change.

Remove

3/4 8-14

Insert

3/4 8-14

ELECTRICAL POWER SYSTEMS

DC SOURCES - OPERATING

SURVEILLANCE REQUIREMENTS (Continued)

4.8.2.1 (Continued)

b) Division II

- > 462 amperes for the first 60 seconds
- ≥ 296 amperes for the next 59 minutes
- ≥ 108 amperes for the next 180 minutes

c) Division III

- > 112 amperes for the first 60 seconds
- ≥ 52 amperes for the next 239 minutes

d) Division IV

- > 127 amperes for the first 60 seconds
- ≥ 117 amperes for the next 59 minutes
- ≥ 44 amperes for the next 180 minutes

- e. At least once per 60 months, during shutdown, by verifying that the battery capacity is at least 80% of the manufacturer's rating when subjected to a performance discharge test. Once per 60 month interval, this performance discharge test may be performed in lieu of the battery service test.
- f. At least once per 18 months, during shutdown, performance discharge tests of battery capacity shall be given to any battery that shows signs of degradation or has reached 85% of the service life expected for the application. Degradation is indicated when the battery capacity drops more than 10% of rated capacity from its average on previous performance tests, or is below 90% of the manufacturer's rating.