B. Ralph Sylvia Senior Vice President

8808290282 880818 PDR ADOCK 05000341 PDC PDC



6400 North Dio e F ghway Newport, Mich gan 48166 (313) 586-4150

> August 18, 1988 NRC-88-0197

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington D. C. 20555

References: 1) Fermi 2 NRC Docket No. 50-341 NRC License No. NPF-43

- NRC Bulletin No. 87-02, "Fastener Testing to Determine Conformance rith Applicable Material Specifications" dated November 6, 1987
- Detroit Edison Letter to NRC, "Response to NRC Bulletin No. 87-02", NRC-88-0003, dated January 14, 1988
- Supplements 1 and 2 to the NRC Bulletin No. 87-02, dated April 22, 1988 and June 10, 1988
- Subject: Response to Supplements 1 and 2 to NRC Bulletin 87-02, and Submittal of Testing Results for Additional Fastener Sample

This letter is to submit Detroit Edison Company's response to Supplement 1 and 2 to Bulletin 87-02 (Reference 4), and to transmit testing results for an additional fastener sample selected in response to Bulletin 87-02.

Enclosure 1 provides a list of manufacturers and suppliers from which safety-related and non safety-related fasteners, under the scope of Supplement 1 and 2 to Bulletin 87-02, may have been purchased for Fermi 2 within the past 10 years. Information concerning manufacturer is not available for the cases where a supplier is not a manufacturer.

Enclosure 2 provides testing results for another sample of fasteners selected with the participation of the NRC Senior Resident Inspector, as committed in Reference 3. Further evaluation of a previous sample is also provided with this enclosure.

IE 57

USNRC August 18, 1988 NRC-88-0197 Page 2

If you have any questions, please contact Mr. Girija Shukla at (313) 586-4270.

Sincerely, Bhalph Sylin

64

3

Enclosures

1 . S

1

cc: Mr. A. B. Davis Mr. R. C. Knop Mr. T. R. Quay Mr. W. G. Rogers USNRC August 18, 1988 NRC-88-0197 Page 3

I, B. RALPH SYLVIA, do hereby affirm that the foregoing statements are based on facts and circumstances which are true and accurate to the best of my knowledge and belief.

Halph & B. RALPH SYLVIA

Senior Vice President

On this 8th day of *decycest* 1988, before me personally appeared B. Ralph Sylvia, being first duly sworn and says that he executed the foregoing as his free act and deed.

Marcia Buck Notary Public

MARCIA BUCK Notary Public, Washtenaw County, MI My Commission Expires Jan. 11, 1992

acting in Monrae Causty, Ni

.

ENCLOSURE 1

LIST OF MANUFACTURERS AND SUPPLIERS

| SUPPLIER | ITEM | SAFETY RELATED |
|---|--|----------------|
| Acme Bolt & Nut Co. | Bolt 18-8-SS | Yes |
| 414 S. Oakwood | | |
| Detroit, MI 48217 | | |
| Acme Bolt & Nut Co. | Bolts ASTM A-193 GR B7 | No |
| Acme Bolt & Nut Co. | Nut 18-8-83 | Yes |
| Acme Bolt & Nut Co. | Bolts C.S. Slotted | No |
| Acme Bolt & Nut Co. | Carriage Bolts C.S. GR5 | Yes |
| Acine Bolt & Nut Co. | Machipe Bolts C.S. GR5 | Yes |
| Acme Bolt & Nut Co. | Machine Screws SS W/Hex HD Nut | Yes |
| Acme Bolt & Nut Co. | Nuts C.S. | No |
| Acme Bolt & Nut Co. | Sheet Metal Screws | No |
| All Metal Screw Prod. | Bolts & Nuts S.S. | No |
| 1150 E. 9 Mile Rd. Ferndale, MI 48220 | | |
| All State Fastener 14495 E. 8 Mile Rd. | Nuts & Bolts ASTM A-325 | Yes |
| Warren, MI 《 8092 | | |
| All State Fristener | Head Cap Screw Zinc Gr.2 | No |
| All State Fastener | Hex Nuts Zinc | No |
| All State Fastener | Nuts & Screws C.S. | No |
| All State Fastener | Shoulder Screw Alloy Steel | No |
| All State Fastener | Bolt A-325 w/Nut | Yes |
| All State Fastener | Bolt A-490 w/Nut | Yes |
| All State Fastener | Bolts ASTM F467-81 | No |
| All State Fastener | Bolts ASTM A-193 GRB-7 | Yes |
| All State Fastener | Bolts ASTM A-325 | Yes |
| All State Fastener | Nuts ASTM A-563 GRC | Yes |
| All State Fastener | Screw UNC-2A | No |
| All State Fastener | Treaded Rod ASTM A-307 GRB | Yes |
| All State Fastener | Pan Head Screw CAD. | No |
| All State Fastener | 5/8" Hex Nuts & 3/4" Bolt A325 | No |
| All State Fastener | Bolt SAZ GR 2 | No |
| All State Fastener | Bolt Steel Cad PLTD | No |
| All State Fastener | Bolt w/Nut ASTM A-307 Bolts Cad. PLTD | No |
| All State Fastener | DOILS Cad. FLID | No |

1

| SUPPLIER | ITEM | SAFETY RELATED |
|--------------------|---|----------------|
| All State Fastener | Bolts S.S. ASTM A-193 GR B-8 | Yes |
| All State Fastener | Capscrews | No |
| All State Fastener | Nut Steel Cad PLTD | No |
| All State Fastener | Nut Steel Zinc CTD | Yes |
| All State Fastener | Nuts & Bolts Zinc | Yes |
| All State Fastener | Nuts ASTM A-194 | Yes |
| All State Fastener | Nuts S.S. ASTM A-194 GR. B | Yes |
| All State Fastener | Nuts Zinc | No |
| All State Fastener | Nuts Zinc Nuts-Ansi B18.2.2 Screw | Yes |
| All State Fastener | DOTON | Yes |
| All State Fastener | Screw Steel Cad PLTD | No |
| All State Fastener | Screws ANSI B18.3 | No |
| All State Fastener | Screws Nickel Plated | No |
| All State Fastener | Screws Zinc ASTM A-307 GR.2 | Yes |
| All State Fastener | Tek Screws | Yes |
| All State Fastener | Threaded Rod ASTM A-36 | Yes |
| All State Fastener | Threaded Rod, Zinc | No |
| All State Fastener | Bolts S.S. | Yes |
| All State Fastener | Nuts S.S. | Yes |
| All State Tastener | #14 Screws | No |
| All State Fastener | 1-1/2" Nuts and Bolts C.S. | No |
| All State Fastener | 2-1/4" Screws, Cadmium | No |
| All State Fastener | 1/2 " Hex Nuts & Screws S.S. | No |
| All State Fastener | 3/4" Hex Nuts A-194 B3 | No |
| All State Fastener | 3/4" Studs A-193 B8 | No |
| All State Fastener | 3/4" Studs A-193 B8 3/8" Galv Bolts | No |
| All State Fastener | 5/8" Hex Bolts Mild Steel | No |
| All State Fastener | A193-87 Studs | No |
| All State Fastener | All-Threaded Rod ASTM A-36 | Yes |
| All State Fastener | Bolts A-193 GRB8 Type 304 | Yes |
| All State Fastener | | Yes |
| All State Fastener | Cap Screw A-325 | Yes |
| All State Fastener | Cap Screws ANSI B18.6.3 | Yes |
| Al' State Fastener | Cap Screws ANSI B18.6.3 Capscrew 18-8 S.S. | Yes |
| All State Fastener | | Yes |
| All State Fastener | Coupling Nuts Zinc Plated | No |
| All State Fastener | Hex Nuts ASTM A-563 | 10 |
| All State Fastener | Eye Bolt ASTM Z325 | Yes |
| All State Fastener | Locknut UNC-2B | No . |
| All State Fastener | Nut 20 UNC-2B GR18-8 S.S. | Yes |
| All State Fastener | Nut ASTM A-563 GRA | Yes |

| SUPPLIER | ITEM | SAFETY RELATED |
|--|-----------------------------|----------------|
| All Stale Fastener | Nuts ASTM A-563 GRA | Yes |
| All State Fastener | Screw 20 UNC-3A GR18-8 S.S. | Yes |
| All State Fastener | Screw ASTM A-307 | Yes |
| All State Fastener | Screw ASTM A-574 | No |
| All State Fastener | Screws Zinc Coated | Yes |
| All State Fastener | Slotted Screw 18-8 S.S. | Yes |
| American Air Filter 17570 12 Mile Rd. Southfield, MI 48076 | Screw Fastner | No |
| American Bolt & Sup 2244 E. 14 Mile Rd. Warren, MI 48092 | 1/2" Bolt Stainless Steel | No |
| American Bolt & Sup | 1/2" Bolts, C.S. | No |
| American Bolt & Sup | 5/8" Cap Screws | No |
| Atwood & Morrill 285 Canal St. Salem, MA 01970 | Bolts | Yes |
| Atwood Ind 1315 Main Cleveland, OH 44113 | 3/8" Cap Screw | No |
| Atwood Ind. | 1-1/2" Bolts, High Tensile | No |
| Atwood Ind. | 1/2" Hex Nuts | No |
| Cardinal Ind Prod 3873 Cquendo Las Vegas, NV 89118 | Bolt A-307 | Yes |
| Cardinal Ind Prod | Bolt GR A ASTM A-307 | Yes |
| Cardinal Ind Prod | Bolts ASTM A-325 | Yes |
| Cardinal Ind Prod | Cap Screws SAE CR-5 | Yes |
| Cardinal Ind Prod | Nut ASTM A-563 | Yes |

| SUPPLIER | ITEM | SAFETY RELATED |
|---|-------------------------------|----------------|
| Cardinal Ind Prod | Nuts, HEX A-325 | Yes |
| Cardinal Ind Prod | 3/8" Hex Bolts A-307 GR2 | Yes |
| Cardinal Ind Prod | Nuts ASTM A-563 Type 307 | Yes |
| Cardinal Ind Prod | Threaded Stock A-307 | Yes |
| Cardinal Ind Prod | Bolts A-193 B-7 | Yes |
| Cardinal Ind Prod | Bolts A-490 | Yes |
| Cardinal Ind Prod | Nut 5/8" SS 304 ASTM A194GR8 | Yes |
| Cardinal Ind Prod | Nuts A-194 2H | Yes |
| Cardinal Ind Prod | Nuts F-436 | Yes |
| Cardinal Ind Prod | Bolt & Nuts S.S. | Yes |
| Chicago Bridge & Iron 20600 Chagrin Shaker Hts., OH 44122 | Bolt SA-193 GRB7 | Yes |
| Chicago Bridge & Iron | NUTS SA-194 GR4, 7 or 8 CL 2B | Yes |
| Chicago Bullet Equip 2250 Western Ave. Prk Forest, IL 60466 | 1/4"/20 Hex Nuts | No |
| Colt Ind 701 Lawton Av. Beloit, VI 53511 | Bolts | Yes |
| Colt Ind | Capscrews | Yes |
| Colt Ind | Locknuts | Yes |
| Crane Co. 884 South Broadway Salem, OH 44460 | 316 SS Screwa | No |
| Dragon Valves 13457 Excelsier Norwalk, CA 90650 | Capscrew | No |

| SUPPLIER | ITEM | SAFETY RELATED |
|--|--|---|
| English Electric 500 Executive Blvd. Elmsford, NY 10525 | //8" Studs, British Std | No |
| English Electric Fermi 2 Monroe, MI 48161 | Bolts, B.F. | No |
| English Electric English Electric | Bolts, Coupling & Nuts Bolts, Fitted Bolts, Off Caps, Hex Head w/Nuts Nuts BSF Nuts, Full & U.N. Nuts, Lock & U.N. Screw, Jacking BSP Screw, RSE Carriage Screws, Set Screws, Hex Screws, Set Studs, Nuts Studs, Nuts, Screws BS? | No No No No No No No No No No No No No N |
| F. B. Wright Co. 9999 Me cier Dearborn, MI 48121 | Hex Nut | Yes |
| General Electric 12000 Globe Rd. Livonia, MI 48150 | 2" Bolts, ASTM A-307A | No |
| General Electric 8157 S. Cass Ave. Darien, IL 60559 | Bolts ASTM A-193 B7 | No |
| General Electric General Electric | Nuts ASTM-194 Studs ASTM | No No |

| SUPPLIER | ITEM | SAFETY RELATED |
|---|----------------------------------|----------------|
| Gould Pumps Inc STE 3222 30600 Tele Birmingham, MI 48010 | Cap Screws ASTM A-193 GR B7 | Yes |
| Gould Pumps Inc | Nus ASTM A-194-2H | Yes |
| Gould Pumps Inc | Split Ring ASTM A-108 GR 1213 | Yes |
| GPE Controls 6511 W. Oakton Morton Grv., IL 60053 | Hex Bolts | Yes |
| Hilti 37473 Schoolcraft Livonia, MI 48150 | Hex Nuts | No |
| Ingersell Rand 888 Industrial Elmhurst, IL 60106 | Bolts | No |
| Ingersoll Rand | Bolts,Coupling | No |
| Ingersoll Rand 22122 Telegraph Southfield, MI 48075 | Coupling Bolts w/Nuts | No |
| Interstate Fastner 32458 W. 8 Mile Rd. Farmington, MI 48024 | Lolt, Machine | N¢ |
| Interstate Fastner | Nut, Hex Head | No |
| Interstate Fastener | Bolt, Hex Head w/Nut | No |
| Interstate Fastener | Nuts & Bolts A-307 | No |
| Interstate Fastener Interstate Fastener | Bolts, Machine Nuts, Hex Head | No No |
| Interstate Fastener | Bolts, A-325 | No |
| and a construction of the sector | | |

1

| SUPPLIER | ITEM | SAFETY RELATED |
|---|---|---|
| Interstate Fastener 6051 Telegraph Toledo, OH 43612 | Nuts & Bolts ASTM A-325 | Yes |
| ITT Grinnell 26155 Trolly Dr. Taylor, MI 48180 | Nuts SA-194-2H | Yes |
| ITT Grinnell | Stud SA-193 GR B7 | Yes |
| Johnston Pump Co. 154 Eisenhower LN.S. Lombard, IL 60148 | Capscrews, Allen | No |
| Joy Manufacturing 338 S. Broadway New Phil., OH 44663 | Nuts | No |
| Kilbourn Eng. Co 9226 W. Flagg Ave Milwaukee, WI 53225 | Nuts ASTM A-194 | Ves |
| Kilbourn Eng. Co. Kilbourn Eng. Co. | Nuts, Jam Studs ASTM A 193 GR B7 All Thread Bolt ASTM A-325 Bolt ASTM A-193 GR B7 Bolts ASTM A-307 Cspscraw ASTMA-193 Nuts ASTM A-194 GR 2H Nuts ASTM A-325 Nuts ASTM A-563 Bolts ASTM A-325 | Yes No Yes Yes Yes Yes Yes Yes Yes Yes |
| Kilbourn Eng. Co. | Bolts ASTM A-490 | Yes |

+

| SUPPLIER | ITEM | SAFETY RELATED |
|---|----------------------------------|----------------|
| Lone Star Screw P.O. Box 15211 Houston, TX 77020 | Bolt W/Nut ASTM A-325 | Yes |
| Lone Star Screw | Nuts & Studs GR-25 AE | Yes |
| Lone Star Screw | Misc Nuts & Screws S.S. | Yes |
| Marley Cooling TWR 1500 N. Stephenson Royal Oak, MI 48068 | 3/8-16 NC x 1-1/4" Cap Screws SS | Yes |
| MCC Powers Regulator 3400 Oakton Skokie, IL 60076 | Bolt | Yes |
| McCalley Tool & Sup 2874 Farmington Rd. Livonia, MI 48150 | Bolt, Hex Head | No |
| McCalley Tool & Sup | Nuts, Hex Head | No |
| McMaster Carr P.O. Box 4355 Chicago, IL 60680 | Button Head Socket 18-8 SS | Nc |
| McMaster Carr | Cap Screw | No |
| McMaster Carr | Capscrew GR5 Zinc | Yes |
| McMascer Carx | Lockeus | Yes |
| McMaster Carr | Nuis | No |
| McMaster Cari | Screw Zinc Gr. 5 | Yes |
| McMaster Carr | "hreaded Rod SS | No |
| McMaster Carr | Bolts Zinc GR. 2 | Yes |
| McMaster Carr | Nuts Zinc | Yes |
| McMaster Carr | Screws Zinc | No |
| | | |

1.

FASTENER MANUFACTURER AND SUPPLIER LIST FOR MERMI 2

•••

ſ

C

ĝ.

00

.

| SUPPLIER | ITEM | SAFETY RELATED |
|--|---------------------------------|----------------|
| Metric Components 8228 W. 47th St. Lyons, IL 60534 | Bolt & Nut BSF | No |
| Metric Components | BSW Screws | No |
| Monroe Welding 810 W. Front St. Monroe, MI 48161 | Nuts & Bolts ASTM A-325 | Yes |
| Monro: Welding Monroe Welding Monroe Welding | Bolt A-325 Nuts Studs | No No No |
| Premier Ind. 513 N. Dixie Hwy. Monroe, MI 48161 | 1-1/8" Hex Nut A-193 B7 | No |
| Premier Ind. Premier Ind. | Bolts, A-193 B7 T-Bolt & Nut | No Yes |
| Quality BDG/THRD Co. 5140 Stanton Detroit, MI 48208 | Nuts & Bolts ASTM A-325 | yes |
| Rexnord Ind. 22150 Greenfield Rd. Oak Park, MI 48237 | Bolt, Coupling | No |
| Rexnord, Inc. | Nut, Lock | No |
| Schrieber Mfg. Co. 1400 W. 14 Mile Rd. Clawson, MI 48017 | HH Nut | No |
| Schrieber Mfg.Co. | T-Bolt | No |

*

.

| SUPPLIER | ITEM | SAFETY RELATED |
|---|---|--|
| Spadone Mach. Co. 507 Westport Ave. Norwalk, CA 90650 | Bolt Hext, Nut,S.S. | No |
| Suburban Bolt & Supp. 27670 Groesbeck Roseville, M7. 48066 | Hex Nut S.S. | No |
| Talley Fastener 1616 Construction Dr. Kalamazoo, MI 49001 | Bolt ASTM A-325 | Yes |
| Talley Fastener Talley Fastener Talley Fastener Talley Fastener Talley Fastener Talley Fastener Talley Fastener Talley Fastener Talley Fastener | Bolts & Nuts Bolts ASTM A-307 GR B Nuts ASTM A-194 Nuts ASTM A-307 GR B Nuts SA-194 Stud SA-193 GR B7 Studs ASTM A-193-B7 Bolts & Nuts SS Nuts & Forews Zinc or Cad. PL | Yes Yes Yes Yes Yes Yes No No |
| Texas Bolt P.O.Box 1212 Rougton, TX 77001 | Nuts, ASIM A-194 | Yes |
| Texas Bolt Texas Bolt | Nuts, ASTM A-194-2H Studs, ASTM A-193 | Yes Yes |
| Trans Delaval 30161 Southfield Southfield, MI 48076 | '-3/4" Bolts & Nuts | No |
| U.S. Fastner Corp. 8100 Schoolcraft Detroit, MI 48238 | 2" ASTM 325 Gal Bolts | No |

.

| SUPPLIER | ITEM | SAFETY RELATED |
|--|--|----------------|
| Wayne Bolt & Nut 14471 Livernois Detroit, MI 48238 | Bolt GR18-8 S.S. | No |
| Wayne Bolt & Nut Wayne Bolt & Nut | Screw Cad PLTD Stl Bolt & Nut A-325 | No No |
| Williams Form Eng. Co. 1501 Madison Ave. Grand Rpds., MI 49507 | Nuts, Hex | Yes |
| Y. C. Smith 900 Tower Dr. Troy, MI 48098 | Bolts/Nuts | No |

ENCLOSURE 2

TESTING RESULTS FOR ADDITIONAL SAMPLE OF FASTENERS AND FURTHER EVALUATION OF A PREVIOUS SAMPLE

o Response to Bulletin 87-02 Action Nos. 2 through 4

Forty (40) different samples were obtained from stock in warehouse A and B, with the participation of the NRC Senior Resident Inspector. Of the selected samples, 30 were sent to Detroit Edison's Engineering Research Laboratory and 10 were sent to Consumers Fower Company for testing per NRC Bulletin 87-02 Action No. 4.

Identification system for samples is as follows.

Fasteners testing data and fasteners test reports are given in Attachment 1 and 2, respectively.

o Response to Bulletin 87-02 Action Nos. 5 and 6

The results of tests are provided under Test Reports as requested per requisition tabled below.

| Test Report | Requisition |
|----------------|-------------|
| 88071-6 | 685-350 |
| 87071-7 Rev. 1 | \$85-361 |
| 83071-8 | 685-362 |
| BEM project | |
| 138854-101-001 | 685-359 |
| | |

Summary sheets have been completed for each sample and are provided in Attachment 2.

Based upon test reports all but four samples were found to meet the requisite specification requirements. Engineering Research Report 88C63-7 has evaluated these four test results and found two test results for samples BF2ND-3 and BF2ND-6 having only typographical errors. These samples did meet the specification requirements. Sample BF2NN-1 is acceptable for use with the exception that the nut should not be welded. These are non-safety related nuts that are used in non-safety related applications. Sample BF2QB-4 was found to be having lower carbon content but determined to be acceptable for its intended use. Based on these conclusions the use of these fasteners is acceptable and do not adversely impact the quality or safety of the plant. Thus, the recommendation for additional testing to determine the variability of the bolt lot was not followed.

As per Engineering Research report 88C71-6 samples EF2QN3 and 6 were found to be out of Specification for carbon content (0.398 and 0.399 vs. 0.4 minimum). However, the review indicated that this insignificant variation from Specification does not adversely impact the quality of the sample and all other properties met the Specification requirements. Thus, this sample was concluded to be acceptable for its intended use.

o Further Evaluation of the Previous Sample No. DENB-9

Enclosure 2 of Reference 3 stated that per Engineering Research Report 87C71-21, Revision 2, Sample No. DENB-9 was found to be much barder than the Specification requirements and is being further evaluated by the Detroit Edison Engineering Research Department.

Two more samples from the same bin were tested and per Engineering Research Report 88071-5 found to demonstrate the same physical and chemical properties as the sample DENB-9. By further investigation of paperwork and inquiring with the vendor, it was identified that though grade-2 or equivalent bolts were requested, grade-8 bolts were ordered and received. These high strength fasteners are susceptible to failure by stress corrosion cracking. However, it was concluded by calculations that stress corrosion cracking will not be expected for these bolts due to their use in grade-2 applications. Of the 100 tieces bought, 6 have been used in the plant, 3 were destroyed in the test, and 91 still in stock are being scrapped. Since these bolts are being scrapped, the recommendation for additional testing to verify stress corrosion cracking resistance was not followed.

Those used in the plant are non-safety related bolts in non-safety related applications and do not adversely impact the quality or safety of the plant. No further action is required on this sample.

ATTACHMENT 1

Fasteners Testing Data Sheets

Fastener Testing Data Sheet

* Sample ID# EF2QB-1 P.O.#317976 REQ.#5-586937

Fastener Description: 1/2" -13x3" STUD

Description of Sample Stock Location: B1-RR-4E

Material Specification as Documented by Licensee Records: SA193 GR. B7 ASME III CL.2

Head Marking (Specification and Manufacturer): KB7/XXZ

******Class/Procurement Level: SAFETY-RELATED (Q)

General Plant Application (e.g., Prossure Boundary, Structural) PRESSURE BOUNDARY

Supplier: SAME

Manufacturer: KILBOURN ENGINELAING CO. INC. 9226 W. FLAGG AVE. MILWAUKEE, WI. 53225

QA Requirements imposed on Vendor: STANDARD ATTACHMENT 11A, ASME III CL 2 1971/WINTER 1972

Licensee Representative: S. SHARMA

Signature

1. Sharm Date 6.20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

EFZOB-1

Standard Attachment - 11 Rev. A Pace 1 of 2

QUALITY ASSURANCE PROCUREMENT CONDITIONS - NUCLEAR SAFETY-RELATED

SHIPPING IDENTIFICATION: All material shipped against this order must be tagged with the Edison purchase order and item number or with the Edison number so that identification is clear. Similarly, the packing slip must identify all stems included in the shipment so that comparison may be made against the Edison purchase order. All communication on this order must be in the English language. To expedite payment of your invoice, each line item invoiced must reference the corresponding purchase order line item and Edison number if applicable. Failure to comply with any of these requirements may constitute cause to reject a shipment.

NO SUBSTITUTIONS TO THIS P.O. No substitutions are authorized. Should the vendor be unable to fill this purchase order exactly as written and in compliance with the referenced specifications and codes, the vendor shall promptly notify Detroit Edison Company in writing prior to proceeding with the questionable item. Alteration or modification of the requirements of this purchase order can be made only by a written change to this purchase order. Upon receipt, this order will be inspected for conformance to requirements. Non-conforming items will be rejected.

CERTIFICATE OF CONFORMANCE: The vendor shall provide a certificate of conformance stating that the items furnished meet the requirements of this purchase order.

<u>AIGHT OF ACCESS</u>: Upon request, personnel from Detroit Edison Company or its authorized agent shall be permitted access to the vendors or his subteir supplier's facilities and records (other than commercial grade vendors) for the purpose of performing inprocess inspections, final inspections or other inspections and audit activities pertinent to the items ordered herein. The vendor shall advise Detroit Edison Company of any advance notice requirements which must be met in order to gain access to said premises.

FEDERAL REG., PART 21: Work performed on this purchase order involves a safety related item, defined by Edison as QA Level I, for installation in a nuclear power plant and is subject to the requirements of Title 10 Code of Federal Regulations, Part 21. In particular we draw your attention to Faragraph 21.21 (A) (1) (ii).

ANSI 45.2.2: This shipment shall be prepared in such a manner as to ensure arrival at the destination in an undamaged condition and shall conform to ANSI N 45.2.2. "Packaging Shipping, Receiving, Storage and Handling of Items for Nuclear Power Plants" for Level B storage. Each part shall be packaged for long term storage, with adequate moisture protection required.

100/8290/9.14 062884

EF288-1

1 . A.

-

QUALITY ASSURANCE PROCUREMENT CONDITIONS - NUCLEAR SAFETY-RELATED

ANSI 345.2 - 1977: The vendor/manufacturer and subtier supplier shall ensure that they have implemented a quality assurance program that meets or exceeds all requirements of ANSI N45.2 - 1977 "Quality Assurance Requirements for Nuclear Power Plants", in addition to other codes and standards listed.

100/R290/9.15 062884

4

Fastener Testing Data Sheet

* Sample ID# EF2QB-2 P.O.#317898 REQ.#5-586738

Fastener Description: 1-1/8" -12x6-1/4" BOLT

1

* 6

Description of Sample Stock Location: B1-NN-2B

Material Specification as Documented by Licensee Records: SA193 GR.B7 ASME III CL.1

Head Marking (Specification and Manufacturer): BTS B7 LICS

**Class/Procurement Level: SAFETY-RELATED (Q)

General Plant Application (e.g., Pressure Boundary, Structural) PRESSURE BOUNDARY

Supplier: G.E. CO. 175 CURTNER AVE. SAN JOSE, CALIF. 95125

Manufacturer: BETHLEHEM STEEL

QA Requirements Imposed on Vendor: STANDARD ATTACHMENT 13A, ASME III CL.1

Licensee Representative: S. SHARMA

| Ji fleccere | Date | 6.20.88 |
|-------------|------|---------|
| | | - |

*The sample IV# shall have a prefix that contains the licensee facility initials.

.

GE SPARE PARTS CONTRACT - NUCLEAR SAFETY-RELATED ITEMS

SHIPPING IDENTIFICATION: All material shipped against this order must be tagged with the Edison purchase order and item number or with the Edison number so that identification is clear. Similarly, the packing slip must identify all items included in the shipment so that comparison may be made against the Edison purchase order. All communication on this order must be in the English language. To expedite payment of your invoice, each line item inviced must reference the corresponding purchase order line item and Edison number if applicable. Failure to comply with any of these requirements may constitute cause to reject a shipment.

GENERAL ELECTRIC CONTRACT: This purchase order shall be processed in accordance with General Electric and Detroit Edison Spare Parts Contract 1E-86783. All special requirements sust be specified or if no special requirements, this also must be specified to purchaser in writing prior to shipment.

NO SUBSTITUTIONS TO ORIGINAL P.O.: No substitutions are authorized. Should the vendor be unable to fill this purchase order exactly as written and in accordince with the requirements of the original purchase order, the vendor shall promptly notify Detroit Edison Company in writing prior to proceeding with the questionable item. Such notification shall provide a statement of the code, design or other process change and justification for attesting to the functional equivalency of the item to that furnished with the original equipment. Alterations or modification of the requirements of this purchase order can be made only by a written change to this purchase order. Upon receipt, this order will be inspected for conformance to requirements. Non-conforming items will be rejected.

FEDERAL REG., PART 21: Work performed on this purchase order involves a safety-related item, defined by Edison as QA Level I, for installation in a nuclear power plant and is subject to the requirements of Title 10 Code of Federal Regulations, Part 21. In particular we draw your attention to Paragraph 21.21 (A) (1) (11).

100/R290/9.8 061984

Fastener Testing Data Sheet

* Sample ID# EF2QB-3 P.O.#296178 REQ.#5-490676

Fastener Description: 1-1/4" -7x3-3/4" CAP SCREW

Description of Sample Stock Location: B1-UU-38A

Material Specification as Documented by Licensee Records: ASTM A449

Head Marking (Specification and Manufacturer):

**Class/Procurement Level: SAFETY-RELATED (CQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: WM. POWELL CO. P.O. BOX 14006 2503 SPRING GROVE AVE. CINCINNATI, OHIO 45214

Manufacturer: N/A - Not Available.

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

J. Mun Date 6.20.88

*The sample ID# shall have a profix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2QB-4 P.O.#149481 REQ.#606-890

Fastener Description: 1/2" -13x1-1/2" BOLT

Description of Sample Stock Location: B1-UU-380

Material Specification as Documented by Licensee Records: SAE J429 GR.5

Head Marking (Specification and '_ ufacturer): LE

******Class/Procurement Level: SAFETY-RELATED (Q)

General Plant Application (e.g., Pressure Boundary. Structural) STRUCTURAL

Supplier: HUB INC. 2146 FLINTSTONE DR. TUCKER, GEORGIA 30085

Manufacturer: CARDINAL PRODUCTS INC. 3873 WEST OQUENDO LAS VEGAS, NEVADA 39118

QA Requirements Imposed on Vendor: CERT. OF CONFORMANCE

Licensee Representative: S. SHARMA

Signature

Thur Date 6.20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2QB-5 REQ.#587016

Fastener Description: 1-1/4" -7x8 BOLT

Description of Sample Stock Location: WHSE A (1B)

Material Specification as Documented by Licensee Records: ASTM A449

Head Marking (Specification and Manufacturer):

**Class/Procurement Level: SAFETY-RELATED (CQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: N/A - NOT Available.

Manufacturer: THE TRIAD METAL PRODUCTS CO. 14701 INDUSTRIAL PKWY., S.W. CLEVELAND, OHIO 44435

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature S. Share Date 6-20-88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2QB-6 REQ.#527736

Fastener Description: 3/4" -10x2" BOLT

Description of Sample Stock Location: WHSE A

Material Specification as Documented by Licensee Records: ASTM A325

Head Marking (Specification and Manufacturer):

**Class/Procurement Level: SAFETY-PELATED (CQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL Supplier: GENERAL FASTENERS CO., 11820 GLOBE RD, LIVONIA, MI. 48150 Manufacturer: N/A - NOt Available

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

J. Shurn Date 6.20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2QB-7 REQ.#587016

Fastener Description: 1/2" -13x1-1/4" BOLT

Description of Sample Stock Location: WHSE A

Material Specification as Documented by Licensee Records: SAE J429 GR.5

Head Marking (Specification and Manufacturer):

**Class/Procurement Level: SAFETY-RELATED (CQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: N/A - Not Available.

Manufacturer: THE TRIAD METAL PRODUCTS CO. 14701 INDUSTRIAL PKWY., S.W. CLEVELAND, OHIO 44435

QA Requirements Imposed on Vendor: NONE

Licensce Representative: S. SHARMA

J. Share Date 6.20-88 Signature

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2QB-8 REQ.#491301

Fastener Description: 5/16" -24x1-1/2" BOLT

Description of Sample Stock Location: WHSE A

Material Specification as Documented by Licensee Records: SAE J429 GR.5

Head Marking (Specification and Manufacturer):

**Class/Procurement Level: SAFETY-RELATED (CQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL Supplier: N/A - Not Available

Manufacturer: THE TRIAD METAL PRODUCTS CO. 14701 INDUSTRIAL PKWY., S.W., CLEVELAND, OHIO 44135

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

61

Signature

- Share Date 620-88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2QB-9 REQ.#414577

Fastener Description: 5/8" -18x1" BOLT

Description of Sample Stock Location: WHSE A

Material Specification as Documented by Licensee Records: SAE J429 GR.5

Head Marking (Specification and Manufacturer):

 $\downarrow \Delta$

**Class/Procurement Level: SAFETY-RELATED (CQ)

General Plane Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: ALL-STATE FASTENER CORPORATION 14495 EIGHT MILE RD. P.O. BOX 356 EAST DETROIT, MI. 48021

Manufacturer: THE TRIAD METAL PRODUCTS CO. 14701 INDUSTRIAL PKWY., S.W., CLEVELAND, OHIO 44135

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

Date 6-20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2QB-10 REQ.#587016

Fastener Description: 7/8" -9x4" BOLT

Description of Sample Stock Location: WHSE A

Material Specification as Documented by Licensee Records: SAE J429 GR.5

Head Marking (Specification and Manufacturer):

**Class/Produrement Level: SAFETY-RELATED (CQ)

General Flant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

N/A - Not Available Supplier:

Manufacturer: THE TRIAD METAL PRODUCTS CO. 14701 INDUSTPIAL PKWY., S.W., CLEVELAND, OHIO 44135

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature S. Sharm Date 6.20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2QN-1 P.O.#142816 REQ.#R0256436

Fastener Description: 1-1/8"-7 NUT

Description of Sample Stock Location: B1MM3C

Material Specification as Documented by Licensee Records: SA194 GR.B7 ASME III CL.1

Head Marking (Specification and Manufacturer): K7B AUX

******Class/Procurement Level: SAFETY-RELATED (Q)

General Plant Application (e.g., Pressure Boundary, Structural) PRESSURE BOUNDARY

Supplier: SAME

Manufacturer: KILBOURN ENGINEEERING CO. INC. 9226 W. FLAGG AVE. MILWAUKEE, WI. 53225

QA Requirements Imposed on Vendor: CMTR W/STATEMENT OF HEAT TREATMENT, CHARPY V-NOTCH TEST, MAGNETIC PARTICLE OR LIQUID PENETRANT EXAMINATION REPORT, C OF C TO ASME III CL. 1

Licensee Representative: S. SHARMA

Signature

Man Date 6.20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fartener Testing Data Sheet

* Sample ID# EF2QN-2 P.O.#129663 REQ.#R0256435

Fastener Description: 7/8" -9 NUT

1 '

Description of Sample Stock Location: B1WW9E.

Material Specification as Documented by Licensee Records: SA 194 GR.2H ASME III CL.1

Head Marking (Specification and Manufacturer): 2HB (X18)HEAT

******Class/Procurement Level: SAFETY-RELATED (Q)

General Plant Application (e.g., Pressure Boundary, Structural) PRESSURE BOUNDARY

Supplier: TIOGA PIPE SUPPLY CO. INC. 2450 WHEATSHEAF LANE P.O. BOX 5997 PHILADELPHIA, PA. 19137

Manufacturer: VITCO NUCLEAR PROLJCTS, INC. 4445 HAMANN PKWY. WILLOUGHBY, OHIO 44094

QA Requirements Imposed on Vendor: STANDARD ATTACHMENT 16B

Licensee Representative: S. SHARMA

Signature . . Ilen Date 6.20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

FF20N-2

Standard Attachment - 16 Rev. B Page 1 of 2

CONTROLLED

ASME PROCUREMENT CONDITIONS - NUCLEAR SAFETY-RELATED

SHIPPING IDENTIFICATION: All material shipped against this order must be tagged with the Edison purchase order and item number or with the Edison number so that identification is clear. Similarly, the packing slip must identify all items included in the shipment so that comparison may be made against the Edison purchase order. All communication on this order must be in the English language. To expedite payment of your invoice, each line item invoiced must reference the corresponding purchase order line item and Edison number if applicable. Failure to comply with any of these requirements may constitute cause to reject a shipment.

NO SUBSTITUTIONS TO THIS P.O.: No substitutions of **Items**, parts, of **materials** are authorized. Should the vendor be unable to fill this purchase order exactly as written and in accordance with the referenced **Decifications and codes**, the vendor shall promptly notify Detroit Edison Company in writing prior to proceeding with the questionable item. Such notification shall provide a statement of the code, design or other process change and justification for attesting to the functional equivalency of the item to that specified by this order. Alterations or modification of the requirements of this purchase order can be made only by a written change to this purchase order. Upon receipt, this order will be inspected for conformance to requirements. Nonconforming items will be rejected. If referenced, this order must also be filled in Accordance with the requirements of the requirements of the requirements also be filled in

CERTIFICATE OF CONFORMANCE TO THIS P.O. AND ASME III: The vendor shall provide a Certificate of Conformance stating that the items furnished meet the requirements of this purchase order, and if referenced, the requirements of Editori Doriginal purchase order, and that the material meets the requirements of the ASME Boiler Pressure Vensel Code, Section III, subsections NB-(Class-1), NC-(Class-2), or ND-(Class-3) as applicable for each line item. The vendor shall meet the requirements of the ASME Code Section III, 1971 and winter addenda 1972 or an equal later edition. The year and addenda c2 the ASME Code for which each line item is manufactured shall be identified. When an original purchase order in referenced, the vendor shall list the briginal and correct purchase order numbers on the Certificate of Conformance.

RIGHT OF ACCESS: Upon request, personnel from Detroit Edison Company or its authorized agent shall be permitted access to the vendor's or his subtier supplier's facilities and records (other than comme ial grade vendors) for the purpose of performing inprocess inspections, final inspections or other inspections and audit activities pertinent to the items ordered herein. The vendor shall advise Detroit Edison Company of any advance notice requirements which must be met in order to gain access to said premises.

LMP/100/R477/7.0 101685

ATMS - INCORMATION SYSTEMS PAGE PRV 3 PIS OCT 1 8 1985 # 7 55 RECIPIENT NO



Standard Attachment - 16 Rev. B Page 2 of 2

ASME PROCUREMENT CONDITIONS - NUCLEAR SAFETY-RELATED

FEDERAL REG., PART 21: Work performed on this purchase order involves a safety-related item, defined by Edison as QA Level I, for installation in a nuclear power plant and is subject to the requirements of Title 10 Code of Federal Regulations, Part 21. In particular we draw your attention to Paragraph 21.21 (a) (1) (ii).

ANSI N45.2.2: This shipment shall be prepared in such a manner as to ensure arrival at the destination in an undamaged condition and shall conform to ANSI N45.2.2. "Packaging Shipping, Receiving, Storage and Handling of Items for Nuclear Power Plants" for Level B storage. Each part shall be packaged for long term storage, with adequate moisture protection required.

ANSI N45.2 - 1977: The vendor/manufacturer and subtier supplier shall ensure that they have implemented a quality assurance program that meets or exceeds the applicable sections and elements of ANSI N45.2 - 1977 "Quality Assurance Requirements for Nuclear Power Plants", in addition to other codes and standards listed.

NONCONFORMANCES: Nonconformances shall contain a proposed disposition and be sumitted for approval to: Detroit Edison, 6400 North Dixie Highway, Newport, MI 48166, Attention: Approval Control (136 EF2 NOC).

The transmittal letter should reference the Edison PO number. The following types of nonconformances shall be submitted:

n. Nonconformance to technical or material requirements.

-

b. Nonconformance to vendor documents previously approved by Edison.

c. Nonconformance to original requirements even though the item can be restored to a condition such that the capability of the item to function is unimpaired.

A copy of the Edison approved nonconformance shall be shipped with the itea.

Fastener Testing Data Sheet

* Sample ID# EF2QN-3 P.O.#A118500 REQ.#415-475

Fastener Description: 5/8" -11 NUT

ŵ

Description of Sample Stock Location: B1-UU-11C

Material Specification as Documented by Licensee Records: ASTM A194 GR.2H

Head Marking (Specification and Manufacturer): 2H T EQ44

******Class/Procurement Level: SAFETY-RELATED (Q)

General Plant Application (e.g., Pressure Boundary, Structural)

Supplier: WM. POWELL CO. 2503 SPRING GROVE RD. P.O BOX 145434 CINCINNATI, OHIO 45214

Manufacturer: TEXAS BOLT CO. P.O. BOX 1211 HOUSTON, TEXAS 77001

QA Requirements Imposed on Vendor: SEE ATTACHED

Licensee Representative: S. SHARMA

- There Date 6.20.88 Signature

*The sample ID# shall have a prefix that contains the licensee facility initials.

2) CMTR'S WITH HEAT PREAT REPORTS - ALL TRONS REQUIREMENTS - The Manufacturer shall meet the Requirements of the ASME BULER PLESSURE VESSEL CODE, Section - 1971 1) LERTIFICATE OF Can TORMANCE - ALL TTENS EDITION AND WINTER HODENDA, AND SHALL PROVIDE 3) MIT RAY AND PLY INSPECTION CEPERS - I'M & R. Lare 4/19/84 nout as 2-84 CERTIFICATION TO THESE REQUEREMENTS. CF2BN-31 N-2 CODE DATA REPORT REQUIRED. CERTIFICATIONS -ASHE

CERTIFICATE OF CONFORMANCE

E-NBN-3

THE VOUCOR SHALL PROVIDE A CERTIFICATE OF CONFORMANCE STATING THAT THE ITENS ORGRED HEREIN MEET THE REQUIREMENTS OF THIS PURCHASE ORDER.

RIGHT OF ACCESS

EF28N-3

AND RECORDS FOR THE PURPOSE OF PERFORMING INPROCESS INSPECTIONS, FINAL INSPECTIONS, The vendor shall advise detroit edison coppany of any advance notice requirents or other inspections and addit activities pertinent to the items ordered herein. SHALL BE PERMITTED ACCESS TO THE VENDORS OR HIS SUBTEIR SUPPLIER'S FACILITIES UPON REGLEST, PERSONAL FROM DETROIT EDISON COMPANY OR ITS AUTHORIZED AGENT WHICH MUST HE MET IN ORDER TO GAIN ACCESS TO SAID PREMISES. ****

.....

EF202N-3 FEDERAL REG., PART 21

PART 21. IN PARTICULAR WE INAW YOUR ATTENTION TO PARAGRAPH 21.21 (A) (1) (11). IS SUBJECT TO THE REQUIREMENTS OF TITLE 10 CODE OF FEDERAL REGULATIONS. WORK PERFORMED ON THIS PURCHASE ORDER INVOLVES A SAFETY RELATED ITEM. LEFINED AS GALEVEL 1, FOR INSTALLATION IN A NUCLEAR POWER PLANT AND

MSI 45.2.2

C-N BH3

THIS SHIPPENT SHALL RE PREPARED IN SUCH A MANUER AS TO ENSURE ARRIVAL ANSI N 45.2.2. "PROCAGING SHIPPING, RECEIVING, STORAGE AND HANDLING OF ITEMS FOR NUCLEAR POWER PLANTS" FOR LEVEL B STORAGE. EACH PART AT THE DESTINATION IN AN UNDAMAGED CONDITION AND SHALL CONFORM TO SHALL BE PACKAGED FOR LONG TERM STORAGE, WITH ALEQUATE MOISTURE PROTECTION REQUIRED.

ANSI N45.2 - 1977 EF28.K-3

THE VENDOR/MANUFACTURE AND SUBTIER SUPPLIER SHALL ENSURE THAT THEY HAVE IMPLEMENTED A GUALITY ASSURANCE PROGRAM THAT MEETS OR EXCEEDS ALL REQUIRE-MENTS OF ANSI N45.2 - 1977 "QUALITY ASSURANCE REQUIREMENTS FOR NUCLEAR POWER PLANTS", IN ADDITION TO OTHER CODES AND STANDARDS LISTED.

Fastener Testing Data Sheet

* Sample ID# EF2QN-4 P.O.#106235 REQ.#5575224

Fastener Description: 1-1/4" -8 NUT

Description of Sample Stock Location: B1F19B

Material Specification as Documented by Licensee Records: SA194 GR.2H ASME III CL.3

Head Marking (Specification and Manufacturer): 2H P53

**Class/Procurement Level: SAFETY-RELATED (Q)

General Plant Application (e.g., Pressure Boundary, Structural) PRESSURE BOUNDARY VALVE PART

Supplier: WM. POWELL CO. P.O BOX 145434 CINCINNATI, OHIO 45214

Manufacturer: TEXAS BOLT CO. 3233 WEST 11TH ST. P.O BOX 1211 HOUSTON, TEXAS 77001

QA Requirements Imposed on Vendor: STANDARD ATTACHMENT 16A, CMTR W/STATEMENT OF HEAT TREATMENT, C OF C TO P.O. 1E86734.

Licensee Representative: S. SHARMA

Signature

S. Man Date 6-20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

2

.

ASME PROCUREMENT CONDITIONS - NUCLEAR SAFETY-RELATED

SHIPPING IDENTIFICATION: All material shipped against this order must be tagged with the Edison purchase order and item number or with the Edison number so that identification is clear. Similarly, the packing slip must identify all items included in the shipment so that comparison may be made against the Edison purchase order. All communication on this order must be in the English language. To expedite payment of your invoice, each line item invoiced must reference the corresponding purchase order line item and Edison number if applicable. Failure to comply with any of these requirements may constitute cause to reject a shipment.

NO SUBSTITUTIONS TO ORIGINAL P.O.: No substitutions are authorized. Should the vendor be unable to fill this purchase order exactly as written and in accordance with the requirements of the original purchase order, the vendor shall promptly notify Detroit Edison Company in writing prior to proceeding with the questionable item. Such notification shall provide a statement of the code, design or other process change and justification for attesting to the functional equivalency of the item to that furnished with the original equipment. Alterations or modification of the requirements of this purchase order will be inspected for conformance to requirements. Non-conforming items will be rejected.

CERTIFICATE OF CONFORMANCE TO ASME: The vendor shall supply, with the material, a certificate of conformance stating that the items furnished meet the requirements of this purchase order and that the material meets the requirements of the ASME Boiler Pressure Vessel Code, Section III, subsections NB-(Class-1), NC-(Class-2) or ND-(Class-3) as applicable for each line item. The vendor shall meet the requirements of the ASME Code Section III, 1971 and winter addenda 1972 or an equal later edition. The year and addenda of the ASME Code for which each line item is manufactured shall be identified.

RIGHT OF ACCESS: Upon request, personnel from Detroit Edison Company or its authorized agent shall be permitted access to the vendor's or his subtier supplier's facilities and records (other than commercial grade vendors) for the purpose of performing inprocess inspections, final inspections or other inspections and audit activities pertinent to the items ordered herein. The vendor shall advise Detroit Edison Company of any advance notice requirements which must be met in order to gain access to said premises.

FEDERAL REG., PART 21: Work performed on this purchase order involves a safety-related item, defined by Edison as QA Level I, for installation in a nuclear power plant and is subject to the requirements of Title 10 Code of Federal Regulations, Part 21. In particular we draw your attention to Paragraph 21.21 (A) (1) (ii).

100/R296/9.0. 062884 Page 1 of 2

Standard Attachment - 16 Rev. A Jaco 2 = 2 L ..

.

EF2 GN-4

ASME PROCUREMENT CONDITIONS - NUCLEAR SAFETY-RELATED

ANSI 45.2.2: This shipment shall be prepared in such a manner as to ensure arrival at the destination in an undamaged condition and shall conform to ANSI N 45.2.2. "Packaging Shipping, Receiving, Storage and Handling of Items for Nuclear Power Plants" for Level B storage. Each part shall be packaged for long term, storage, with adequate moisture protection required.

ANSI N45.2 - 1977: The vendor/manufacturer and subtier supplier shall ensure that they have implemented a quality assurance program that meets or exceeds all requirements of ANSI N45.2 - 1977 "Quality Assurance Requirements for Nuclear Power Plants", in addition to other codes and standards listed.

Fastener Testing Data Sheet

* Sample ID# EF2QN-5 P.O.#1D50859 REQ.#C-3732-P

Fastener Description: 3/4" - 10 NUT

Description of Sample Stock Location: WHSE. A

Material Specification as Documented by Licensee Records: ASTM A563 GR.C

Head Marking (Specification and Manufacturer):

**Class/Procurement Level: (CQ) SAFETY-RELATED

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: INTERSTATE FASTENER 32458 W. 8 MILE RD. FARMINGTON, MI. 46024

Manufacturer: N/A - Not Available

QA Requirements Imposed on Vendor: NONE, DEDICATED UNDER REQ.#587-202.

Licensee Representative: S. SHARMA

Signature

1. Man Date 6.20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2QN-6 P.O.#A119303 REQ.#5-415151

Fastener Description: 3/4" -10 WT

Description of Sample Stock Location: B1WW9B

Material Specification as Documented by Licensee Records: SA194 GR.2H ASME III CL.1

Heed Marking (Specification and Manufacturer): 2H T P51

******Class/Procurement Level: SAFETY-RELATED (Q)

General Plant Application (e.g., Pressure Boundary, Structural) VALVE - PRESSURE BOUNDARY

Supplier: WM. POWELL CO. P.O. BOX 14006 CINCINNATI, OHIO 45214

Manufacturer: TEXAS BOLT CO. 3233 WEST 11TH ST. P.O. BOX 1211 HOUSTON, TEXAS 77001

QA Requirements Imposed on Vendor: C OF C ASME III CL.1, CMTR'S W/HEAT TREAT REPORT, CERT. OF CONFORMANCE, 10CFR PART 21.

Licensee Representative: S. SHARMA

Signature

J. Shurrow Date 6.20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2QN-7 P.O.#104347 REQ.#587-613

Fastener Description: 1-1/4" -7 NUT

Description of Sample Stock Location: B1WW14G

Material Specification as Documented by Licensee Records: ASTM A194 GR.2H

Head Marking (Specification and Manufacturer): 2H E

**Class/Procurement Level: SAFETY-RELATED (CQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: GENERAL FASTENERS CO. 11820 GLOBE RD. LIVONIA, MI. 48150

Manufacturer: EATON MFG. 75

QA Requirements Imposed on Vendor: STANDARD ATTACHMENT 51A

Licensee Representative: S. SHARMA

Signature _____ Date _____ Date _____ .20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Standard Attachment - 51 Rev. A

PROCUREMENT INSTRUCTIONS TO OUR MANUFACTURER/SUPPLIER

EF28N-7

SHIPPING IDENTIFICATION: All material shipped against this order must be tagged with the Edison purchase order and item number or with the Edison number so that identification is clear. Similarly, the packing slip must identify all items included in the shipment so that comparison may be made against the Edison purchase order. All communication on this order must be in the English language. To expedite payment of your invoice, each line item invoiced must reference the corresponding purchase order line item and Edison number if applicable. Failure to comply with any of these requirements may constitute cause to reject a shipment.

NO SUBSTITUTIONS TO THIS P.O. No substitutions are authorized. Should the vendor be unable to fill this purchase order exactly as written and in compliance with the referenced specifications and codes, the vendor shall promptly notify Detroit Edison Company in writing prior to proceeding with the questionable item. Alteration or modification of the requirements of this purchase order can be made only by a written change to this purchase order. Upon receipt, this order will be inspected for conformance to requirements. Non-conforming items will be rejected.

Fastener Testing Data Sheet

* Sample ID# EF2QN-8 P.O.#A118687 REQ.#5-446730

Fastener Description: 1" -8 NUT

Description of Sample Stock Location: B1JJ49B

Material Specification as Documented by Licensee Records: ASTM A194 GR.2H

Head Marking (Specification and Manufacturer): 2H B K AHC

******Class/Procurement Level: SAFETY-RELATED (Q)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: SAME

Manufacturer: KILBOURN ENGINEERING CO. 9226 WEST FLAG AVE. MILWAUKEE, WI. 53225

QA Requirements Imposed on Vendor: CMTR, C OF C

Licensee Representative: S. SHARMA

Signature

J. Shure ... Date 6.20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2QN-9 P.O.#143057 REQ.#R0258748

Fastener Description: 1-1/8" -12 NUT

Description of Sample Stock Location: B1NN2C

Material Specification as Documented by Licensee Records: SA194 GR. 7 ASME III CL.1

Head Marking (Specification and Manufacturer): HS 7B CWB

******Class/Procurement Level: SAFETY-RELATED (Q)

General Plant Application (e.g., Pressure Boundary, Structural)

Supplier: GENERAL ELECTRIC CO. ORDER SERVICE M/C 847 175 CURTNER AVE. SAN JOSE, CA. 95125

Manufacturer: HARDWARE SPECIALTY CO. INC. 48-75 36TH ST. LONG ISLAND CITY, N.Y. 11101

QA Requirements Imposed on Vendor: C OF C, PQC, CODE DATA REPORT, CMTR

Licensee Representative: S. SHARMA

J. Mun Date 6.20.88 Signature

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2QN-10 P.O.#318001 REQ.#553-918

Fastener Description: 2" -8 NUT

Description of Sample Stock Location: B12/F

Material Specification as Documented by Licensee Records: MA194 GR. 2H ASME III CL.1

Head Marking (Specification and Manufacturer): 2H K1469

******Class/Procurement Level: SAFETY-RELATED (Q)

General Plant Application (e.g., Pressure Boundary, Structural) PRESSURE BOUNDARY

Supplier: GENERAL ELECTRIC CO. ORDER SERVICE M/C 847 175 CURTNER AVE. SAN JOSE, CA. 95125

Manufacturer: SAME

QA Requirements Imposed on Vendor: G.E. PQC

Licensee Representative: S. SHARMA

J. Mun Date 6.20.88 Signature

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NN-1

Fastener Description: 1" -8 NUT

Description of Sample Stock Location: JJ57B

Material Specification as Documented by Licensee Records: ASTM A194 GR.6

Head Marking (Specification and Manufacturer): A194 B6 C 5 HT 61827 R94 899

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) REACTOR COOLANT PUMP

Vendor: BYRON JACKSON

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature J. Stranne Date 6.20.65

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NN-2 P.O.#A033790 REQ.#168758

Fastener Description: 1-1/8" -7 NUT

Description of Sample Stock Location: WHSE. A

Material Specification as Documented by Licensee Records: ASTM A194 GR.2H

Head Marking (Specification and Manufacturer): 2H

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: N/A - Not Available

Manufacturer: N/A - Not Available

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

Sharman Date 6-20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NN-3 P.O.#A033790 REQ.#168758

Fastener Description: 7/8" -9 NUT

Description of Sample Stock Location: WHSE A

Material Specification as Documented by Licensee Records: ASTM A194 GR.2H

Head Marking (Specification and Manufacturer): 2H E

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: N/A - Mot Available

Manufacturer: EATON MANUFACTURING CO.

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

S. Aleccione Date 6.20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NN-4 REQ.#489-420

Fastener Description: 3/8" -16 NUT

Description of Sample Stock Location: WHSE A

Material Specification as Documented by Licensee Records: ASTM A194 GR.2H

Head Marking (Specification and Manufacturer): CA 2H

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: N/A - Not Available Manufacturer: N/A - Not Available

QA Requirements Imposed on Vendor: NONE

License: Representative: S. SHARMA

Signature

S. Streem Date 6.20-88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NN-5 REQ.#489-420

Pastener Description: 3/4" -10 NUT

Description of Sample Stock Location: WHSE - A

Material Specification as Documented by Licensee Records: ASTM A194 GR.2H

Head Marking (Specification and Manufacturer): 2H C-U A

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: N/A - Not Available

Manufacturer: N/A - Not Available

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

J. January Date 6.20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NN-6

Fastener Description: 9/16" -11 NUT

Description of Sample Stock Location: B1WW22G

Material Specification as Documented by Licensee Records: ASTM A563 GR.A

Head Marking (Specification and Manufacturer): NONE

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: N/A - Not Available

Manufacturer: N/A - Not Available

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

J. Man Date 6-20-88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NN-7 P.O.#A117394

Fastener Description: 7/16" -13 NUT

Description of Sample Stock Location: B1JJ26H

Material Specification as Documented by Licensee Records: ASTM A563 GR.A

Head Marking (Specification and Manufacturer): NONE

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL/VALVE PARTS

Supplier: WM. POWELL CO. 2503 SPRING GROVE RD. CINCINNATI, OHIO

Manufacturer: N/A - Not Available

QA Requirements Imposed on Vendcr: NONE

Licensee Representative: S. SHARMA

Signature

. Marcan Date 6.20.8.8

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NN-8 P.O.#A117394

Fastener Description: 7/16" -14 NUT

Description of Sample Stock Location: B1JJ33A

Material Specification as Documented by Licensee Records: ASTM A563 GR.A

Head Marking (Specification and Manufacturer): NONE

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL/VALVE PARTS

Supplier: WM. POWELL CO. 2503 SPRING GROVE RD. CINCINNATI, OHIO

Manufacturer: N/A - Not Available

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

J. Mun Date 6.20-88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NN-9 P.O.#A110802-42

Fastmer Description: 5/8" -10 NUT

Description of Sample Stock Location: B1JJ33G

Material Specification as Documented by Licensee Records: ASTM A563 GR.A

Head Marking (Specification and Manufacturer): NONE

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) VALVE PARTS

Supplier: MICHIGAN INDUSTRIAL PIPING SUPPLY CO. P.O. BOX 282 WYANDOTTE, MICH. 48192

Manufacturer: N/A - Not Available

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

Luci Date 6.20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NN-10 P.O.#A117394

Fastener Description: 7/8" -9 NUT

Description of Sample Stock Location: B1WW14F

Material Specification as Documented by Licensee Records: ASTM A563 GR.A

Head Marking (Specification and Manufacturer): NONE

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL/VALVE PARTS

Supplier: WM. POWELL CO. 2503 SPRING GROVE RD. CINCINNATI, OHIO

Manufacturer: N/A - Not Available

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

J. Man Date 6-20-58

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NB-1 P.O.#297489 REQ.#5-578089

Fastener Description: 3/4" -10x2-1/4" BOLT

Description of Sample Stock Location: B1JJ5E

Material Specification as Documented by Licensee Records: ASTM A307 GR.B

Head Marking (Specification and Manufacturer): BTS

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) VALVE PART NON PRESSURE BOUNDARY

Manufacturer: STA BETHLEHEM STEEL

QA Requirements Imposed on Vendor: NONE

Him

Licensee Representative: S. SHARMA

Signature

Date 6-20-88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NB-2 P.O.#134996 REQ.#R0262699

Fastener Description: 3/8" -16x13/16" BOLT

Description of Sample Stock Location: B1JJ49C

Material Specification as Documented by Licensee Records: ASTM A193 GR.B7

Head Marking (Specification and Manufacturer): B7 TB

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) VALVE - BONNET BOLTING FOR NON-SAFETY RELATED VALVE

Supplier: MICHIGAN INDUSTRIAL PIPING SUPPLY CO. INC. 4410 13TH ST. / P.O. BOX 282 WYANDOTTE, MI. 481,2

Manufacturer: TEXAS BOLT CO.

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

Date 6-20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NB-3 P.O.#241352

Fastener Description: 1-1/4" -7x6" BOLT

Description of Sample Stock Location: B1JJ51A

Material Specification as Documented by Licensee Records: ASTM A325

Head Marking (Specification and Manufacturer):

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) REACTOR COOLANT PUMP

Vendor: BYRON JACKSON

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

Date 6.20-58

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NB-4

Fastener Description: 1" -8 x 2-1/2" LONG BOLT

Description of Sample Stock Location: B1JJ55E

Material Specification as Documented by Licensee Records: ASTM A193 GR.B8

Head Marking (Specification and Manufacturer): B8 C

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) REACTOR COOLANT PUMP

theme

Vendor: BYRON JACKSON

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

Date 6-20-8 2

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NB-5

Fastener Description: 1/2" -13x5" BOLT

Description of Sample Stock Location: WHSE A

Material Specification as Documented by Licensee Records: SAE J429 GR.5

Head Marking (Specification and Manufacturer):

2

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: N/A - Not Available

Manufacturer: THE TRIAD METAL PRODUCTS CO. 14701 INDUSTRIAL PKWY. OHIO CLEVELAND, 44135

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

Marine Date 6.20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NB-6 REQ.#576929

Fastener Description: 7/8" -9x3-1/4" BOLT

Description of Sample Stock Location: WHSE A

Material Specification as Documented by Licensee Records: ASTM A325

Head Marking (Specification and Manufacturer):

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: N/A - Not Available.

14701 INDUSTRIAL PKWY., S.W., Manufacturer: THE TRIAD METAL PRODUCTS CO. CLEVELAND, OHIO 44435

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature S. Sturn Date 6-20-88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NB-7

Fastener Description: 3/4" - 16x4" BOLT

Description of Sample Stock Location: WHSE A

Material Specification as Documented by Licensee Records: SAE J429 GR.5

Head Marking (Specification and Manufacturer):

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

N/A - Not Available Supplier:

14701 INDUSTRIAL PKWY., S.W., Manufacturer: THE TRIAD METAL PRODUCTS CO. CLEVELAND, OHIO 44435

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature J. Sharman Date 6.20-88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NB-8

Fastener Description: 5/16" -24x5/8" BOLT

Description of Sample Stock Location: WHSE A

Material Specification as Documented by Licensee Records: SAE J429 GR.5

Head Marking (Specification and Manufacturer): M

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: N/A - Not Available Manufacturer: N/A - Not Available

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

5. Ileanna Date 6.20.88

*The sample ID# shall have a prefix that contains the licensee facility initials.

Fastener Testing Data Sheet

* Sample ID# EF2NB-9

Fastener Description: 3/4" -16x3-1/2" BOLT

Description of Sample Stock Location: WHSE A

Material Specification as Documented by Licensee Records: SAE J429 GR.5

Head Marking (Specification and Manufacturer):

******Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

N/A - Not Available Supplier:

Manufacturer: THE TRIAD METAL PRODUCTS CO. 14701 INDUSTRIAL PKWY., S.W. , CLEVELAND, OHIO 44435

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature In Man Date 6.20-82

*The sample ID# shall have a prefix that contains the licensee facility initials.

Attachment 1

Fastener Testing Data Sheet

* Sample ID# EF2NB-10 REQ.#279269

Fastener Description: 5/8" -11x2-1/2" BOLT

Description of Sample Stock Location: WHSE A

Material Specification as Documented by Licensee Records: SAE J429 GR.5

Head Marking (Specification and Manufacturer):

**Class/Procurement Level: NON SAFETY-RELATED (NQ)

General Plant Application (e.g., Pressure Boundary, Structural) STRUCTURAL

Supplier: N/A - Not Available

Manufacturer: N/A - Not Available

QA Requirements Imposed on Vendor: NONE

Licensee Representative: S. SHARMA

Signature

S Sterrer Date 6.20-68

*The sample ID# shall have a prefix that contains the licensee facility initials.

**If applicable, please provide an explanation for your classification system.

ATTACHMENT 2

Fasteners Test Reports

| A | T 21 | N A | | 100 | 10 |
|------|------|------------|--------------|-----|-----|
| AT | 1 AL | 340 | a – n | 11 | 1 |
| 1.11 | 11.8 | | Beat | ¥.£ | Sec |

| Detroit | | | |
|---------|------------------------|--|--|
| Fdison | - | | |
| Labor | THE OTHER DESIGNATION. | | |

Date:

February 3, 1988

To: S. K. Sharma Fermi 2

From: R. L. Colwell RLC P. M. Beckwith Mills Engineering Research

Subject: Chemical and Physical Testing of Fasteners for Fermi 2. Fermi Test Req. 685 360 Engineering Research Report 88C71-6

Ten items were delivered to Engineering Research for material analysis. They are described as follows:

| Item # | EF2QN # | Description | |
|--------|---------|---------------------------|------|
| 1 | 1 | 1-1/8" - 7 Nut SA 194 Gr | . 7 |
| 2 | 2 | 7/8" - 9 Nut SA 194 Gr | . 2H |
| 3 | 3 | 5/8" - 11 Nut SA 194 Gr | • 2H |
| 4 | 4 | 1-1/4" - 8 Nut SA 194 Gr | • 2H |
| 5 | 5 | 3/4" - 10 Nut A 563 Gr. | С |
| 6 | 6 | 3/4" - 10 Nut A 194 Gr. | 2H |
| 7 | 7 | 1-1/4" - 7 Nut A 194 Gr. | 2H |
| 8 | 8 | 1" - 8 Nut A 194 Gr. | 2H |
| 9 | 9 | 1-1/8" - 12 Nut SA 194 Gr | . 7 |
| 10 | 10 | 2" - 8 Nut SA 194 Gr | • 2H |

The testing results are displayed on the attached NRC Data Summary Form with the appropriate specifications for each item.

All work was performed in Accordance with the Engineering Research Quality Assurance Program. Q. A. Traveler #0091.

Approved by: D. D. Cyrulewski J. D. Cyrulewski Supervisor

W. D. Gilbert

W. D. Gilbert Supervisor

Q. A. Administrator <u>Rt</u> Butte R. L. Gamble

Copies to: R. L. McIntyre (File) Fermi 2 Dist.

RLC/gc PE.14/47

DATA SUMMARY

à.

| Me | chanic | al Analy | sis | | | | | Chemical | Analysis | (wt.Z) | | |
|---------|--------|----------|------|--|---------|------------|------------|------------|----------|-----------|------------|---------|
| Item # | G | rade | | Hard | Iness | <u>c</u> | <u>P</u> | <u>s</u> | Ma | <u>Si</u> | Cr | Mo |
| 1 | SA194 | Gr. 7 | | 29.0 | (HRC) | 0.421 | <0.020 | 0.013 | 0.91 | 0.21 | 0.92 | 0.20 |
| 9 | ** | | | 32.8 | ** | 0.387 | <0.020 | <0.010 | 0.83 | 0.19 | 0.98 | 0.22 |
| (Spec.) | | | | 24 <hf< td=""><td>RC<38</td><td>(.3749)</td><td>(<0.04)</td><td>(<0.04)</td><td></td><td></td><td>(.75-1.20)</td><td>(.1525)</td></hf<> | RC<38 | (.3749) | (<0.04) | (<0.04) | | | (.75-1.20) | (.1525) |
| | | | | | | | | | | | | |
| 2 | SA194 | Gr. 2H | | 28.5 | (HRC) | 0.454 | <0.02) | 0.033 | | | | |
| 3 | | | | 29.5 | ** | 0.398* | 0.025 | 0.022 | | | | |
| 4 | .00 | ** | | 28.8 | | 0.469 | <0.020 | 0.020 | | | | |
| 4 6 | ** | ** | | 25.8 | | 0.399* | ** | 0.023 | | | | |
| 7 | - 14 | | | 29.3 | ** | 0.443 | | 0.035 | | | | |
| 8 | | ** | | 28.8 | ** | 0.435 | | 0.018 | | | | |
| 10 | | ** | | 36.0 | * | 0.451 | | 0.028 | | | | |
| (Spec.) | | | | 24 <hf< td=""><td>C<38</td><td>(0.4 min)</td><td>(<.04)</td><td>(<.05)</td><td></td><td></td><td></td><td></td></hf<> | C<38 | (0.4 min) | (<.04) | (<.05) | | | | |
| | | | | | | | | | | | | |
| 5 | | Gr. C | | | (HRC) | 0.300 | <0.020 | 0.028 | | | | |
| (Spec.) | | | (78 | HRB-3 | B8 HRC) | (0.55 max) | (0.12 max) | (0.15 max) | | | | |
| | | | | | | | | | | | | |
| Correco | anding | 0000151 | anti | | a brazi | hata () | | | | | | |
| corresp | onorng | specifi | cari | Louis 1 | u orac | kets (). | | | | | | |

* Denotes out of specification.

PE.14/47

ATTACHMENT 2

Edison =

Date: June 18, 1988 To: P. I. Temple Nuclear Engineering From: M. L. Holly MLH Engineering Research Subject: Metallurgical Review of Nonconforming Fasteners for Fermi 2. Engineering Research Report 88C63-7

Recently, forty(40) fasteners selected from Fermi 2 storage were tested for conformance to specification requirements. These tests were performed in response to an NRC request for evaluation of bolt quality at Nuclear facilities. Five(5) items were found to have non-specification conditions as a result of this program. The request was made by Fermi 2 Nuclear Engineering to review the non-specification conditions and provide recommendations. The fasteners are listed below:

| Item | Report No. | Description |
|--------|----------------------|---|
| 1 | 87C71-7 | l inch-8 Nut, ASTM A194 Gr. 6. Sulfur and Chromium exceed specification. |
| 3&6 | 87071-8 | 1.25 inch-7 and 7/8 inch-9 Bolts, ASTM A325. Manganese below specifi- cation. |
| 9 | 87071-21 | 3/8 inch-24 Cap Screw, SAE J429 Gr. 2. Hardness exceeds specification. |
| 4 | 138854-101-001* | 1/2 inch-13 Bolt, SAE J429 Gr. 5. Carbon below specification. |
| * = Te | sted by Consumers Po | wer Company Research and Testing |

PE.17/22

Laboratory, Jackson, MI.

Conclusions

Metallurgical review of each item revealed the following:

Item 1, 87C71-7

The nut was manufactured from a resulphurized martensitic stainless steel ASTM A194 Gr. 6F, commonly known as grade 416 (S=0.15% minimum). The specification, ASTM A194 Gr. 6, requires grade 410 (S=0.030% maximum) martensitic stainless steel. Resulphurized stainless steels are utilized in applications where heavy machining is employed, manufacture of a nut typically requires several metal removal operations. Sulphur combines with manganese forming manganese sulfide inclusions which improve machinability, they act as chip breakers, and reduce the cost of manufacturing. Grade 416 stainless is a modification of Grade 410, the increased sulphur content in 416 is normally accompanied by higher manganese and chromium contents.

Increased sulfur content can reduce the ductility and fatigue properties perpendicular to the hot rolling direction (refs. 1 and 2). However, longitudinal mechanical and fatigue properties for 416 and 410 are the same when given identical thermal treatments. With intermediate manganese content (0.40 to 1.80%), similar to the composition of Item 1, chromium rich manganese sulfides are formed which improves the corrosion resistance of 416 stainless steel (reference 2). Polarization curves indicate type 416 is more noble than 410 in the hardened and tempered condition, see Figure 1 (reference 3). Notch toughness values for type 416 are lower than 410, 40 ft-1b. for 416 vs 75 ft-1b. for 410 @ room temperature, and are adversely affected by increased carbon content for both grades. Resulphurized stainless steels are not readily weldable.

Items 3 and 6, 87C71-8

Both items meet specification A 325 and are acceptable. The manganese content was incorrectly listed as a maximum and should have been denoted as a minimum of 0.57% Mn. Additionally, the specification requirements for chemistry incorrectly list heat analysis and should be product analysis. These changes will be made in a revision to the test report.

Item 9, 87C71-21

The cap screws were identified as grade 2 carbon steel (hardness 80-100 HRB), however, they were found to be a quench and tempered alloy steel (hardness HRC 38-40). High strength fasteners, Hardness > 40 HRC, are susceptible to failure by Stress Corrosion Cracking. The calculated stress intensity factor, K, for a 3/8 inch-24 cap screw torqued to maximum grade 2 requirement (21.9 ft-1b. @ 70% yield) is 11 ksi in 17 see attachment 1. Alloy steel (SAE 4140) heat treated to HRC 40 (Y.S. = 165 ksi) has a K_SCC of 35 ksi in 172 when tested in a combined aqueous NaCl and distilled water environment, see Figure 2. Since K is less than K_ISCC.

îtem 4, 138854-101-001

Chemical analysis of the 1/2 inch-24 SAE grade 5 bolt found the carbon content below specification, 0.23% examination vs 0.28% minimum required. All mechanical properties met specification. Grade 5 fasteners are heat treated by oil or water quenching and tempered to achieve the required properties. A medium carbon steel is specified in order to provide adequate hardenability for proper response to the heat treatment operation. Calculation of the ideal diameter or DI, the diameter which will heat treat to a 50% martensitic microstructure under ideal quenching, and converting this value to an actual critical diameter, DC, for a water quenched part is a method for assessing material hardenability. These values are listed below:

Examined bolt (Item 4) 0.6 inch 0.25 inch (approx.) 0.28% carbon steel 0.8 inch 0.3 inch (approx.)

DT

Under ideal quenching conditions both of the above materials have sufficient hardenability to produce a martensitic microstructure in a 1/2 inch diameter section. Neither material has sufficient hardenability with water quenching techniques, however, adequate mechanical properties were produced with the lower carbon content and the bolt will be fit for use.

Recommendations

Based on metallurgical analysis the following recommendations are made:

- o Item 1 is acceptable for use provided the nut is not welded. Impact properties for type 416 are lower than type 410 stainless steel, however, fasteners are normally loaded in tension and are varely subjected to impact loads.
- o Items 3 and 6 are acceptable.
- o Item 9 has adequate resistance to Stress Corrosion Cracking when torqued to the maximum value of a grade 2 fastener. The recommendation is made to verify stress corrosion cracking resistance using the methods detailed in ASTM G-36. Testing in several corrosive solutions would be conducted on full size bolts torqued in an assembly which allows migration of the solution into the threaded section. Contact ER metallurgists for specific details if a test verification program is deemed necessary.
- Recommend additional samples of Item 4, the 1/2 inch diameter grade 5 bolt, be submitted for chemistry, hardness and microstructure examination. These additional samples are required to determine the variability of this bolt lot.

DC

88663-7


References:

- D. H. Breen and E. M. Wene, "Fatigue in Machine and Structures", Fatigue and Microstructure, ASM, 1979, 83-86
- Peckner and Bernstein, "Handbook of Stainless Steels", 1977, 14-9 to 14-11
- 3. ASM, Vol. 13 "Corrosion", ASM, 198/, 70-74

Approved: <u>J. D. Cyrulewski</u> Supervisor

| Copies | to: | Fermi | 2 Distribution |
|--------|-----|-------|------------------|
| | | R. L. | Colwell |
| | | L. C. | Fron |
| | | R. L. | Gamble |
| | | A. K. | 1.43 |
| | | R. L. | McInc, re (File) |
| | | J. E. | Schaefer |
| | | S. K. | Sharma |

MH/gc PE.17/22






Figure 1. Polarization curves for 410 and 416 stainless steel. Type 416 is more noble than 410 in the quench and tempered condition.




Figure 2. KISCC versus yield strength for SAE 4130 and 4140 alloy steels reported for combined aqueous NaCl, and distilled H₂O environments. Dashed line denotes 165 ksi yield strength. From lower bound KISCC values for bolting materials, Lawrence Livermore National Lab, 1981

FERMI BOLT

CEZ- GES FASTENERS MH

FERMI MI-MOSS (SQ) TORQUE TO 60-70% OF THELD

FROM EPRE GOD BETING PRACTICES MANUAL

T=KDM53 AS/12 WHERE T = TORQUE K = NOT FACTOR D= NomiNAL DIA (IN) M = % OF PIELD 5 = PIELD STREAKTH (PSi) AD = TENSILE STRESS AREA (-N) 2 FRE GRZ SAE 3429 5 - = 57,000 ps; MIN. FERNI Z 3/8 - NCH - 24 K= 0.2 D= 375 IN M=,70 52 = 57,000 ps: 43 = 0,7854 (D-0,9743) Z N= 24 A5 = ,0878 ,22

7 = 0,2 × 0,375 × ,70 × 57,000 × .0878 /12 = 21.944-16

P= 127/kD = 3504 AG

6117188

182

GRZ-GRE LONT.

DEFORMATION & F. ERTURE FRM: 12 28/ OF ENGINEERING MATERIALS MECHANICS R.W. HERTZBURG < D-3 K, = Y 1/2 M-d-M Y=1.72 D/2-1.27 Vp

282

6/17/88

For 2/8-24 $\begin{array}{l}
0 = 0,375 \\
- 0.3239 \\
- .72
\end{array}$

FOR 4140 ALLOY STEEL @ EL 40 (BHN 370)

7:5. = 18/ ks; 9:5. = 165 ks;

FROM: LAWRENCE LIVERMORE LABS "LOW BOUNDAR Lizze VALUES FOR BUTINE MATERIALS

KISSE = 35 KSI INTE, IN AQUEOUS MACL E DISTILLED HZO

K. C Kasee

| Eaisc | |
|----------|--|
| Date: | March 9, 1988 |
| To: | S. K. Sharma Fermi 2 |
| From: | R. L. Colwell P. M. Beckwith Engineering Research |
| Subject: | Chemical and Physical Testing of Fasteners for Fermi 2. Fermi Test Req. 685 361 Engineering Research Report 87C71-7, Kev. 1 |

ATTACHMENT 2

Ten items were delivered to Engineering Research for material analysis. They are described below.

| Ites f | EF2NN # | | | | | Description |
|--------|---------|--------|--------|---|----|-------------------|
| 1 | 1 | | 1" | - | 8 | Nut A 194 Gr. 6 |
| 2 | 2 | | 1-1/8" | - | 7 | Nut A 194 Gr. 2H |
| 3 | 3 | | 7/8" | - | 9 | Nut A 194 Gr. 2H |
| 4 | 4 | (Four) | 3/8 | - | 15 | Nuts A 194 Gr. 2H |
| 5 | 5 | | 3/4" | - | 10 | Nut A 194 Gr. 2H |
| б | 6 | | 9/16" | - | 11 | Nut A 563 Gr. A |
| 7 | 7 | (Twc) | 7/16" | - | 13 | Nuts A 563 Gr. A |
| 8 | 8 | (Two) | 7/16" | | 14 | Nuts A 563 Gr. A |
| 9 | 9 | | 5/8" | - | 10 | Nut A 563 Gr. A |
| 10 | 10 | | 7/8" | - | 9 | Nut A 563 Cr. A |

The testing results are displayed on the attached NRC Data Summary Form with the appropriate specifications for each item.

All work was performed in Accordance with the Engineering Research Quality Assurance Program. Q. A. Traveler #0092.

Q. A. Administrator QR. fring for R. L. Gamble

Copies to: R. L. McIntyre (File) Fermi 2 Dist.

RLC/gc 22.14/48

DATA SUMMARY

| Me | chanica | al Analys | s1s | | | | Chemi | cal Analysi | ls (wt.Z) | |
|---------|---------|-----------|--------|-------|------------|------------|------------|-------------|-----------|-------------|
| Item # | GI | rade | Hard | ness | <u>c</u> | P | <u>s</u> | Mn | <u>S1</u> | Cr |
| 1 | A194 0 | Gr. 6 | 25.0 | HRC | 0.13 | <0.020 | 0.354* | 0.50 | 0.57 | 14.1* |
| (Spec.) | - | | (20-28 | HRC) | (0.15 max) | (.04 max) | (.03 max) | (1.0 max) | (1.0 max) | (11.5-13.5) |
| 2 | 194 G | r. 2H | 30.3 | (arc) | 0.51 | <0.020 | 0.036 | | | |
| 3 | | | 27.8 | | 0.44 | * | 0.022 | | | |
| here | | | 28.9 | ** | 0.45 | | 0.014 | | | |
| 4B | | | 28.3 | | 0.45 | • | 0.018 | | | |
| 4C | | - | 29.0 | | 0.44 | | 0.018 | | | |
| 4D | | | 28.0 | | 0.44 | | 0.015 | | | |
| 5 | | | 29.0 | | 0.45 | - | 0.016 | | | |
| (Spec.) | - | | (24-38 | FAC) | (0.4 min) | (.04 max) | (.05 max) | | | |
| 6 | A563 | Gr. A | 84.0 | (HRB) | 0.22 | <0.020 | 0.034 | | | |
| 7A | | | 94.0 | ** | 0.97 . | | 0.015 | | | |
| 7B | | | 95.8 | | 0.07 | * | 0.016 | | | |
| 8A | | | 98 | | 0.07 | | 0.014 | | | |
| 8B | | - | 91.3 | | 0.05 | | <0.010 | | | |
| 9 | * | | 73.0 | | 0.14 | | 0.010 | | | |
| 10 | | ** | 97.8 | - | 0.05 | | 0.020 | | | |
| (Spec.) | | | (B68- | C32) | (0.55 max) | (0.12 max) | (0.15 max) | | | |

Corresponding specifications in brackets ().

*Denotes out of specification.

Sulfur and phosphorous concentrations were not determined.

PE.14/48

| E T | FA. | 1 | MENT | 0 |
|-----|-----|-----|------|---|
| BU | 114 | ur, | MENT | 6 |

Edison

| Date: | February | 3, | 1988 |
|-------|----------|----|------|
|-------|----------|----|------|

To: S. K. Sharma Fermi 2

From: R. L. Colwell Rt. P. M. Beckwith Mill Engineering Research

Subject: Chemical and Physical Testing of Fasteners for Fermi 2. Fermi Test Req. 685 362 Engineering Research Report 88C71-8

Ten items were delivered to Engineering Research for material analysis. They are described below.

| Item # | EF2 NB | 1 | Description |
|--------|--------|---------|--|
| 1 | 1 | | 3/4" - 10 x 2-1/4" Bolt A307 Gr. B |
| 2 | 2 | (Two) | 3/8" - 16 x 13/16" Bolts A193 Cr. B7 |
| 3 | 3 | | 1-1/4" - 7 x 6" Bolt A325 |
| 4 | 4 | | 1" - 8 x 2-1/2" Bolt A193 Gr. B8 |
| 5 | 5 | | 1/2" - 13 x 5" Bolt SAE J429 Gr. 5 |
| 6 | 6 | | 7/8" - 9 x 3-1/4" Bolt A325 |
| 7 | 7 | | 3/4" - 16 x 4" Bolt SAE J429 Gr. 5 |
| 8 | 8 | (Three) | 5/16" - 24 x 5/8" Bolt SAE J429 Gr. 5 |
| 9 | 9 | | 3/4" - 16 x 3-1/2" Bolt SAE J429 Gr. 5 |
| 10 | 10 | | 5/8" - 11 - 2-1/2" Bolt SAD J429 Gr. 5 |

The testing results are displayed on the attached NRC Data Summary Form with the appropriate specifications for each item.

All work was performed in Accordance with the Engineering Research Quality Assurance Program. Q. A. Traveler #0093.

| Approved | by: | J. O. Lymbark |
|----------|-----|--------------------------------|
| | | J. D. Cyrulewski Supervisor |

W. D. Gilbert

Supervisor

Q. A. Administrator RL Somble R. L. Gamble

Copies to: R. L. McIntyre (File) Fermi 2 Dist.

RLC/gc PE.14/49 88C71-8

DATA SUMMARY

| Mec | hanical Analysi | .6 | Chemical Analysis (wt.7) | | | | | | | | | |
|---------------------|-----------------|-------------------------|--------------------------|----------------------------|-----------------------------|---------------------------|-------------------------|-------------------------|---------------------------|--------------------|--|--|
| Item 1 | Grade | Hardness | <u>c</u> | Mn | P | <u>s</u> | <u>S1</u> | Mo | Cr | NI | | |
| 2A 2B (Spec.) | A193 Gr. B7 | 29.5 HRC 29.8 () | .41 .41 (.37-49) | 0.97 0.88 (.65-1.10) | <0.020 <0.020 (<.035) | 0.025 0.014 (<.040) | 0.22 0.21 (.1535) | 0.20 0.17 (.1525) | 1.01 1.01 (.75-1.2) | 0.07 0.13 () | | |
| 4 (Spec.) | A193 Gr. B8 | 76.8 HRB (<96 HRB) | 0.06 (0.08 max) | 1.42 (2.0 max) | 0.030 | 0.022 | 0.27 (1.0 max) | 0.4 () | 19.9 (18.0-20.0) | 9.5 (8.0-10.5) | | |
| l (Spec.) | A307 Gr. B | 93.3 HRB (69-95 HRB) | 0.17 () | | <0.020 (<0.040) | 0.021 (<0.050) | | | | | | |
| 3 (Spec.) | A325 | 22.8 HRC (19-31 HRC) | 0.41 (.2855) | 0.82* (<0.60) | <0.020 (<0.040) | 0.036 (<0.050) | | | | | | |
| 6 (Spec.) | A325 | 28.8 (24-35 HRC) | 0.38 | 0.68* | 0.020 | 0.028 | | | | | | |

HARDNESS

Chemical Analysis (wtZ)

2. .

| | | | CORE (HRC) | Superficial (30-N) | <u>c</u> | P | <u>s</u> |
|---------|----------|------|------------|--------------------|----------|---------|----------|
| 5 | SAE J429 | Gr.5 | 30.0 | 52.0 | .34 | <0.020 | 0.033 |
| 7 | | ** | 29.8 | 50.8 | .34 | | 0.017 |
| 8A | | | 30.8 | 49.8 | .38 | | 0.012 |
| 8B | | | 30.0 | 50.8 | , 39 | | 0.012 |
| 8C | | | 29.8 | 50.0 | .38 | ** | 0.012 |
| 9 | | | 28.8 | 49.8 | .38 | 0.021 | 0.016 |
| 10 | | | 29.5 | 50.0 | .28 | <0.020 | 0.014 |
| (Spec.) | | ** | (25-34) | (<54) | (.2855) | (<.048) | (<.058) |

A325 samples lie within the composition range of Type 1 and Type 2 material. The hardness specifications are a function of bolt size.

*Denotes out of specifications.

PE.14/49



"Division of Consumers Power Company

135 West Trail Street Jackson, Michigan 49201

> EEM Project: 138854-101-001 Detroit Edison PO NR-176637 UFI: A-200/42*30 Detroit Edison Fermi II Plant

Report

TESTING OF TEN "Q" FASTENER ITEMS TO DETERMINE CONFORMANCE TO THEIR ASTM REQUIREMENTS FOR DETROIT EDISON FERMI II NUCLEAR POWER STATION

> Prepared by: Dr William R Pavlichko Staff Engineer Engineering Evaluations and Metallurgy Department Consumers Power Company 135 West Trail Street Jackson, MI 49201

Report date: March 3, 1988

ATTACHMENT 2

EEM Project: 138854-101-001

TESTING OF TEN "Q" FASTENER ITEMS TO DETERMINE CONFORMANCE TO THEIR ASTM REQUIREMENTS

Requested by: H Valenta, Fermi II 260-TAC Report date: March 3, 1988 Report by: WRPavlichko, Laboratory Services

Distribution: EEM File (2) DCC: A-200/42*30

INTRODUCTION

Ten items/sets of "Q" fasteners were received from the Detroit Edison Fermi II Plant for chemical and mechanical testing to verify conformance to their respective ASTM requirements. Each item was identified by a unique Enrico Fermi II Plant designation, EF2QB. A list and description of the ten items received follows:

| EF2QB-1 | 1/2" - 13 X 3" Stud SA-193 GR B7 CL-2 RIR 586937 |
|----------|--|
| EF2QB-2 | 1-1/8" - 12 X 6-1/4" Bolt SA-193 GR B7 CL-1 RIR 5-586738 |
| EF 2QB-3 | 1-1/4" - 7 X 3-3/4" Cap Screw SA-449 RIR 5-490676 Tag V8-2139 Item 1 PO NR 296178 |
| EF2QB-4 | 1/2" - 13 X 1-1/2" Bolt SAE J429 GR 5 RIR 606890 |
| EF2QB-5 | 1-1/4" - 7 X 8" Bolt SA449 RIR 587016 |
| EF2QB-6 | 3/4" - 10 X 2" Bolt SA325 RIR 527736 |
| EF2QB-7 | 1/2" - 13 X 1-1/4" Bolt SAE J429 GR 5 RIR 587016 |
| EF2QB-8 | 5/16" - 24 X 1-1/2" Bolt SAE J429 GR 5 |
| EF2QB-9 | 5/8" - 18 X 1" Bolt SAE J429 GR 5 RIR 414577 |
| EF2QB-10 | 7/8" - 9 X 4" Bolt SAE J429 GR 5 RIR 587086 |

Chemical analyses, hardness tests and the appropriate tensile testing per specification requirements were performed on samples from each item. Charpy V-notch impact tests were performed on item 2 samples. The Detroit Edison Purchase Order was NR 176637.

CHEMICAL ANALYSES

Samples from each item were chemically analyzed by emission spectroscopy, except for carbon analyses, which was accomplished by combustion IR testing - Leco Tester. Chicago Spectro performed the tests. Chemistry test data for the items and the item specification chemistry requirements are presented in Table I.

MECHANICAL TESTING

Hardness tests were performed on samples from each item. Tensile tests were performed on samples from each item. Either machined samples or full size bolts were tested depending on the ASTM specification requirements. Charpy V-notch impact test were run on samples from item 2.

Hardness Tests

Rockwell "C" hardness tests (HRC) were run on samples from each item per MET-02 procedure. Results for the ten items are presented in Table II along with item ASTM specification requirements. Hardness tests were run on either top (head) or side (flat) of the fastener.

Tensile Tests

Tensile tests were performed per Consumers Power Company MET-02 procedures and ASTM SA-370 specifications for machined tensile testing and full size bolt testing. Items EF2QB-1 and EF2QB-2 were tested using machined tensile specimens and UTS, YS, elongation and reduction in area were obtained. Items EF2QB-3 to EF2QB-10 were tested full size as per their ASTM specifications.

Yield load for full size bolt tested specimens was not obtained. Three items had ASTM requirements which specified yield load, EF2QB-3, -5 and -6. Attempts were made to obtain the yield load during full size testing by the pointer method, however no discernible load drops occurred so only the failure load was determined. An extensometer could not be employed.

For Table III (tensile requirements) in SA-449-80, there is a relationship between failure load and yield load for all sizes. This is approximately .772 (yield is approximately .772 of failure load). An approximate relationship between failure load and yield load also exists in Table IV of SA-325-81 for all sizes. This value is approximately .766 (yield is approximately .766 of failure load). Using these values, an estimated yield load was calculated for EF2QB-3, EF2QB-5 and EF2QB-6 and placed in Table II. Basically, if the failure is above minimum failure specification, the yield load should also be above minimum yield specification. Tensile data results are in Table II along with item ASTM specifications.

EEM Project: 138854-101-001

Charpy Impact Tests

A set of three Charpy impact V-notch specimens were tested on item 2 (EF2QB-2) material. Item 2 is SA-193 GR B7 CL-1 material. The specification refers to SA-320 when Charpy impact tests are required. Impact tests were performed per MET-02, SA-320 and SA-370 requirements for Charpy Impact testing of V-Notch specimens. The test temperature specified by Detroit Edison was -20°F. Test data for item 2 is in Table II.

SUMMARY

- All tests met chemistry specifications except item EF2QB-4, sample carbon level was 0.23 (specification 0.28-0.55).
- 2. All items met mechanical specifications (hardness, tensile and Charpy test requirements per the appropriate ASTM specification).
- All items were stamped with correct markings as required by the appropriate ASTM specification.
- 4. The hardness values of tested items were converted to tensile equivalents from data tables and these are with the hardness data in Table II.
- Items 3 and 5 did not fail during full size tensile testing, tests were run to machine load limit. However, both tests exceeded the tensile minimum required per specifications.
- Item 9 did not fail during full size tensile testing because the fixture threading failed, however specimen load had exceeded the minimum load required per specification.

Approved

oock

Date 3-11-88

Engineering Evaluations and Metallurgy Supervisor

| Chandistry Test Data (vt \$) | | | | | | | | | | | | | |
|------------------------------|------------------------|----------------|-----------------|------------------|------------------|--------------|------------------|----------------|--------------|--------------|---------------|----------|------------|
| Iten Runbsr | Specification | Carbon | Manganewo | Phosphorus P | Sulfur S | | Molybdenam Mo | Chronium Cr | Wickel W1 | Copper Ou | Vanadium V | Titanium | Boron B |
| Br295-1 Bample | 84-193-794 87 CL-2 | -3749 .44 | .65-1.10 .91 | .04 Max | .04 Max | .1535 | .1525 .16 | .75-1.20 | .19 | .13 | : | - | - |
| Braple | 84-193-79 87 CL-1 | .3749 .42 | .65-1.10 .80 | .04 Max | .04 Max | .1535 .24 | .1525 .18 | .75-1.20 | .01 | 01 | : | : | - |
| Br200-3 Bample | 84-149-80 | .2855 .36 | .60 Min .74 | .040 Max .006 | .050 Max | .018 | - 01 | .01 | - <.01 | .01 | : | .030 | .0007 |
| Br208-4 Bample | SAE JA29-78 GB-5 | .2855 .23 | .94 | .048 Max .18 | .058 Max | .19 | .01 | .03 | .03 | .07 | : | - | - |
| Br205-5 Basple | 84 119 80 | .2855 .35 | .60 MLn .69 | .040 Max .007 | .050 Max .013 | - .21 | - | .07 | - <.01 | .01 | : | : | - |
| Bragle | 84-325-81 Type 1 | .27 Min .39 | .47 Min .67 | .048 Max .009 | .058 Max | .20 | - | .20 | 04 | .03 | 2 | ÷ | - |
| Bragle | BAR J\$29-78 OR-5 | .2855 | .70 | .048 Max | .058 Max | .20 | - | 05 | - <-01 | .03 | : | - | - |
| MP2Q8-8 Shaple | BAR JA29-78 (R-5 | .2855 .34 | .62 | .048 Max | .058 Max | .22 | - | .08 | .03 | 13 | - | - | - |
| Br208-9 Sample | BAE JA29-78 GB-5 | .2855 .37 | .63 | .048 Max | .058 Max | .18 | .01 | 09 | .10 | | - | - 11 | - |
| 87208-10 Sample | SAR J429-78 (09-5 - | -2855 -37 | .65 | .048 Max | .058 Max | .19 | - <.01 | - | .04 | .03 | : | - | - |

0368-015-6HT

TABLE I. Chemistry Test Data

Page 5 of 60 EEM Project: 138854-101-001

| | | | | | | schined 7 | tensile | Data | Bolte Full Size Testing | | the state | | |
|----------------|--------------------|--------------|---------|----------------------------|------------|----------------------|----------------------|-----------------------------|------------------------------------|---------|--------------------------------------|-------------------------------|--|
| Item Hunber | Specification | 81se Inch | Marking | Hardness | MBI UTS | 1031 (0.2) 175 | Min \$ ED.cong | Min Reduction Area \$ | L8 Pailure Lord | PSI | PSI C | arpy (-20"7) Hotch (FT-LB) | |
| 17208-1 | 84-193-798 BT CL-2 | 1/2 | 87 | 1 1 1 1 1 1 | 125 | 105 | 16 | 50 | 1.1.1.1.1.1.1.1.1 | _ | | | |
| Sample | | | KBIT | HRC33.2 UTS EQ 148 KBI | 153 | 140.8 | 20.3 | 59 | | - | - | | |
| B7208-2 | 84-193-79 B7 C1-1 | 1-1/8 | 87 | - | 125 | 105 | 16 | 50 | | - | - | 20 Min | |
| Sample | | | ET | HIRC28.7 UTS BQ 131 KBI | 135 | 118.5 | 22.4 | 63 | | - | - | 65 Are (3) | |
| B723B-3 | SA-449-80 | 1-1/4 | * | HRC19-30 | - | 2 | - | 2 N.S | 101,700 | - | 78,500 | | |
| Sample | | | A | 2075 80 124 KBI | - | - | - | *) R | 120,000+ - Sample Did Not Break | - | 92,640 Cal | - | |
| 87208-A | BAE J429-78 GR-5 | 1/2 | 2 | HRC25-34 | - | - | - | - 11 | 17,028 Oal | 120,000 | Not Neg | | |
| Sample | | | ~ | NRC31.6 UTS BQ 142 NBI | - | - | | • | 20,600 | 145,200 | - | - | |
| 87208-5 | 84-149-80 | 1-1/4 | 7 | HRC19-30 | - | - | - | | 101,700 | 2.11 | 78,500 | | |
| Sample | | | ~ | HRC30.3 UTS NQ 137 KBI | - | - | - | - | 120,000+ - Sumple Did Not Break | • 11 | 92,640 Cal | - | |
| 17298-6 | 8A-325-81 Type 1 | 3/4 | A-325 | HRC24-35 | - | - | - | - | 40,100 | | 30,700 | 1.2.2.7.5 | |
| Sample | | | A-325 | UTS BQ 144 KBI | - | - | - | - | 47,500 | - · · · | 36,385 Cal | - | |
| 17203-7 | SAE J429-78 GR-5 | 1/2 | 1. | HRC25-34 | - | - | _ | | 17,028 Cal | 120,000 | Not Reg | | |
| Sample | | | ~ | HRC27.9 UTS EQ 129 KBI | - | - | - | - | 18,200 | 128,300 | | | |
| 8-80510 | SAE JA29-78 GR-5 | 5/16 | 1 | HRC25-34 | - | - | - | _ | 6,960 Cal | 120.000 | Not Neg | 1.2.348 | |
| Sample | | | 1 | HRC28.9 UTS BQ 132 KBI | - | - | - | - | 8,200 | 141,400 | - | - F. S. | |
| 17208-9 | SAE J429-78 GR-5 | 5/8 | 1 | HRC25-34 | - 2 - | - | - | _ | 30,720 Cal | 120,000 | Not Neg | | |
| Sample | | | * | HRC31.1 UTS RQ 140 KBI | - | - | - | - | 33,100 | 129,300 | Fixture Pailure Sample Did Not Br | | |
| 17208-10 | BAE J429-78 OR-5 | 7/8 | 4 | HRC25-34 | - | - | - | - | 55,440 Cal | 120,000 | Not Neg | | |
| Sample | | | * | HRC29.3 UTS RQ 133 KSI | - | ÷ | - | - | 61,500 | 133,100 | Tensile Specimen | - | |
| | | | | | | -10 Sampl | | | | | | | |
| | | | | HRC30.3 UTS NO 137 | - | - 1 | - | - | • | - | Hardness Specimen | - | |

0388-015-64T

TABLE II. Mechanical Test Data

Page 6 of 60 EEM Project: 138854-101-001

CHICAGO SPECTRO SERVICE LABORATORY, INC.

Spectrographic and Chemical Analysts

Metallurgists

Page 19 of 60 4848 S. KEDZIE AVE. . CHICAGO, ILL. 60632 Proj: 138854-101-001 AREA CODE 312 - 523-7088

ANALYSIS REPORT FOR

| | Consumers Power Company |
|---|----------------------------------|
| | Research & Testing Laboratory |
| • | 135 West Trail Street |
| | Jackson, Michigan 49201 |
| • | Attention: Dr. William Paylichko |

PURCHASE ORDER NO. (RMR706-6932

DATE 23/88 2 Report Number: 9165

Sample Identification: 138854101001

| | <u>No. 1</u> | No. 2 | No. 3 | No. 4 | No. 5 |
|---|--|--|---|---|--|
| Carbon Manganese Phosphorus Sulfur Silicon Nickel Chromium Molybdenum Copper Titanium Boron | 0.44 * 0.91 0.012 0.032 0.25 0.19 1.05 0.16 0.13 | 0.42 % 0.80 0.014 0.018 0.24 0.01 0.94 0.18 0.01 | 0.36 % 0.74 0.006 0.022 0.18 < 0.01 0.01 0.01 0.01 0.030 0.0007 | 0.23 * 0.94 0.018 0.010 0.19 0.03 0.03 0.01 0.07 | 0.35 % 0.69 0.007 0.013 0.21 < 0.01 0.07 < 0.01 0.01 |
| | No. 6 | No. 7 | <u>No. 8</u> | No. 9 | No. 10 |
| Carbon Manganese Phosphorus Sulfur Silicon Nickel Chromium Molybdenum Copper | 0.39 0.67 0.009 0.028 0.28 0.20 0.01 0.20 0.01 0.03 | 0.32 • 0.70 0.005 0.020 0.020 0.020 0.020 0.020 0.01 0.01 | 0.34 4 0.62 0.015 C 0.617 · 0.617 · 0.08 0.08 0.08 0.08 0.08 | 0.37 % 0.63 0.005 0.020 0.18 0.10 0.09 0.01 0.17 | 0.37 % 0.65 0.013 0.005 0.19 0.04 0.02 < 0.01 0.03 |

RATORY, INC.

THE FOREGOING REPO PRODUCED FOR PUBLICA S FURNISHED BY US PURSUANT TO CONTRACT AND IN STRICT CONFIDENCE. NO PART HEREOF MAY" BE RE-STTHOUT OUR PRIOR SRITTEN APPROVAL

| | | ATTACHMENT 2 | | |
|---------|-------------------------|--------------|--------------------------------|--|
| Detroit | | | | |
| Edicon | No. of Concession, Name | | COLUMN STATE OF TAXABLE PARTY. | |
| EUISOIT | - | 1 | | |

Date: February 11, 1988

To: S. K. Sharma Fermi 2

From: R. L. Colwell ##C Engineering Research

Subject: Material Analysis of Fasteners for Fermi 2. Test Req. #685336 Engineering Research Report 88C71-5

Two identical bolts were delivered to Engineering Research for evaluation. They were labled DENB-9A, and were the cap screw type, measuring 3/8" - 24x2". They were both identified as SAE J429 Grade 2 material.

Chemical analysis was obtained by Argon Plasma Spectroscopy and infrared spectroscopy. The results are tabulated below.

Elemental Composition (wt.Z)

| Bolt | <u>c</u> | Cr | Mn | Si | <u>P</u> | <u>s</u> |
|------------------------------|-------------------------|--------------------|--------------------|--------------------|----------------------------|----------------------------|
| 1 2 (Spec) | 0.36 0.37 (<0.55) | 1.04 0.98 () | 0.74 0.74 () | 0.24 0.26 () | 0,022 0.020 (<0.048) | 0.027 0.027 (<0.058) |
| Item 9 Test Rec 610143 | 0.37 | | | | 0.020 | 0.028 |

Tested hardness values are listed below.

 Item
 Hardness (HRC)

 1
 40.4

 2
 38.2

 (5 Spec)
 (80-100) HRB

 Item 9
 40.4 HRC

 610143
 40.4 HRC

PE.16/6

Conclusion

It has been demonstrated that these bolts have the same physical and chemical properties as the bolt (Item #9) tested in test req. #610-143.

The bolts are fabricated from medium carbon, low alloy steel, which very closely corresponds to a grade 8 material.

The bolts' high strengths contribute to increased sensitivity to Stress Corrosion Cracking (SCC). "SCC is a mechanical environmental failure process in which mechanical stress and chemical attack combine to initiate and propogate fracture in a metal part. Stress-corrosion cracking is produced by the synergistic action of sustained tensile stress and a specific corrosive environment; this action causes failure to occur more rapidly than it would if the separate effects of the stress and the corrosive environment were simply added together.

Failure by SCC frequently is caused by simultaneous exposure to a seemingly mild chemical environment and to a tensile stress far below the yield strength of the metal. Under such conditions, fine cracks can penetrate deeply into the part while the surface exhibits only insignificant amounts of corrosion. Hence, there may be no macroscopic indications of an impending failure." (Metals Handbook, 9th. Ed. Vol. 1 pg. 687).

The chemical agents which can cause SCC are usually aqueous acids or salts and gaseous halogens and acids.

If the bolts are being utilized in a dry environment and in areas where the formerly mentioned gases are not present, the bolts will perform as required, since they are made from a material that is superior to a Grade 2.

All work was performed in accordance with the Engineering Research Quality Assurance Program. Q.A. Traveler #0089.

Approved by: Office l

Q.A. Administrator AI South

Copies to: R. L. McIntyre (File) Fermi 2 Dist.

RLC/gc PE.16/6