



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

7590-01

UNITED STATES NUCLEAR REGULATORY COMMISSION

SYSTEM ENERGY RESOURCES, INC., et al.

DOCKET NO. 50-416

NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT

TO FACILITY OPERATING LICENSE AND

OPPORTUNITY FOR HEARING

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-29 issued to Mississippi Power & Light Company, South Mississippi Electric Power Association and System Energy Resources, Inc. (the licensees) for operation of the Grand Gulf Nuclear Station, Unit 1, located in Claiborne County, Mississippi.

The proposed amendment would change the Technical Specifications (TS) by changing Table 4.8.1.1.2-1, "Diesel Generator Test Schedule" to:

- (1) Delete the criterion for using the diesel generator test interval of 14 days.
- (2) Change the criterion for using the 7 day test interval from greater than 2 diesel generator test failures in the last 100 valid tests to greater than 4 diesel generator test failures in the last 100 valid tests or greater than 1 diesel generator test failure in the last 20 valid tests.
- (3) Change the criterion for using the 31 day test interval from less than or equal to 1 diesel generator test failure in the last 100 valid tests to less than or equal to 4 diesel generator test failures in the last 100 valid tests or less than or equal to 1 diesel generator test failure in the last 20 valid tests.

- (4) Add a footnote to state that if increased frequency testing is required due to exceeding 1 diesel generator test failure in the last 20 valid tests, then the increased test frequency shall be maintained until seven consecutive failure free tests have been performed and the number of failures in the last 20 valid tests have been reduced to less than or equal to one.
- (5) Delete the portion of the present footnote that states only valid tests conducted after the Operating License issuance date of June 16, 1982 shall be used in the computation of the last 100 valid tests.

Prior to issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations.

By June 1, 1988 , the licensees may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for hearing and a petition for leave to intervene. Requests for a hearing and petitions for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition, and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR §2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to fifteen (15) days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than fifteen (15) days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter, and the bases for each contention set forth with reasonable specificity. Contentions shall be limited to matters within the scope of the amendment under consideration. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene shall be filed with the Secretary of the Commission, United States Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Branch, or may be delivered to the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C., by the above date. Where petitions are filed during the last ten (10) days of the notice period, it is requested that the petitioner or representative for the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at 1-800-325-6000 (in Missouri 1-800-342-6700). The Western Union operator should be given Datagram Identification Number 3737 and the following message addressed to Elinor G. Adensam: petitioner's name and telephone number; date petition was mailed; plant name; and publication date and page number of this FEDERAL REGISTER notice. A copy of the petition should also be sent to the Office of General Counsel, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, and to Nicholas S. Reynolds, Esquire, Bishop, Liberman, Cook, Purcell and Reynolds, 1200 17th Street, N.W., Washington, D.C. 20036, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the

presiding Atomic Safety and Licensing Board, that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

If a request for hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the application for amendment dated April 8, 1988, which is available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. 20555, and at the Hinds Junior College, McLendon Library, Raymond, Mississippi 39154.

Dated at Rockville, Maryland, this 25th day of April 1988.

FOR THE NUCLEAR REGULATORY COMMISSION

Original Signed By
Elinor G. Adensam

Elinor G. Adensam, Director
Project Directorate II-1
Division of Reactor Projects I/II

*Forwarded
4/21/88*

OFFICIAL RECORD COPY

OFC	:LA:PD21:DRPR:PM:PD21:DRPR:	OGC	:ADRY:DRPR	:DIPD21:DRPR	:
NAME	:PAnderson:ch:LLKintner	:	:GCLAdnas	:EAdensam	:
DATE	: 4/18/88	: 4/18/88	: 4/ /88	: 4/18/88	: 4/25/88