

UNITED STATES NUCLEAR REGULATORY COMMISSION
DOCKET NOS. 50-440 AND 50-441
CLEVELAND ELECTRIC ILLUMINATING COMPANY, ET AL.
PERRY NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2
ISSUANCE OF DIRECTOR'S DECISION UNDER 10 CFR 2.206

Notice is hereby given that the Director, Office of Nuclear Reactor Regulation, has issued a Director's Decision concerning a Petition dated January 22, 1988, filed by Susan L. Hiatt on behalf of Ohio Citizens for Responsible Energy, Inc. (Petitioner). The Petitioner requested that the Nuclear Regulatory Commission (NRC) grant a variety of relief, including suspension of the operating license for the Perry Nuclear Power Plant, Unit 1, and suspension of the construction permit for the Perry Nuclear Power Plant, Unit 2. The Petition alleged various seismic inadequacies in the Perry Nuclear Power Plant design, specifically:

1. The earthquake of January 31, 1986, at Chardon, Ohio and the historic seismicity near the Perry Nuclear Power Plant can be associated with a tectonic structure (fault) that has been revealed by magnetic data.
2. This tectonic structure is capable of an earthquake with a magnitude of 6.5 or greater.
3. The present safe-shutdown earthquake (magnitude of 5.3 ± 0.5) for the Perry facility does not provide the margin of safety required.


On the basis of these alleged inadequacies, Petitioner claimed that the Perry facility did not comply with the Commission's requirements related to seismic design.

On March 2, 1988, the Director of the Office of Nuclear Reactor Regulation acknowledged receipt of the Petition and notified the Petitioner that this matter would be considered pursuant to 10 CFR 2.206.

The Director has determined that the Petitioner's request should be denied. The reasons for the denial are set forth in the "Director's Decision Pursuant to 10 CFR 2.206" (DD-88-10), which is available for inspection and copying in the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. 20555 and at the local public document room for the Perry Nuclear Power Plant at the Perry Public Library, 3753 Main Street, Perry, Ohio 44081.

A copy of the decision will be filed with the Secretary of the Commission for the Commission's review in accordance with 10 CFR 2.206(c). As provided in 10 CFR 2.206(c), the decision will become the final action of the Commission 25 days after issuance unless the Commission on its own motion institutes review of the decision within that time.

FOR THE NUCLEAR REGULATORY COMMISSION



Thomas E. Murley, Director
Office of Nuclear Reactor Regulation

Dated at Rockville, Maryland
this 22nd day of June 1988



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 22, 1988

Docket Nos. 50-440
and 50-441

(10 CFR Section 2.206)

Ms. Susan L. Hiatt
Ohio Citizens for Responsible
Energy, Inc.
8275 Munson Road
Mentor, Ohio 44060

Dear Ms. Hiatt:

This letter responds to the "Petition for Immediate Action to Relieve Undue Risk Posed by the Inadequate Seismic Design of the Perry Nuclear Power Plant" filed by you on behalf of the Ohio Citizens for Responsible Energy, Inc. (Petitioner) on January 22, 1988 pursuant to 10 CFR 2.206. The Petition made the following allegations regarding the seismic design of the Perry Nuclear Power Plant (PNPP) of the Cleveland Electric Illuminating Company et al. (Licensees):

1. The earthquake of January 31, 1986 at Chardon, Ohio and the historic seismicity near the PNPP can be associated with a tectonic structure (fault) that has been revealed by magnetic data.
2. This tectonic structure is capable of an earthquake with a magnitude of 6.5 or greater.
3. The present safe-shutdown earthquake (SSE) of magnitude of 5.3 ± 0.5 for the PNPP does not provide an adequate margin of safety.

Based on these allegations, the Petition concluded that the PNPP does not comply with the Commission's regulations regarding seismic design required by 10 CFR Part 50, Appendix A, General Design Criterion 2, and 10 CFR Part 100, Appendix A, Parts IV, V, and VI.

The Petition requested an immediate suspension of the operating license (OL) for PNPP Unit 1 and the construction permit (CP) for PNPP Unit 2. It further requested that additional geologic and geophysical studies be conducted, and appropriate corrective actions considered, by the Licensees and that an adjudicatory hearing be held to evaluate the effectiveness of those corrective actions.

On March 2, 1988, I sent you a letter acknowledging receipt of the Petition and declined to take any immediate action for the reasons stated in that


Ms. Susan L. Hiatt

- 2 -

letter. I also indicated that a formal decision would be issued in the reasonably near future.

For the reasons set forth in the enclosed Director's Decision under 10 CFR 2.206, DD-88-10, your Petition has been denied. A copy of the Decision will be referred to the Secretary of the Commission for the Commission's review in accordance with 10 CFR 2.206(c) of the Commission's regulations. As provided by this regulation, the Decision will constitute the final action of the Commission 25 days after the date of issuance of the Decision unless the Commission, on its own motion, institutes a review of the Decision within that time. For your information, I have enclosed a copy of the notice regarding this Decision that has been filed with the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in black ink that reads "Thomas E. Murley". The signature is written in a cursive style with a large, sweeping flourish at the end.

Thomas E. Murley, Director
Office of Nuclear Reactor Regulation

Enclosures:

1. Director's Decision
2. Federal Register Notice

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

OFFICE OF NUCLEAR REACTOR REGULATION
Thomas E. Murley, Director

In the Matter of

CLEVELAND ELECTRIC ILLUMINATING
COMPANY, ET AL.

(Perry Nuclear Power Plant,
Units 1 & 2)

}
}
}
}

Docket Nos. 50-440
50-441

(10 CFR 2.206)

DIRECTOR'S DECISION UNDER 10 CFR 2.206

INTRODUCTION

On January 22, 1988, Ms. Susan L. Hiatt on behalf of Ohio Citizens for Responsible Energy, Inc. (Petitioner) filed with the Director of the Office of Nuclear Reactor Regulation of the Nuclear Regulatory Commission (NRC) a "Petition for Immediate Action to Relieve Undue Risk Posed by the Inadequate Seismic Design of the Perry Nuclear Power Plant" requesting a variety of relief including immediate suspension of the operating license (OL) for the Perry Nuclear Power Plant, Unit 1, and suspension of the construction permit (CP) for the Perry Nuclear Power Plant, Unit 2, of the Cleveland Electric Illuminating Company, et al. ^{1/} (Licensees).

^{1/} Cleveland Electric Illuminating Company is authorized to act as agent for Duquesne Light Company, Ohio Edison Company, Pennsylvania Power Company, and the Toledo Edison Company and has exclusive responsibility and control over the physical construction, operation, and maintenance of the facility.

The Petitioner also requested that, before reinstating the OL for Perry Unit 1 and the CP for Perry Unit 2, the Licensees should be required to engage in appropriate geologic and geophysical research, including but not limited to confirmatory studies recommended by Petitioner, to determine the appropriate safe-shutdown earthquake (SSE) for the PNPP.

Additionally, the Petitioner requested that the Licensees be required to evaluate whether applicable systems, structures, and components important to safety will remain functional throughout their design life and withstand the vibratory ground motion (and concurrent normal and accident loads) resulting from the earthquake which appropriate geologic and geophysical research reveals to be the proper SSE for the Perry facility. If any system, structure, or component were unable to withstand the appropriate SSE, corrective action should be taken and an adjudicatory hearing should be held to determine whether the corrective actions taken are sufficient. Should the corrective actions not be completed as specified, the Petitioner requested that the OL and CP for Perry Units 1 and 2, respectively, be revoked.

The Petition's allegations are based largely upon an analysis of data and evaluations that had been performed by other groups in response to the January 31, 1986 earthquake that occurred near the Perry facility. The analysis was performed for the Petitioner by Dr. Yash Aggarwal, and his affidavit and report (Aggarwal Report) are attached to the Petition.

The Aggarwal Report notes that, on January 31, 1986, an earthquake with a magnitude of 5.0 occurred with an epicenter about 10 miles south of the

PNPP. Dr. Aggarwal concluded (a) that the January 1986 earthquake and historical seismicity can be associated with a tectonic structure (fault) revealed by magnetic data; (b) that this fault passes within a few miles of the PNPP and is capable of generating much larger earthquakes; (c) that an earthquake with a magnitude of 6.5 is a realistic probability for the purposes of determining the proper SSE for Perry; and (d) that the present magnitude of 5.3 ± 0.5 for the SSE does not provide an adequate margin of safety required for the PNPP. The Petitioner alleges for these reasons that the Licensees are in noncompliance with various regulations of the Commission, specifically, 10 CFR Part 50, Appendix A, General Design Criterion 2, and 10 CFR Part 100, Appendix A, Parts IV, V, and VI.

On March 2, 1988, I acknowledged receipt of the Petition and explained to the Petitioner my reasons for declining to take any immediate actions. I indicated that I would issue a final decision in this matter in the reasonably near future. My decision in this matter follows.

DISCUSSION

The basis for the Petition is the Aggarwal Report. In his report, Dr. Aggarwal asserts that an earthquake with a magnitude of 6.5 or larger is probable on a "feature" that, at its closest approach, is approximately 10 kilometers southeast of the Perry site. This feature is a "boundary" in the magnetic map of Ohio which separates a region of relatively high magnetic relief to the northwest from a region of relatively low magnetic relief to the southeast. Weston Geophysical Corporation identified this boundary as the "Akron Magnetic Boundary" (AMB) (Reference 1, Figure 4-2). Dr. Aggarwal

concludes that correlations of magnetic data and "macroearthquakes" known to have occurred historically within 50 miles of the 1986 event strongly suggest that the AMB marks the locus of a pre-existing fault or fault zone which must be considered capable of generating an earthquake much larger than the magnitude 5.0 earthquake of January 31, 1986. Dr. Aggarwal concludes that a magnitude 6.5 earthquake is a reasonable possibility for purposes of determining the safe-shutdown earthquake for the Perry facility.

Dr. Aggarwal based his findings, to a large extent, on his analysis of recent studies performed by Weston Geophysical Corporation (Reference 1) on behalf of the Licensees, by the U. S. Geological Survey (Reference 2) on behalf of the U. S. Nuclear Regulatory Commission (NRC), and on testimony before the U. S. House of Representatives by Dr. L. Seeber (Reference 3).

Since the occurrence of the earthquake on January 31, 1986 in the vicinity of the Perry site, numerous investigations have taken place to study that earthquake, its aftershocks, and the possible causative structure. The concerns enumerated by Dr. Aggarwal above regarding the adequacy of the SSE for the Perry facility have been discussed extensively in supplements to the Perry Safety Evaluation Report (SER) (Reference 4) prepared by the NRC Staff. The conclusions arrived at by the NRC Staff after reviewing all available pertinent information on the geological and geophysical characteristics of the northeastern region of Ohio were that no discernible geological structure had been identified that could be associated with the earthquake of January 31, 1986, that the earthquake by itself was not uncharacteristic of the general earthquake history of the tectonic province (Central Stable Region) in which the Perry Nuclear Power

Plant is located, and that SSE for Perry of magnitude 5.3 ± 0.5 remained appropriate. The Staff still considers these conclusions to be valid.

Since the publication of the above supplements to the Perry SER, the Licensees have continued monitoring the seismic activity in the vicinity of the Perry site. Five quarterly reports have been reviewed by the NRC (References 5-9). The cumulative activity recorded by the seismic monitoring network (Reference 9, Figure 4) exhibits some microseismic activity in the corridor covered by the network. The epicentral locations of these very small tremors (with a magnitude range of -0.7 to 1.3) form a small cluster, parallel to and slightly offset from the AMB. The experience of the NRC Staff indicates that the occurrence of recorded earthquakes of this size are typical of many locations within the Eastern United States. Further they are only detectable when a highly sensitive seismic network such as that employed by the Licensees is used. These events by themselves do not indicate potential for large and possibly damaging earthquakes.

The NRC has also received a Preliminary Report (Reference 10) that discusses the earthquake of July 13, 1987, at Ashtabula, Ohio, and its aftershock sequence. In addition to the discussions on the Ashtabula event of 1987, the Preliminary Report also mentions the earthquake of January 31, 1986 at Chardon, Ohio. The authors, including Dr. Seeber who originally provided testimony concerning the event (Reference 3), recognize, as Dr. Aggarwal did, the association of this event with the NNE trending AMB and suggest that the association may indicate that the magnetic feature could be an expression of a reactivated fault of considerable length on which earthquakes much larger than the 1986 event could occur. However, it should be pointed out that the

authors of this Preliminary Report themselves state that, because of the lack of any evidence of the extension of this postulated fault into the Paleozoic platform cover (upper 2 kilometers of rock strata), very large ruptures involving much of any postulated fault are unlikely. For reasons which are discussed below in response to Dr. Aggarwal's specific arguments, the Staff continues to be of the view that the existing seismic design at Perry is appropriate and in compliance with the requirements of 10 CFR Part 100, Appendix A.

Dr. Aggarwal raises two arguments to support his view that the present SSE for the Perry facility is inadequate. First, Dr. Aggarwal argues that the main shock and aftershock focal mechanisms of the January 31, 1986 earthquake indicate a fault approximately $N30^{\circ}E$ colinear with the AMB. While a general NNE trend of the main shock and aftershock focal mechanisms appears to be inferred, the uncertainty associated with Dr. Aggarwal's preferred orientation is larger than he indicates. For example, the most recent study of the 1986 earthquake (Reference 11) indicates that the northeast trending plane of the main shock could vary from $N22^{\circ}E$ to $N55^{\circ}E$ depending upon the type of seismic wave analyzed. Dr. Aggarwal appears to be incorrect in his assertion that Herrmann and Nguyen (Reference 12) defined a possible source of the earthquake as being a $N28^{\circ}E$ westward dipping fault (82°). Dr. Herrmann (Personal Communication 1988) indicated that this possible source would be a $N21^{\circ}E$ eastward dipping fault.

Dr. Aggarwal next argues that several of the earthquakes that occurred in recent history have a sufficient error band in their epicentral location that they also can be associated with the AMB and that this correlation

implies the existence of a fault on which the occurrence of an earthquake much larger than the earthquake of January 31, 1986 must be considered a realistic possibility. The Staff disagrees with this assertion and bases its conclusion on this matter on the following observations:

1. The earthquake of January 31, 1986 itself is not uncharacteristic of the general earthquake history of the tectonic province, which includes the 1937 earthquake at Anna, Ohio; the 1982 earthquake at Sharpsburg, Kentucky; and many other earthquakes in the range of magnitude of 5.0 to 5.3.
2. The nature and depth of the geologic feature or features manifested by the AMB have not been determined. Throughout the Eastern United States, there are many magnetic features and many earthquakes the size of the 1986 Ohio event. Some of these earthquakes are near anomalous magnetic features, and others are not. Magnetic boundaries indicate changes in rock properties. However, these changes in rock properties do not necessarily indicate faults or support that the indicated faults are active and capable of large ruptures.
3. Dr. Aggarwal is of the opinion that the macroseismicity criterion in Appendix A to 10 CFR Part 100 can be used to identify the AMB as a capable fault. Past use of macroseismicity to identify capable faults has proven to be a difficult process. Macroseismicity has been considered to be a level of seismicity that implies significant, sustained, and coherent tectonic activity representative of a major deformational movement within the earth's crust (Reference 13). Aside from the well-located 1986 earthquake, Dr. Aggarwal has identified six other

earthquakes, one with a magnitude of 4.7 and five in the magnitude range of 2.7 to 3.8, that have occurred since 1885 that, because of location uncertainties, could conceivably be associated with the AMB. Such correlations based upon historic earthquakes, many of which are demonstrably associated with large uncertainties in location, have not in the past proven to be definitive indicators of earthquake sources. Moreover, the statement by Dr. Aggarwal that the data strongly suggest a causal relationship between earthquakes and the AMB is questionable because he ignores the fact that there are other earthquake occurrences in nearby northeastern Ohio whose locations cannot be associated with the AMB. For example, several earthquakes have occurred to the west of the AMB, between that feature and the city of Cleveland. Most recently, the earthquake of July 13, 1987, with a magnitude of 3.6, discussed in Reference 10, a very well-located event, occurred some 25 kilometers east of the AMB on an east-west trending fault. Therefore, the small number of earthquakes used by Dr. Aggarwal to support his correlation, most of which are less than a magnitude of 4, the uncertainties in their location, and the occurrence of earthquakes in areas not associated with the AMB do not, in the Staff's opinion, support use of macroseismicity to identify a capable fault.

4. Dr. Aggarwal argues that even if the AMB cannot be identified as a capable fault, a higher SSE than presently assigned to Perry is needed since Appendix A to 10 CFR Part 100 indicates that if seismological and geological data warrant, the SSE shall be larger than that derived by the normal procedures outlined in the regulations. In the procedures

provided by Appendix A, the SSE is determined by assuming the reoccurrence at the site of the largest historic earthquake that has occurred in the tectonic province within which the site is located. In Dr. Aggarwal's view, the seismological and geological data he presented imply the existence of a fault which could cause a significantly larger earthquake. As discussed above, the NRC staff does not believe the data warrant the existence of such a fault and the need to use an SSE larger than that defined by normal licensing procedures.

The Staff has determined that the arguments presented in the Aggarwal Report indicating the presence of a large fault that could generate an earthquake with a magnitude of 6.5 or greater in the vicinity of the Perry Nuclear Power Plant are not persuasive. The Staff reaffirms its conclusion that the seismic design for the Perry facility is appropriate. Therefore, the request for a suspension of the Perry licenses until additional geological and geophysical studies and engineering evaluations are completed is unwarranted.

Also, given the continued acceptability of the SSE for the Perry facility, the allegations by Petitioner that the Perry facility is in noncompliance with the Commission's regulations in the area of seismic design are unwarranted. In particular, the Petitioner calls into question the seismic capability of the 8x8 fuel spacer utilized at the Perry facility. The allegation is based upon the occurrence of a near-field magnitude 6.5 earthquake and exposure of the spacer to the resultant acceleration in excess of 0.3 g. Our above evaluation indicates that consideration of such an earthquake is inappropriate, therefore concerns related to the seismic capability are unwarranted.

In the absence of a substantial health and safety issue, I decline to grant relief requested by Petitioner pursuant to 10 CFR 2.206. See Consolidated Edison Co. of New York (Indian Point, Units 1, 2, and 3), CLI-75-8, 2 NRC 173, 176 (1975); Washington Public Power Supply System (WPPSS Nuclear Project No 2), DD-84-7, 19 NRC 899, 923 (1984). The northeastern Ohio region is an area of continuing investigation by the NRC, university groups, and the Licensees, which, as indicated previously, are monitoring microseismicity in the vicinity of the Perry plant. The Staff is keeping abreast of studies being performed in the region and will evaluate the resulting reports with respect to any changes that might be required in the above conclusions and any effect such changes might have upon the seismic safety of the Perry plant. ^{2/}

CONCLUSION


For the reasons discussed above, I have concluded that no adequate basis exists for suspending the OL for Perry Unit 1 and the CP for Perry Unit 2. I have also concluded that the geologic and geophysical research and studies requested of the Licensees by the Petitioner also are unnecessary.

^{2/}The Staff has recently received a June 8, 1988 response to the Petition filed by the Licensees. The response contains an enclosure, "Analyses of North-eastern Ohio Seismicity and Tectonics," dated June 1988, prepared by Weston Geophysical Corporation. A review of the Licensees' response indicates that it contains information that supports the Staff's conclusions with regard to the Petition. Since the Staff does not intend to study this document further it is not basing its conclusions in whole or in part upon this response by the Licensees.

I have further concluded that, because the Staff does not consider the SSE for the Perry Nuclear Power Plant to be in question, corrective actions and an adjudicatory hearing to judge the adequacy of those corrective actions are unwarranted. Accordingly, the Petitioner's request for action pursuant to 10 CFR 2.206 is denied.

As provided in 10 CFR 2.206(c), a copy of this decision will be filed with the Secretary of the Commission for the Commission's review.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in cursive script that reads "Thomas E. Murley". The signature is written in dark ink and is positioned above the printed name and title.

Thomas E. Murley, Director
Office of Nuclear Reactor Regulation

Dated at Rockville, Maryland
this 22nd day of June 1988

References

1. Weston Geophysical Corporation: "Investigations of Confirmatory Seismological and Geological Issues. Northeastern Ohio Earthquake of January 31, 1986," dated June 1986.
2. U.S. Geological Survey: "Studies of the January 31, 1986 Northeastern Ohio Earthquake." Open File Report 86-331, 1986.
3. Leonardo Seeber: "Testimony before the Subcommittee on Energy and the Environment Committee on Interior and Insular Affairs of the U.S. House of Representatives." April 8, 1986.
4. Safety Evaluation Report Related to the Operation of Perry Nuclear Power Plant, Units 1 and 2, NUREG-0887, Supplements No. 9, March 1986, and No. 10, September 1986.
5. Weston Geophysical Corporation: "Quarterly Progress Report," Cleveland Electric Illuminating Company, et al. (CEI) Seismic Monitoring Program for Northeastern Ohio, October 15, 1986 - January 15, 1987.
6. Weston Geophysical Corporation: "Second Quarterly Report," CEI Seismic Monitoring Network, January 15 - April 15, 1987.
7. Weston Geophysical Corporation: "Third Quarterly Report," CEI Seismic Monitoring Network, April 16 - July 15, 1987.
8. Weston Geophysical Corporation: "Fourth Quarterly Report," CEI Seismic Monitoring Network, July 16 - October 15, 1987, issued December 1987.
9. Weston Geophysical Corporation: "Fifth Quarterly Report," CEI Seismic Monitoring Network, October 16 - December 31, 1987, issued February 1988.
10. L. Seeber and J. G. Armbruster, Lamont-Doherty Geological Observatory of Columbia University: "Recent and Historic Seismicity in Northeastern Ohio: Reactivation of Precambrian Faults and the Role of Deep Fluid Injection," Preliminary Report to the U.S. NRC.
11. C. Nicholson, E. Rocloffs, and R. L. Wesson: "The Northeastern Ohio Earthquake of 31 January 1986: Was It Induced?" Bulletin of the Seismological Society of America, Volume 78, No. 1, February 1988.
12. Herrmann, R. B., and B. V. Nguyen: "Focal Mechanism Studies of the January 31, 1986 Perry Ohio Earthquake" (abstract), Earthquake Notes, Volume 57, page 107, October 1986.
13. SECY-97-300. Identification of issues pertaining to seismic and geologic siting regulation, policy, and practice for nuclear power plants. April 27, 1979.

UNITED STATES NUCLEAR REGULATORY COMMISSION
DOCKET NOS. 50-440 AND 50-441
CLEVELAND ELECTRIC ILLUMINATING COMPANY, ET AL.
PERRY NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2
ISSUANCE OF DIRECTOR'S DECISION UNDER 10 CFR 2.206

Notice is hereby given that the Director, Office of Nuclear Reactor Regulation, has issued a Director's Decision concerning a Petition dated January 22, 1988, filed by Susan L. Hiatt on behalf of Ohio Citizens for Responsible Energy, Inc. (Petitioner). The Petitioner requested that the Nuclear Regulatory Commission (NRC) grant a variety of relief, including suspension of the operating license for the Perry Nuclear Power Plant, Unit 1, and suspension of the construction permit for the Perry Nuclear Power Plant, Unit 2. The Petition alleged various seismic inadequacies in the Perry Nuclear Power Plant design, specifically:

1. The earthquake of January 31, 1986, at Chardon, Ohio and the historic seismicity near the Perry Nuclear Power Plant can be associated with a tectonic structure (fault) that has been revealed by magnetic data.
2. This tectonic structure is capable of an earthquake with a magnitude of 6.5 or greater.
3. The present safe-shutdown earthquake (magnitude of 5.3 ± 0.5) for the Perry facility does not provide the margin of safety required.


On the basis of these alleged inadequacies, Petitioner claimed that the Perry facility did not comply with the Commission's requirements related to seismic design.

On March 2, 1988, the Director of the Office of Nuclear Reactor Regulation acknowledged receipt of the Petition and notified the Petitioner that this matter would be considered pursuant to 10 CFR 2.206.

The Director has determined that the Petitioner's request should be denied. The reasons for the denial are set forth in the "Director's Decision Pursuant to 10 CFR 2.206" (DD-88-10), which is available for inspection and copying in the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. 20555 and at the local public document room for the Perry Nuclear Power Plant at the Perry Public Library, 3753 Main Street, Perry, Ohio 44081.

A copy of the decision will be filed with the Secretary of the Commission for the Commission's review in accordance with 10 CFR 2.206(c). As provided in 10 CFR 2.206(c), the decision will become the final action of the Commission 25 days after issuance unless the Commission on its own motion institutes review of the decision within that time.

FOR THE NUCLEAR REGULATORY COMMISSION



Thomas E. Murley, Director
Office of Nuclear Reactor Regulation

Dated at Rockville, Maryland
this 22nd day of June 1988

INCOMING

INCOMING AND SIGNATURE TAB

Use this side of the sheet to precede the incoming material when assembling correspondence.

(USE REVERSE SIDE FOR SIGNATURE TAB)

June 22, 1988

DISTRIBUTION:

Docket Files w/incoming	NRC & Local PDRs
EDO#0003493	EDO Reading
TMurley.JSnizek	TMartin, NRR
FMiraglia	KPerkins
GHolahan	Gillespie
DCrutchfield	PKreutzer
TColburn	GPA/PA
DMossburg PMAS(EDO#0003493)	PDIII-3 r/f
DHagan	VStello
Bill Clements, SECY(5)	OGC-WF1
JLieberman	ASLAB
ASLBP	ACRS(10)
JResner(2)(W-501)	

Docket Nos. 50-440
and 50-441

(10 CFR Section 2.206)

Ms. Susan L. Hiatt
Ohio Citizens for Responsible
Energy, Inc.
8275 Munson Road
Mentor, Ohio 44060

Dear Ms. Hiatt:

This letter responds to the "Petition for Immediate Action to Relieve Undue Risk Posed by the Inadequate Seismic Design of the Perry Nuclear Power Plant" filed by you on behalf of the Ohio Citizens for Responsible Energy, Inc. (Petitioner) on January 22, 1988 pursuant to 10 CFR 2.206. The Petition made the following allegations regarding the seismic design of the Perry Nuclear Power Plant (PNPP) of the Cleveland Electric Illuminating Company et al. (Licensees):

1. The earthquake of January 31, 1986 at Chardon, Ohio and the historic seismicity near the PNPP can be associated with a tectonic structure (fault) that has been revealed by magnetic data.
2. This tectonic structure is capable of an earthquake with a magnitude of 6.5 or greater.
3. The present safe-shutdown earthquake (SSE) of magnitude of 5.3 ± 0.5 for the PNPP does not provide an adequate margin of safety.

Based on these allegations, the Petition concluded that the PNPP does not comply with the Commission's regulations regarding seismic design required by 10 CFR Part 50, Appendix A, General Design Criterion 2, and 10 CFR Part 100, Appendix A, Parts IV, V, and VI.

The Petition requested an immediate suspension of the operating license (OL) for PNPP Unit 1 and the construction permit (CP) for PNPP Unit 2. It further requested that additional geologic and geophysical studies be conducted, and appropriate corrective actions considered, by the Licensees and that an adjudicatory hearing be held to evaluate the effectiveness of those corrective actions.

On March 2, 1988, I sent you a letter acknowledging receipt of the Petition and declined to take any immediate action for the reasons stated in that

Ms. Susan L. Hiatt

-2-

letter. I also indicated that a formal decision would be issued in the reasonably near future.

For the reasons set forth in the enclosed Director's Decision under 10 CFR 2.206, DD-88-10, your Petition has been denied. A copy of the Decision will be referred to the Secretary of the Commission for the Commission's review in accordance with 10 CFR 2.206(c) of the Commission's regulations. As provided by this regulation, the Decision will constitute the final action of the Commission twenty-five days after the date of issuance of the Decision unless the Commission, on its own motion, institutes a review of the Decision within that time. For your information, I have enclosed a copy of the notice regarding this Decision that has been filed with the Office of the Federal Register for publication.

Sincerely,

Original signed by
Thomas E. Murley.

Thomas E. Murley, Director
Office of Nuclear Reactor Regulation

Enclosures:

1. Director's Decision
2. Federal Register Notice

*SEE PREVIOUS CONCURRENCE

Office: LA/PDIII-3
Surname: *PKreutzer
Date: 05/13/88

PM/PDIII-3
*TColburn/tg
05/13/88

PD/PDIII-3 OGC
*KPerkins *LChandler
05/13/88 06/09/88

Office: AD/DRSP
Surname: *GHolahan
Date: 05/27/88

D/DRSP
*DCrutchfield
05/27/88

AD
*FMiraglia
05/27/88
6/22/88

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

OFFICE OF NUCLEAR REACTOR REGULATION
Thomas E. Murley, Director

In the Matter of)	
CLEVELAND ELECTRIC ILLUMINATING)	Docket Nos. 50-440
COMPANY, ET AL.)	50-441
(Perry Nuclear Power Plant,)	(10 CFR 2.206)
Units 1 & 2))	

DIRECTOR'S DECISION UNDER 10 CFR 2.206

INTRODUCTION

On January 22, 1988, Ms. Susan L. Hiatt on behalf of Ohio Citizens for Responsible Energy, Inc. (Petitioner) filed with the Director of the Office of Nuclear Reactor Regulation of the Nuclear Regulatory Commission (NRC) a "Petition for Immediate Action to Relieve Undue Risk Posed by the Inadequate Seismic Design of the Perry Nuclear Power Plant" requesting a variety of relief including immediate suspension of the operating license (OL) for the Perry Nuclear Power Plant, Unit 1, and suspension of the construction permit (CP) for the Perry Nuclear Power Plant, Unit 2, of the Cleveland Electric Illuminating Company, et al. ^{1/} (Licensees).

^{1/} Cleveland Electric Illuminating Company is authorized to act as agent for Duquesne Light Company, Ohio Edison Company, Pennsylvania Power Company, and the Toledo Edison Company and has exclusive responsibility and control over the physical construction, operation, and maintenance of the facility.

The Petitioner also requested that, before reinstating the OL for Perry Unit 1 and the CP for Perry Unit 2, the Licensees should be required to engage in appropriate geologic and geophysical research, including but not limited to confirmatory studies recommended by Petitioner, to determine the appropriate safe-shutdown earthquake (SSE) for the PNPP.

Additionally, the Petitioner requested that the Licensees be required to evaluate whether applicable systems, structures, and components important to safety will remain functional throughout their design life and withstand the vibratory ground motion (and concurrent normal and accident loads) resulting from the earthquake which appropriate geologic and geophysical research reveals to be the proper SSE for the Perry facility. If any system, structure, or component were unable to withstand the appropriate SSE, corrective action should be taken and an adjudicatory hearing should be held to determine whether the corrective actions taken are sufficient. Should the corrective actions not be completed as specified, the Petitioner requested that the OL and CP for Perry Units 1 and 2, respectively, be revoked.

The Petition's allegations are based largely upon an analysis of data and evaluations that had been performed by other groups in response to the January 31, 1986 earthquake that occurred near the Perry facility. The analysis was performed for the Petitioner by Dr. Yash Aggarwal, and his affidavit and report (Aggarwal Report) are attached to the Petition.

The Aggarwal Report notes that, on January 31, 1986, an earthquake with a magnitude of 5.0 occurred with an epicenter about 10 miles south of the

PNPP. Dr. Aggarwal concluded (a) that the January 1986 earthquake and historical seismicity can be associated with a tectonic structure (fault) revealed by magnetic data; (b) that this fault passes within a few miles of the PNPP and is capable of generating much larger earthquakes; (c) that an earthquake with a magnitude of 6.5 is a realistic probability for the purposes of determining the proper SSE for Perry; and (d) that the present magnitude of 5.3 ± 0.5 for the SSE does not provide an adequate margin of safety required for the PNPP. The Petitioner alleges for these reasons that the Licensees are in noncompliance with various regulations of the Commission, specifically, 10 CFR Part 50, Appendix A, General Design Criterion 2, and 10 CFR Part 100, Appendix A, Parts IV, V, and VI.

On March 2, 1988, I acknowledged receipt of the Petition and explained to the Petitioner my reasons for declining to take any immediate actions. I indicated that I would issue a final decision in this matter in the reasonably near future. My decision in this matter follows.

DISCUSSION

The basis for the Petition is the Aggarwal Report. In his report, Dr. Aggarwal asserts that an earthquake with a magnitude of 6.5 or larger is probable on a "feature" that, at its closest approach, is approximately 10 kilometers southeast of the Perry site. This feature is a "boundary" in the magnetic map of Ohio which separates a region of relatively high magnetic relief to the northwest from a region of relatively low magnetic relief to the southeast. Weston Geophysical Corporation identified this boundary as the "Akron Magnetic Boundary" (AMB) (Reference 1, Figure 4-2). Dr. Aggarwal

concludes that correlations of magnetic data and "macroearthquakes" known to have occurred historically within 50 miles of the 1986 event strongly suggest that the AMB marks the locus of a pre-existing fault or fault zone which must be considered capable of generating an earthquake much larger than the magnitude 5.0 earthquake of January 31, 1986. Dr. Aggarwal concludes that a magnitude 6.5 earthquake is a reasonable possibility for purposes of determining the safe-shutdown earthquake for the Perry facility.

Dr. Aggarwal based his findings, to a large extent, on his analysis of recent studies performed by Weston Geophysical Corporation (Reference 1) on behalf of the Licensees, by the U. S. Geological Survey (Reference 2) on behalf of the U. S. Nuclear Regulatory Commission (NRC), and on testimony before the U. S. House of Representatives by Dr. L. Seeber (Reference 3).

Since the occurrence of the earthquake on January 31, 1986 in the vicinity of the Perry site, numerous investigations have taken place to study that earthquake, its aftershocks, and the possible causative structure. The concerns enumerated by Dr. Aggarwal above regarding the adequacy of the SSE for the Perry facility have been discussed extensively in supplements to the Perry Safety Evaluation Report (SER) (Reference 4) prepared by the NRC Staff. The conclusions arrived at by the NRC Staff after reviewing all available pertinent information on the geological and geophysical characteristics of the northeastern region of Ohio were that no discernible geological structure had been identified that could be associated with the earthquake of January 31, 1986, that the earthquake by itself was not uncharacteristic of the general earthquake history of the tectonic province (Central Stable Region) in which the Perry Nuclear Power

Plant is located, and that SSE for Perry of magnitude 5.3 ± 0.5 remained appropriate. The Staff still considers these conclusions to be valid.

Since the publication of the above supplements to the Perry SER, the Licensees have continued monitoring the seismic activity in the vicinity of the Perry site. Five quarterly reports have been reviewed by the NRC (References 5-9). The cumulative activity recorded by the seismic monitoring network (Reference 9, Figure 4) exhibits some microseismic activity in the corridor covered by the network. The epicentral locations of these very small tremors (with a magnitude range of -0.7 to 1.3) form a small cluster, parallel to and slightly offset from the AMB. The experience of the NRC Staff indicates that the occurrence of recorded earthquakes of this size are typical of many locations within the Eastern United States. Further they are only detectable when a highly sensitive seismic network such as that employed by the Licensees is used. These events by themselves do not indicate potential for large and possibly damaging earthquakes.

The NRC has also received a Preliminary Report (Reference 10) that discusses the earthquake of July 13, 1987, at Ashtabula, Ohio, and its aftershock sequence. In addition to the discussions on the Ashtabula event of 1987, the Preliminary Report also mentions the earthquake of January 31, 1986 at Chardon, Ohio. The authors, including Dr. Seeber who originally provided testimony concerning the event (Reference 3), recognize, as Dr. Aggarwal did, the association of this event with the NNE trending AMB and suggest that the association may indicate that the magnetic feature could be an expression of a reactivated fault of considerable length on which earthquakes much larger than the 1986 event could occur. However, it should be pointed out that the

authors of this Preliminary Report themselves state that, because of the lack of any evidence of the extension of this postulated fault into the Paleozoic platform cover (upper 2 kilometers of rock strata), very large ruptures involving much of any postulated fault are unlikely. For reasons which are discussed below in response to Dr. Aggarwal's specific arguments, the Staff continues to be of the view that the existing seismic design at Perry is appropriate and in compliance with the requirements of 10 CFR Part 100, Appendix A.

Dr. Aggarwal raises two arguments to support his view that the present SSE for the Perry facility is inadequate. First, Dr. Aggarwal argues that the main shock and aftershock focal mechanisms of the January 31, 1986 earthquake indicate a fault approximately N30°E colinear with the AMB. While a general NNE trend of the main shock and aftershock focal mechanisms appears to be inferred, the uncertainty associated with Dr. Aggarwal's preferred orientation is larger than he indicates. For example, the most recent study of the 1986 earthquake (Reference 11) indicates that the northeast trending plane of the main shock could vary from N22°E to N55°E depending upon the type of seismic wave analyzed. Dr. Aggarwal appears to be incorrect in his assertion that Herrmann and Nguyen (Reference 12) defined a possible source of the earthquake as being a N28°E westward dipping fault (82°). Dr. Herrmann (Personal Communication 1988) indicated that this possible source would be a N21°E eastward dipping fault.

Dr. Aggarwal next argues that several of the earthquakes that occurred in recent history have a sufficient error band in their epicentral location that they also can be associated with the AMB and that this correlation

implies the existence of a fault on which the occurrence of an earthquake much larger than the earthquake of January 31, 1986 must be considered a realistic possibility. The Staff disagrees with this assertion and bases its conclusion on this matter on the following observations:

1. The earthquake of January 31, 1986 itself is not uncharacteristic of the general earthquake history of the tectonic province, which includes the 1937 earthquake at Anna, Ohio; the 1982 earthquake at Sharpsburg, Kentucky; and many other earthquakes in the range of magnitude of 5.0 to 5.3.
2. The nature and depth of the geologic feature or features manifested by the AMB have not been determined. Throughout the Eastern United States, there are many magnetic features and many earthquakes the size of the 1986 Ohio event. Some of these earthquakes are near anomalous magnetic features, and others are not. Magnetic boundaries indicate changes in rock properties. However, these changes in rock properties do not necessarily indicate faults or support that the indicated faults are active and capable of large ruptures.
3. Dr. Aggarwal is of the opinion that the macroseismicity criterion in Appendix A to 10 CFR Part 100 can be used to identify the AMB as a capable fault. Past use of macroseismicity to identify capable faults has proven to be a difficult process. Macroscopicity has been considered to be a level of seismicity that implies significant, sustained, and coherent tectonic activity representative of a major deformational movement within the earth's crust (Reference 13). Aside from the well-located 1986 earthquake, Dr. Aggarwal has identified six other

earthquakes, one with a magnitude of 4.7 and five in the magnitude range of 2.7 to 3.8, that have occurred since 1885 that, because of location uncertainties, could conceivably be associated with the AMB. Such correlations based upon historic earthquakes, many of which are demonstrably associated with large uncertainties in location, have not in the past proven to be definitive indicators of earthquake sources. Moreover, the statement by Dr. Aggarwal that the data strongly suggest a causal relationship between earthquakes and the AMB is questionable because he ignores the fact that there are other earthquake occurrences in nearby northeastern Ohio whose locations cannot be associated with the AMB. For example, several earthquakes have occurred to the west of the AMB, between that feature and the city of Cleveland. Most recently, the earthquake of July 13, 1987, with a magnitude of 3.6, discussed in Reference 10, a very well-located event, occurred some 25 kilometers east of the AMB on an east-west trending fault. Therefore, the small number of earthquakes used by Dr. Aggarwal to support his correlation, most of which are less than a magnitude of 4, the uncertainties in their location, and the occurrence of earthquakes in areas not associated with the AMB do not, in the Staff's opinion, support use of macroseismicity to identify a capable fault.

4. Dr. Aggarwal argues that even if the AMB cannot be identified as a capable fault, a higher SSE than presently assigned to Perry is needed since Appendix A to 10 CFR Part 100 indicates that if seismological and geological data warrant, the SSE shall be larger than that derived by the normal procedures outlined in the regulations. In the procedures

provided by Appendix A, the SSE is determined by assuming the reoccurrence at the site of the largest historic earthquake that has occurred in the tectonic province within which the site is located. In Dr. Aggarwal's view, the seismological and geological data he presented imply the existence of a fault which could cause a significantly larger earthquake. As discussed above, the NRC staff does not believe the data warrant the existence of such a fault and the need to use an SSE larger than that defined by normal licensing procedures.

The Staff has determined that the arguments presented in the Aggarwal Report indicating the presence of a large fault that could generate an earthquake with a magnitude of 6.5 or greater in the vicinity of the Perry Nuclear Power Plant are not persuasive. The Staff reaffirms its conclusion that the seismic design for the Perry facility is appropriate. Therefore, the request for a suspension of the Perry licenses until additional geological and geophysical studies and engineering evaluations are completed is unwarranted.

Also, given the continued acceptability of the SSE for the Perry facility, the allegations by Petitioner that the Perry facility is in noncompliance with the Commission's regulations in the area of seismic design are unwarranted. In particular, the Petitioner calls into question the seismic capability of the 8x8 fuel spacer utilized at the Perry facility. The allegation is based upon the occurrence of a near-field magnitude 6.5 earthquake and exposure of the spacer to the resultant acceleration in excess of 0.3 g. Our above evaluation indicates that consideration of such an earthquake is inappropriate, therefore concerns related to the seismic capability are unwarranted.

In the absence of a substantial health and safety issue, I decline to grant relief requested by Petitioner pursuant to 10 CFR 2.206. See Consolidated Edison Co. of New York (Indian Point, Units 1, 2, and 3), CLI-75-8, 2 NRC 173, 176 (1975); Washington Public Power Supply System (WPPSS Nuclear Project No 2), DD-84-7, 19 NRC 899, 923 (1984). The northeastern Ohio region is an area of continuing investigation by the NRC, university groups, and the Licensees, which, as indicated previously, are monitoring microseismicity in the vicinity of the Perry plant. The Staff is keeping abreast of studies being performed in the region and will evaluate the resulting reports with respect to any changes that might be required in the above conclusions and any effect such changes might have upon the seismic safety of the Perry plant. ^{2/}

CONCLUSION


For the reasons discussed above, I have concluded that no adequate basis exists for suspending the OL for Perry Unit 1 and the CP for Perry Unit 2. I have also concluded that the geologic and geophysical research and studies requested of the Licensees by the Petitioner also are unnecessary.

^{2/}The Staff has recently received a June 8, 1988 response to the Petition filed by the Licensees. The response contains an enclosure, "Analyses of North-eastern Ohio Seismicity and Tectonics," dated June 1988, prepared by Weston Geophysical Corporation. A review of the Licensees' response indicates that it contains information that supports the Staff's conclusions with regard to the Petition. Since the Staff does not intend to study this document further it is not basing its conclusions in whole or in part upon this response by the Licensees.

I have further concluded that, because the Staff does not consider the SSE for the Perry Nuclear Power Plant to be in question, corrective actions and an adjudicatory hearing to judge the adequacy of those corrective actions are unwarranted. Accordingly, the Petitioner's request for action pursuant to 10 CFR 2.206 is denied.

As provided in 10 CFR 2.206(c), a copy of this decision will be filed with the Secretary of the Commission for the Commission's review.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in cursive script that reads "Thomas E. Murley". The signature is written in dark ink and is positioned above the typed name and title.

Thomas E. Murley, Director
Office of Nuclear Reactor Regulation

Dated at Rockville, Maryland
this 22nd day of June 1988

References

1. Weston Geophysical Corporation: "Investigations of Confirmatory Seismological and Geological Issues. Northeastern Ohio Earthquake of January 31, 1986," dated June 1986.
2. U.S. Geological Survey: "Studies of the January 31, 1986 Northeastern Ohio Earthquake." Open File Report 86-331, 1986.
3. Leonardo Seeber: "Testimony before the Subcommittee on Energy and the Environment Committee on Interior and Insular Affairs of the U.S. House of Representatives." April 8, 1986.
4. Safety Evaluation Report Related to the Operation of Perry Nuclear Power Plant, Units 1 and 2, NUREG-0887, Supplements No. 9, March 1986, and No. 10, September 1986.
5. Weston Geophysical Corporation: "Quarterly Progress Report," Cleveland Electric Illuminating Company, et al. (CEI) Seismic Monitoring Program for Northeastern Ohio, October 15, 1986 - January 15, 1987.
6. Weston Geophysical Corporation: "Second Quarterly Report," CEI Seismic Monitoring Network, January 15 - April 15, 1987.
7. Weston Geophysical Corporation: "Third Quarterly Report," CEI Seismic Monitoring Network, April 16 - July 15, 1987.
8. Weston Geophysical Corporation: "Fourth Quarterly Report," CEI Seismic Monitoring Network, July 16 - October 15, 1987, issued December 1987.
9. Weston Geophysical Corporation: "Fifth Quarterly Report," CEI Seismic Monitoring Network, October 16 - December 31, 1987, issued February 1988.
10. L. Seeber and J. G. Armbruster, Lamont-Doherty Geological Observatory of Columbia University: "Recent and Historic Seismicity in Northeastern Ohio: Reactivation of Precambrian Faults and the Role of Deep Fluid Injection," Preliminary Report to the U.S. NRC.
11. C. Nicholson, E. Rocloffs, and R. L. Wesson: "The Northeastern Ohio Earthquake of 31 January 1986: Was It Induced?" Bulletin of the Seismological Society of America, Volume 78, No. 1, February 1988.
12. Herrmann, R. B., and B. V. Nguyen: "Focal Mechanism Studies of the January 31, 1986 Perry Ohio Earthquake" (abstract), Earthquake Notes, Volume 57, page 107, October 1986.
13. SECY-97-300. Identification of issues pertaining to seismic and geologic siting regulation, policy, and practice for nuclear power plants. April 27, 1979.

UNITED STATES NUCLEAR REGULATORY COMMISSION
DOCKET NOS. 50-440 AND 50-441
CLEVELAND ELECTRIC ILLUMINATING COMPANY, ET AL.
PERRY NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2
ISSUANCE OF DIRECTOR'S DECISION UNDER 10 CFR 2.206

Notice is hereby given that the Director, Office of Nuclear Reactor Regulation, has issued a Director's Decision concerning a Petition dated January 22, 1988, filed by Susan L. Hiatt on behalf of Ohio Citizens for Responsible Energy, Inc. (Petitioner). The Petitioner requested that the Nuclear Regulatory Commission (NRC) grant a variety of relief, including suspension of the operating license for the Perry Nuclear Power Plant, Unit 1, and suspension of the construction permit for the Perry Nuclear Power Plant, Unit 2. The Petition alleged various seismic inadequacies in the Perry Nuclear Power Plant design, specifically:

1. The earthquake of January 31, 1986, at Chardon, Ohio and the historic seismicity near the Perry Nuclear Power Plant can be associated with a tectonic structure (fault) that has been revealed by magnetic data.
2. This tectonic structure is capable of an earthquake with a magnitude of 6.5 or greater.
3. The present safe-shutdown earthquake (magnitude of 5.3 ± 0.5) for the Perry facility does not provide the margin of safety required.


On the basis of these alleged inadequacies, Petitioner claimed that the Perry facility did not comply with the Commission's requirements related to seismic design.

On March 2, 1988, the Director of the Office of Nuclear Reactor Regulation acknowledged receipt of the Petition and notified the Petitioner that this matter would be considered pursuant to 10 CFR 2.206.

The Director has determined that the Petitioner's request should be denied. The reasons for the denial are set forth in the "Director's Decision Pursuant to 10 CFR 2.206" (DD-88-10), which is available for inspection and copying in the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. 20555 and at the local public document room for the Perry Nuclear Power Plant at the Perry Public Library, 3753 Main Street, Perry, Ohio 44081.

A copy of the decision will be filed with the Secretary of the Commission for the Commission's review in accordance with 10 CFR 2.206(c). As provided in 10 CFR 2.206(c), the decision will become the final action of the Commission 25 days after issuance unless the Commission on its own motion institutes review of the decision within that time.

FOR THE NUCLEAR REGULATORY COMMISSION



Thomas E. Murley, Director
Office of Nuclear Reactor Regulation

Dated at Rockville, Maryland
this 22nd day of June 1988



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20545

ACTION

EDO PRINCIPAL CORRESPONDENCE CONTROL

FROM:

SUSAN L. HIATT
OHIO CITIZENS FOR RESPONSIBLE
ENERGY, INC. (OCRE)

DUE: 03/09/88

6/2/88

EDO CONTROL: 003493

DOC DT: 01/22/88

FINAL REPLY:

TO:

NRR

FOR SIGNATURE OF:

** GREEN **

SECY NO:

DESC:

2.206 PETITION FOR IMMEDIATE ACTION TO RELIEVE
UNDUE RISK POSED BY THE INADEQUATE SEISMIC DESIGN
OF THE PERRY NUCLEAR POWER PLANT

ROUTING:

MURLEY
DAVIS

DATE: 02/11/88

ASSIGNED TO: OGC

CONTACT: MURRAY

SPECIAL INSTRUCTIONS OR REMARKS:

NRR RECEIVED: FEBRUARY 23, 1988

ACTION: DRSP:CRUTCHFIELD

NRR ROUTING: MURLEY/SNIEZEK

MIRAGLIA

MARTIN

GILLESPIE

MOSSBURG

ACTION
DUE TO NRR DIRECTOR'S OFFICE
BY March 4, 1988

878115

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

Before the Director, Office of Nuclear Reactor Regulation

In the Matter of)
)
THE CLEVELAND ELECTRIC ILLUMINATING)
COMPANY, ET AL.) Docket Nos. 50-440/441
) 2.206 Petition
(Perry Nuclear Power Plant, Units 1)
and 2))
_____)

PETITION FOR IMMEDIATE ACTION TO RELIEVE
UNDUE RISK POSED BY THE INADEQUATE SEISMIC
DESIGN OF THE PERRY NUCLEAR POWER PLANT

I. INTRODUCTION

Pursuant to 10 CFR 2.206, the Ohio Citizens for Responsible Energy, Inc. ("OCRE") hereby petitions the Director, Office of Nuclear Reactor Regulation, to take immediate action to relieve undue risks to the public health and safety posed by the inadequacy of the seismic design of the Perry Nuclear Power Plant. OCRE reserves the right to reply to any and all responses to this petition which the Cleveland Electric Illuminating Company may submit and to have such replies considered by the Director before a decision is rendered on this Petition.

II. DESCRIPTION OF PETITIONER

Petitioner OCRE is a private, nonprofit corporation organized under the laws of the State of Ohio. OCRE specializes in research and advocacy on issues of nuclear

8803080244
48PP

reactor safety and has as its goal the promotion and application of the highest standards of safety to such facilities. OCRE was an intervenor in the operating license proceeding for the Perry Nuclear Power Plant. Members of OCRE live and own property within 15 miles of Perry.

III. GROUNDS FOR RELIEF

On January 31, 1986 an earthquake of magnitude 5.0 occurred with an epicenter about 10 miles south of the Perry Nuclear Power Plant. Concerned about the implications of seismicity in close proximity to PNPP, OCRE retained a consultant, Dr. Yash P. Aggarwal, to research the matter. Dr. Aggarwal's conclusions, presented in the Affidavit of Dr. Yash P. Aggarwal and associated report, "Seismicity and Tectonic Structure in Northeastern Ohio: Implications for Earthquake Hazard to the Perry Nuclear Power Plant", attached and incorporated herein as Appendix A, are that the January 1986 earthquake and historical seismicity can be associated with a tectonic structure revealed by magnetic data; that this fault, which probably passes within a few miles of PNPP, is capable of generating much larger earthquakes; that a magnitude 6.5 earthquake is a realistic possibility for the purposes of determining the proper Safe Shutdown Earthquake for Perry; and that the present SSE of $m_b = 5.3 + \text{or} - 0.5$ does not provide the margin of safety required for nuclear power plants.

These conclusions reveal that PNPP is in a state of regulatory non-compliance, and, as such, poses an undue risk to

the health and safety of the public. Specifically:

1. Licensees have failed to comply with the requirements of 10 CFR 100, Appendix A, Part IV, "Required Investigations", in that they have not identified and evaluated all tectonic structures in the region surrounding the site (Part IV.(a)(2)); they have not correlated epicenters or locations of highest intensity of historically reported earthquakes with tectonic structures (Part IV.(a)(6)); and they have not conducted a reasonable investigation, using suitable geologic and geophysical techniques, of all faults in the region to determine whether they are to be considered as capable faults (Part IV.(a)(7)).

2. Licensees have failed to comply with the requirements of 10 CFR 100, Appendix A, Part V, "Seismic and Geologic Design Bases", in that they have failed to evaluate the maximum earthquake potential associated with tectonic structures in the region, applying the procedures of Part V in a conservative manner, nor have they assumed that the epicenters of the earthquakes of greatest magnitude related to the tectonic structure are situated at the point on the structure closest to the site (Part V.(a)(1)); and as a result, the present SSE for PNPP is insufficient.

3. Licensees have failed to comply with 10 CFR 50, Appendix A, General Design Criterion 2, "Design Bases for Protection Against Natural Phenomena", and 10 CFR 100, Appendix A, Part

VI, "Application to Engineering Design," in that they have not demonstrated that systems, structures, and components necessary to assure (i) the integrity of the reactor coolant pressure boundary, (ii) the capability to shut down the reactor and maintain it in a safe condition, and (iii) the capability to prevent or mitigate the consequences of accidents, including but not limited to the 8x8 fuel spacer (see Appendix B attached and incorporated herein), can withstand the vibratory ground motion resulting from a near-field magnitude 6.5 earthquake, including aftershocks and applicable concurrent functional and accident-induced loads, and remain functional at all stages of their design life.

4. Licensees have failed to comply with 10 CFR 50, Appendix A, General Design Criterion 2, "Design Bases for Protection Against Natural Phenomena", and 10 CFR 100, Appendix A, Part VI, "Application to Engineering Design," in that they have not demonstrated that systems, structures, and components necessary to assure (i) the integrity of the reactor coolant pressure boundary, (ii) the capability to shut down the reactor and maintain it in a safe condition, and (iii) the capability to prevent or mitigate the consequences of accidents, including but not limited to the 8x8 fuel spacer (see Appendix B attached and incorporated herein), can withstand the vibratory ground motion resulting from that earthquake which appropriate geologic and geophysical research, and conservative application of the procedures of Part V of 10 CFR 100 Appendix A, reveal to be the proper SSE, including aftershocks and applicable

concurrent functional and accident-induced loads, and remain functional at all stages of their design life.

5. Licensees have failed to comply with the requirements of 10 CFR 100, Appendix A, Part V.(a)(2) in that the Operating Basis Earthquake for PNPP is insufficient; licensees have not demonstrated that plant features necessary for continued operation without undue risk to the health and safety of the public can withstand the maximum vibratory ground motion which appropriate geologic and geophysical research, and conservative application of the procedures of Part V, reveal to be appropriately associated with the proper OBE, and remain functional at all stages of their design life.

IV. RELIEF REQUESTED

Because this lack of compliance with the NRC's regulations raises substantial health and safety issues (see Northern Indiana Public Service Co. (Bailly Generating Station, Nuclear-1), CLI-78-7, 7 NRC 428, 433 (1978), aff'd sub nom. Porter County Chapter v. NRC, 606 F.2d 1363 (D.C. Cir. 1979)), the granting of relief is appropriate. OCRE requests that:

1. The operating license for Perry Unit 1 and the construction permit for Perry Unit 2 be suspended.
2. Prior to reinstating the Perry Unit 1 operating license and the Perry Unit 2 construction permit:

(a) the Cleveland Electric Illuminating Company should be required to engage in appropriate geologic and geophysical research, including but not limited to the recommended confirmatory studies set forth at pp. 25-26 of the report "Seismicity and Tectonic Structure in Northeastern Ohio: Implications for Earthquake Hazard to the Perry Nuclear Power Plant", for the purpose of determining the appropriate SSE. In accordance with the recommendation therein, the unprocessed data from such research should be made available to disinterested investigators;

(b) CEI must evaluate whether applicable systems, structures, and components important to safety can withstand and remain functional, throughout their design lives, the vibratory ground motion (and concurrent normal and accident loads) resulting from (i) a near-field magnitude 6.5 earthquake; and (ii) the earthquake which appropriate geologic and geophysical research reveals to be the proper SSE for Perry. Should these systems, structures, and components, as built and installed in the plant, be unable to withstand either the magnitude 6.5 earthquake or the appropriate SSE, corrective actions, including redesign and/or replacement, must be taken such that these seismic events can be withstood;

(c) In every other respect, CEI must take corrective actions to remedy all areas of noncompliance set forth in this petition;

(d) a formal, public adjudicatory hearing should be held to determine whether the corrective actions taken are sufficient to achieve a level of safety that ensures that plant operation will not pose undue risk to the health and safety of the

public; and

(e) all changes found by the hearing board to be necessary to achieve that level of safety should be fully implemented at Perry Unit 1 and incorporated as conditions in the construction permit of Unit 2.

3. Unless the conditions enumerated in paragraph 2. above are met, the operating license for Perry Unit 1 and the construction permit for Perry Unit 2 should be revoked.

Respectfully submitted,



Susan L. Hiatt
OCRE Representative
8275 Munson Road
Mentor, OH 44060
(216) 255-3158

DATED: JAN. 22, 1988

APPENDIX A

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

Before the Director, Office of Nuclear Reactor Regulation

In the matter of)	
)	
THE CLEVELAND ELECTRIC)	Docket No. 50-440/441
ILLUMINATING CO. ET AL.)	2.206 Petition
)	
(Perry Nuclear power)	
Plant, Units 1 and 2)	
)	

AFFIDAVIT OF DR. YASH P. AGGARWAL

STATE OF NEW YORK)
) ss.:
 COUNTY OF *Rockland*


I, YASH P. AGGARWAL, being duly sworn according to law, do hereby state the following as true:

- 1) I am president of Sensearth, Inc. Sensearth, Inc. is a corporation incorporated in the State of New York and engaged in the business of providing consulting services in the field of Geophysics, especially pertaining to earthquake hazard related problems. A statement of my professional qualifications is attached hereto as Exhibit A.
- 2) I am responsible for the preparation of the report entitled "Seismicity and Tectonic Structure in Northeastern Ohio: Implications for Earthquake Hazard to the Perry Nuclear Power Plant." This report is true and correct to the best of my knowledge and belief. (Report attached as Exhibit B and incorporated herein).
- 3) Based upon a recent review of seismological and geophysical data for northeastern Ohio (as documented in the above-mentioned report), it is my professional opinion that an earthquake of magnitude 6.5 or larger is probable in the vicinity of the Perry Nuclear Power Plant.
- 4) The design basis of the Perry Nuclear Power Plant is a magnitude 5.3 + or - 0.5 or a Modified Mercalli Intensity VII earthquake. Given my findings, it is my professional opinion

that the Safe Shutdown Earthquake for PNPP should be substantially larger than the design earthquake used for PNPP.


5) Affiant further sayeth naught.

Dated: 6/9/87



Yash P. Aggarwal

Sworn to and subscribed before me, a Notary Public, on this 9 day of June, 1987, at New City, New York.



NOTARY PUBLIC

JUDITH GORMLEY
NOTARY PUBLIC, STATE OF NEW YORK
No. 4780589
Qualified in Rockland County
Commission Expires June 1, 1989

EXHIBIT A

CURRICULUM VITAE

YASH PAL AGGARWAL

Business Address

SENSEARTH Inc., 17 Tarry Hill Drive, New City, N.Y. 10956
(914) 6341980

Position: President

Home Address

2 Rookery Circle, New City, N.Y. 10956

Education

Ph.D. Seismology, Columbia University, 1975

M.Sc. Geophysical Engineering, Institut de Physique du Globe
Strasbourg, France, 1970

B.Sc. University of Strasbourg, France, 1966
(Math. & Physics Major)

B.Sc. Fergusson College, University of Poona, India, 1962
(Physics Major)

Awards and Scholarships

UNESCO support to study the Rift Valley in Kenya, 1970

French Government Scholarship, 1964-1970

Best student award, Nairobi, Kenya, 1958

Professional Activities

Member American Geophysical Union

Expert witness and consultant to the State of New York on earthquake
related problems, 1976-1977

Consultant to the Govt. of Venezuela, earthquake hazard to large
engineering projects, 1980-1985

Consultant to the Town of Clarkstown, N.Y., on Quarry blasts related
problems, 1985

- 1971 Microearthquakes and the Rift Valley in Kenya (Master's Thesis, in French), University of Strasbourg, France, 1-57 pp.
- 1971 A microearthquake survey in Kenya, with P. Molnar, Bull. Seismol. Soc. Am., 61, no. 1, 195-201.
- 1972 P and S travel times in the Tonga-Fiji region: A zone of low velocity in the uppermost mantle behind the Tonga Island arc, with B. Muawia and B. Isacks, J. Geophys. Res., 77, no. 2 6427-6434.
- 1972 New results in the field of earthquake prediction, Proceedings of the Eleventh Annual Conference on Recent Advances in Physics, Chapel Hill, 59-63:
- 1972 The Adirondacks, New York, earthquake swarm of 1971 and tectonic implications, with M. L. Sbar and J. Armbruster, Bull. Seismol. Soc. Am., 62, no. 5, 1303-1317.
- 1973 Premonitory changes in seismic velocities and prediction of earthquakes, with L. R. Sykes, J. Armbruster and M. L. Sbar, Nature, 241, 101-104.
- 1973 Earthquake prediction: A physical basis, with C. H. Scholz and L. R. Sykes, Science, 181, 803-810.
- 1974 Can we predict earthquakes, Science Today, 13-17. A Times of India Publication, Bombay, India, February 1974.
- 1975 Spatial and temporal variations in t_0/t_p and in P-wave residuals at Blue Mountain Lake, New York: Application to earthquake prediction, with L. R. Sykes, D. Simpson and P. G. Richards, J. Geophys. Res., 80, no. 5, 718-732.
- 1975 Earthquake prediction: Dilatancy-fluid diffusion mechanism of earthquake precursors (review paper), Encyclopedia Universalis, Paris, France (in French).
- 1977 Testimony on behalf of the State of New York, before the Atomic Safety and Licensing Appeal Board, NRC, concerning Indian Point Units, 1, 2, and 3, filed February 25, 1977.
- 1978 Earthquakes, faults and nuclear power plants in southeastern New York-northern New Jersey, with L. R. Sykes, Science, 200, 425-429.
- 1980 Seismicity and tectonics of Philippine Islands, with H. K. Acharya, J. Geophys. Res., 85, 3239-3250.

- 1981 Seismotectonics of northeastern North America and adjacent Canada, with J.-P. Yang, J. Geophys. Res., 86, 4981.
- 1981 Present-day tectonics of the southeastern Caribbean and northern Venezuela, with O. Perez, J. Geophys. Res., 86, 10791.
- 1981 Investigaciones sismologicas en el occidente de Venezuela para las consideraciones sismicas en el Proyecto Uribante-Caparao, FUNVISIS, Caracas, Nov. 1981, pp. 1-14.
- 1982 Sismos, locales registrados por la Red Sismologica de Uribante-Caparo: Implicaciones para el diseno antisismico de las presas y las probabilidades de sismicidad inducida, FUNVISIS, Caracas, Marzo, 1982.
- 1984 Actividad seismica en la region de Uribante-Caparo, Enero 1983 - Marzo 1984, FUNVISIS, Caracas, Mayo 1984.
- 1984 Actividad sismica en la region de Uribante-Caparo, Abril - Agosto 1984, FUNVISIS, Caracas, Oct. 1984.
- 1984 Long-term seismic behavior of the focal and adjacent regions of great earthquakes during two successive shocks, with O. Perez and C. Scholz, J. Geophys. Res., in press.
- 1985 Ground vibrations and airblasts generated by blasting at Trap Rock Quarry: Seismological, Legal, and Health and Safety Aspects. Report to the Town Board, Town of Clarkstown, Rockland Co., N.Y.

EXHIBIT L

**SEISMICITY AND TECTONIC STRUCTURE
IN NORTHEASTERN OHIO:
IMPLICATIONS FOR EARTHQUAKE HAZARD
TO THE PERRY NUCLEAR POWER PLANT**

A Report to the
Ohio Citizens for Responsible Energy, Inc.

Prepared by
YASH P. AGGARWAL
Sensearth, Inc.

March 1987

sens  ***earth inc.***
GEOPHYSICAL CONSULTANTS & ENGINEERS

17 TARRY HILL DRIVE, NEW CITY, N.Y. 10956 (914) 634-1980

**SEISMICITY AND TECTONIC STRUCTURE
IN NORTHEASTERN OHIO:
IMPLICATIONS FOR EARTHQUAKE HAZARD
TO THE PERRY NUCLEAR POWER PLANT**

YASH P. AGGARWAL

March, 1987

TABLE OF CONTENTS

Executive Summary	1
Introduction	3
The 1986 Earthquake	4
Aftershock Data Base	
Source Characteristics	
Mainshock Magnitude	
Structural Relationship	14
Historical Seismicity	
Correlations	
Implications	24
Recommendations	27
Notes and Acknowledgments	27
References	28

EXECUTIVE SUMMARY

At the request of the Ohio Citizens for Responsible Energy, we critically reviewed recent studies concerning the January 31, 1986 and other historically recorded earthquakes in northeastern Ohio having a bearing on the design basis for the Perry Nuclear Power Plant. This report discusses the results of this effort, shedding new light into the source of the January 31, 1986 earthquake and the probable relationship of this (magnitude 5.0 mb) and several other small to moderate size earthquakes to tectonic structure in northeastern Ohio.

Hypocentral locations and focal mechanism solutions for the larger aftershocks of the January 31, 1986 event define a near vertical, strike-slip fault trending approximately N30°E; a result consistent with the focal mechanism solution for the mainshock. The rupture area associated with the 1986 event is inferred to be about 2 to 4 km², centered at a depth of about 6 km.

Apparently, surficial geologic data do not reveal the trace of such a fault in the epicentral area of the 1986 earthquake. Nevertheless, magnetic anomaly data for northeastern Ohio show a prominent magnetic boundary (Akron Magnetic Boundary), the location and the general trend of which agree remarkably well with the fault inferred from earthquake data.

Furthermore, we observe that the better located (epicentral uncertainty ≤ 10 miles) "macroearthquakes" of MM intensity $\geq IV$, known to have occurred historically within 50 miles of the 1986 event, show a non-random distribution falling on or close to the Akron Magnetic Boundary.

These correlations strongly suggest that the Akron Magnetic Boundary in northeastern Ohio marks the locus of a pre-existing fault or fault zone. The spatial extent of the correlated epicenters indicates that the active portion of this fault zone is at least 70 km in length and probably about 10 km in width down dip. Consequently, in our opinion, this fault must be considered capable of generating an earthquake much larger than the magnitude 5.0 earthquake of January 31, 1986.

Theoretically, the inferred fault area available for rupture is large enough to accommodate a magnitude 7 or even larger earthquake. Conservatively, however, the occurrence of a magnitude 6.5 earthquake is in our opinion a realistic possibility for the purposes of determining a design basis earthquake for the Perry Nuclear Power Plant (PNPP).

Clearly, in light of these new findings, the design earthquake of MM intensity VII or mb 5.3 ± 0.5 adopted for PNPP on the basis of previous studies does not provide the margin of safety required for nuclear power plants. Unfortunately, this view is further strengthened by an indication in the data that the inferred fault (zone) probably passes within a few miles of the power-plant site; which potentially places PNPP within the near field of a strong earthquake generated by this fault.

INTRODUCTION

On January 31, 1986 an earthquake of magnitude 5.0 (NEIS) occurred in northeastern Ohio, about 18 km south of the Perry Nuclear Power Plant. This was the largest earthquake known to have occurred in the northeast Ohio region during historical times. The earthquake was widely felt, causing panic, minor injuries, and some damage approaching intensity VII on the Modified Mercalli (MM) Intensity scale (U.S. Geological Survey, 1986). Both the U.S. Geological Survey (USGS) and Weston Geophysical Corporation (WGC), who conducted intensity surveys, assigned an epicentral MM intensity VI to the shock.

A rapid deployment of portable seismographs by several institutions or agencies resulted in the acquisition of data for 13 aftershocks ranging in magnitude from -0.5 to 2.5, of which two were felt (see e.g. USGS, 1986). After a compilation of the data acquired by the participating institutions, the U.S. Geological Survey and Weston Geophysical Corporation independently determined source parameters for the aftershocks, including hypocentral locations and focal mechanism solutions. The results were published in two separate reports (USGS, 1986; WGC, 1986), that also discussed historical seismicity and attempted to tackle, among other issues, the significance of the 1986 shock and its relationship to tectonic structure.

Based on the mainshock—aftershock data, the U.S. Geological Survey did not reach any definitive conclusions as to the orientation of the fault responsible for the 1986 event; whereas Weston Geophysical Corporation concluded that the earthquake occurred on a near vertical, strike-slip fault trending NNE. The two studies, however, concurred that there was no obvious tectonic structure with which the 1986 event could be reasonably correlated. The USGS report, nevertheless, recommended additional geophysical investigations to understand the structural and tectonic conditions that led to the 1986 earthquake.

The licensing basis for PNPP was established prior to the occurrence of the 1986 shock, placing PNPP within the Central Stable Province with a design earthquake of MM intensity VII or mb 5.3 ± 0.5 (see e.g., WGC, 1986). Concerned about the implications of the 1986 event on the level of seismic hazard for PNPP, the Ohio Citizens for Responsible Energy (OCRE) sought our professional opinion and made available to us the reports cited earlier along with some additional material.

Reviewing these reports, certain observations that had apparently been overlooked or missed began to emerge, which prompted us to thoroughly reappraise the data contained therein hoping to clarify some of the issues raised by the occurrence of the 1986 event. First, we realized the need to separate the data from the "noise" (so to speak) that may have needlessly masked or rendered ambiguous an otherwise clear result. Consequently, we consistently sought to extricate, for example, from the available seismicity data the more valuable events using such objective criteria as earthquake size and location uncertainty, and relied primarily on such data in reaching conclusions. Secondly, we derived new composite focal mechanism solutions for the aftershocks of the 1986 event based on the P-wave first motion data reported in these studies. We did not, however, seek or attempt to reanalyze the primary source (e.g. seismograms, intensity reports) of the data contained therein. The results that follow are almost entirely based on the data compiled or obtained by previous workers. Primarily, our contribution is some important new observations and conclusions based thereupon.

First, we discuss the results of the 1986 mainshock-aftershock sequence of events, clarifying the nature of the source of the mainshock. Later, we discuss the correlation of the 1986 shock and the larger historical earthquakes to tectonic structure in the area, and its implications for earthquake hazard to PNPP.

THE 1986 EARTHQUAKE

Aftershock Data Base

As of April 15, 1986, thirteen aftershocks were recorded by a portable network of seismographs deployed by a number of institutions or agencies soon after the occurrence of the mainshock on January 31, 1986. The phase data compiled from the analysis of seismograms by the participating institutions, and the resulting source parameters for these aftershocks determined by the U.S. Geological Survey and Weston Geophysical Corporation (WGC) are tabulated in their respective reports (USGS, 1986; WGC, 1986).

An examination of the source data (e.g. Table 3, USGS, 1986) shows that the aftershocks can be separated into two distinct groups based on their size and displaying different temporal characteristics. First, we note that 7 of the 13 aftershocks had magnitudes ≥ 0.8 (0.8 to 2.4), whereas the remaining 6 were much smaller in size (magnitude -0.5 to 0.1), by almost 2 units of magnitude on the average. It is equally noteworthy that all but

one of the larger aftershocks occurred within the first 10 to 11 days following the mainshock, whereas all but one of the smaller aftershocks occurred much later in time, i.e. on or after the 23rd day following the mainshock. Furthermore, as expected, the phase data for the larger aftershocks are in general more abundant and reliable than for the smaller shocks, resulting in overall better determined hypocentral locations and focal mechanism solutions (see e.g., USGS, 1986).

The aftershock locations obtained by the USGS and WGC using various velocity models differ little, excepting the focal depth determination that shows some dependence on the velocity model chosen. For the purposes of this report, we chose to use the hypocentral locations preferred by the USGS and obtained using a velocity model that attempts to take into account the structural complexity of the area. Table 1 (this study) lists the preferred locations for the 7 larger aftershocks determined by the USGS. The events are numbered in chronological sequence in Table 1.

For these larger aftershocks we determined composite or individual focal mechanism solutions, combining events 1, 3, 4 and 7 (magnitude ≥ 1.3) into one group, events 5 and 6 (magnitude ≈ 1) into another, and event 2 (the smallest) all by itself. The P-wave first motions reported in the USGS and WGC studies were used for this purpose, excepting a small number of arrivals that were indicated as emergent. The inclusion of these less reliable data does not, however, affect the focal mechanism solutions.

Figure 1 shows the hypocentral locations of the 7 aftershocks. The events are numbered in chronological sequence, and a different symbol is used for each group of events for which a focal mechanism solution was determined. The focal mechanism solutions are shown in Figures 2, 3 and 4. The star in Figure 1a indicates the location (41.650°N , 81.162°W) of the mainshock obtained by the USGS, holding the focal depth fixed at 10 km.

Source Characteristics

Long-period surface-wave data indicate that the mainshock occurred at a shallow depth (2 to 6 km), either on a right-lateral strike-slip fault trending approximately $\text{N}28^{\circ}\text{E}$ and dipping steeply ($\approx 82^{\circ}$) to the west, or on a left-lateral strike-slip fault trending $\text{N}115^{\circ}\text{E}$ and dipping about 70° to the south (Hermann and Nguyen, 1986).

The epicentral distribution of the aftershocks (Figure 1a) shows a rather clear north-northeasterly alignment, in agreement with the orientation of one of the nodal planes determined by Hermann and Nguyen (1986) for the mainshock. Also, in each of the three

Table I

**Larger Aftershocks of 1986 Earthquake
(USGS, 1986)**

Event No.	Date Mo-Day	Latitude Deg Min	Longitude Deg Min	Depth km	ERH km	ERZ km	Mag.
1	02-01	41N38.82	81W9.42	4.97	0.45	0.80	1.4
2	02-02	41N38.75	81W9.53	4.99	0.25	0.23	0.8
3	02-03	41N38.90	81W9.61	6.93	0.26	0.36	1.8
4	02-06	41N38.57	81W9.64	5.89	0.28	0.41	2.4
5	02-07	41N39.06	81W9.25	4.64	0.29	0.22	1.7
6	02-10	41N39.16	81W9.27	4.97	0.29	0.42	0.9
7	03-24	41N38.05	81W9.97	4.92	0.45	0.40	1.3




Fig. 1a — Epicentral locations (USGS, 1986) for the 1986 mainshock (star) and 7 largest aftershocks numbered in chronological sequence as in Table 1. For each group of aftershocks denoted by a common symbol, a focal mechanism solution was determined (Figs. 2, 3, and 4). The strike (N30°E) of one of the nodal planes in Fig. 2 is shown.




Fig. 1b — Vertical cross-section showing the focal depth distribution of the aftershocks on a plane perpendicular to N30°E, the trend observed in (a). Note that the earthquake foci show a near-vertical distribution consistent with the dip of the N30°E striking nodal plane in Fig. 2.




Fig. 1c — Vertical cross-section showing the focal depth distribution of aftershocks on a plane striking N30°E, parallel to the trend observed in (a). Note that the focal depth (2 to 6 km) of the mainshock (not plotted) is consistent with the depth distribution of the aftershocks.


focal mechanism solutions for the aftershocks (Figures 2, 3 and 4) one of the nodal planes trends NNE (N15°E to N32°E), although its dip varies considerably.

It is remarkable that the composite focal mechanism solution (Figure 2) for the four largest aftershocks (squares, Figure 1) is almost identical to the focal mechanism solution for the mainshock. Both the strike and the dip of the NNE trending plane in Figure 2 are in excellent agreement with that determined by Hermann and Nguyen (1986) for the mainshock using surface-wave data. The composite focal mechanism solution (Figure 3) for the next two largest aftershocks (events 5 and 6, Figure 1) is also essentially similar to that of the mainshock. Only the smallest (event 2, Figure 1) of the 7 aftershocks apparently shows a substantially different focal mechanism solution (Figure 4). Note, however, that in this case also one of the nodal planes trends NNE.

Figures 1b and 1c show the focal depths of the aftershocks projected on vertical planes orthogonal and parallel to N30°E, the strike of one of the nodal planes in Figure 2. The orthogonal projection (Figure 1b) shows a near-vertical distribution, in excellent agreement with the dip of the NNE striking nodal plane in Figure 2, the focal mechanism solution closest to that of the mainshock. The parallel projection (Figure 1c), in contrast, shows a rather random distribution.

The above results leave little doubt that the mainshock occurred on a near-vertical fault trending NNE. The sense of motion is deduced to be right-lateral strike slip. The rupture area associated with the mainshock is inferred from the in-plane projection (Figure 1c) to be about 2 to 4 km², depending on whether one chooses to exclude or include event number 7 that appears to be somewhat isolated from the rest of the aftershocks. In either case we conclude that the fault (as opposed to the rupture zone) responsible for the 1986 event is at least 2 km long, as indicated by the epicentral distribution of the aftershocks (Figure 1a) having similar focal mechanism solutions (Figures 2 and 3).

The observation that event number 2 apparently shows a thrust mechanism (Figure 4), in contrast to the strike-slip mechanisms for the other aftershocks (Figures 2 and 3), is not surprising. Its location (Figure 1), and the fact that one of the nodal planes trends NNE (Figure 4), suggest that this event probably also occurred on the same fault as the other aftershocks. A fault plane is not expected to be a smooth surface, and such small events are likely to occur on slight "bumps" on the fault surface where stresses may concentrate after a sizeable earthquake. More importantly, however, the focal mechanism solution for the mainshock as well as its aftershocks indicate that these events occurred in response to a stress system in which the maximum principal stress axis is nearly horizontal and oriented ENE.



**FOCAL MECHANISM, EVENTS 1, 3, 4, 7
LOWER HEMISPHERE PLOT**


● - COMPRESSION

○ - DILATATION

P-AXIS, N66°E

T-AXIS, N167°E

Fig. 2 — Composite focal mechanism solution for the four largest aftershocks of the 1986 event. The event numbers correspond to those in Fig. 1 and Table 1. The strike and the dip of the nodal plane inferred to be the fault plane are indicated. P and T respectively denote the Pressure and Tension axes.




**FOCAL MECHANISM, EVENTS 5,6
LOWER HEMISPHERE PLOT**

● - COMPRESSION
○ - DILATATION

P - AXIS, N52°E
T - AXIS, N148°E

Fig. 3 — Composite focal mechanism solution for events 5 and 6 (Fig. 1, Table 1), aftershocks of the 1986 event. Symbols as in Fig. 2.



**FOCAL MECHANISM, EVENT 2
LOWER HEMISPHERE PLOT**

○-COMPRESSION P-AXIS, N97°E
○-DILATATION

Fig. 4 — Focal mechanism solution for event 2 (Fig. 1, Table 1), the smallest of the 7 largest after-shocks of the 1986 earthquake. The solution is not well constrained. Symbols as in Fig. 2.

Mainshock Magnitude

The National Earthquake Information Service (NEIS) calculated the magnitude (mb) for the 1986 event using teleseismic P-wave arrivals at 16 stations. The individual mb values range from 4.1 to 5.9, yielding an average value of 5.0 (5.03) for the 16 readings. Initially, NEIS had assigned a preliminary mb value of 4.9 based on readings from 10 stations.

The Earth Physics Branch (EPB) of Energy, Mines and Resources Canada obtained mbLg values for 24 stations in the Canadian Network. These data are tabulated (Appendix A3.2) in the WCC report (1986). Figure 5 shows the mbLg (Mn) obtained from the Canadian Network as a function of station azimuth. A remarkably clear dependence of mbLg on azimuth emerges from this plot. The peak near N30°E is rather well defined and is in excellent agreement with the focal mechanism solution of the mainshock, from which one would expect maximum amplitudes for Lg waves at stations located along the strike (NNE) of the fault plane responsible for the 1986 event.

The individual values for mbLg range from 4.9 to 5.7, and the average value is 5.3 (5.28). The difference between the mb magnitude (5.0) and the mbLg magnitude (5.3) is not surprising in light of the azimuthal dependence of mbLg observed here. The higher mbLg magnitude is attributed to the fact that almost a half of the Canadian stations reporting mbLg values lie within about 20° of the strike of the fault plane responsible for the 1986 event (Figure 5), thus resulting in near maximum amplitudes for Lg waves recorded at these stations.

STRUCTURAL RELATIONSHIP

Historical Seismicity

Apart from the 1986 sequence of events, some 25 earthquakes, apparently located within approximately 50 miles of PNPP, have occurred in the northeast Ohio region since 1823 (Table 3-2, WCC, 1986). Most of these events are, poorly located and as such are of little use in understanding the relationship of seismicity to tectonic structure in the area. Among the larger (MM intensity \geq IV, or magnitude \geq 3) events, however, there are several that are relatively well located (uncertainty \leq 10 miles) according to the data compiled by Weston Geophysical (1979, 1986). The epicentral locations of these events along with that of the 1986 mainshock are shown in Figure 6. We discuss these events briefly in their chronological sequence going backward in time.




Fig. 5 — Plot showing magnitude (mLg or Mn) determinations for the 1986 mainshock as a function of station azimuth for the Canadian Network obtained by the Earth Physics Branch. The curve shows an approximate fit to the data. The arrow indicates the strike (N30°E) of the fault plane inferred for the 1986 event; note the peak at or near this azimuth.

The 1983 event that occurred on January 22 was recently relocated by Weston Geophysical using instrumental data in addition to those used initially by NEIS and ISC (International Seismological Centre) or EPB. The epicenter was relocated at 41.765°N, 81.110°W with an estimated uncertainty of about 3 km (WGC, 1986). This event was not felt. NEIS assigned a magnitude 2.7 mbLg to this event, whereas EPB (Ottawa) obtained a value of 3.3. In each case, the magnitude is based on readings from only a few stations. Hence, in our opinion, an average of the two determinations (3.0) is a better measure of the magnitude of this event than any one of the two values.

The 1943 event was recently relocated by J. Dewey (USGS, 1986) using instrumental data. Its revised location (41.628°N ± 14 km, 81.309°W ± 10 km) is essentially similar to that (41.6°N, 81.3°W) listed by Coffman and von Hake (1973). This event was widely felt and Weston Geophysical assigned an MM intensity V to it. Its instrumentally determined magnitude of 4.7 mbLg is identical to that estimated from the felt area (see, WGC, 1979).

Two events occurred in 1955, one on May 26 and another on June 29. Both of these events were relocated at 41.33°N, 81.40°W by Weston Geophysical on the basis of the distribution of felt reports compiled and analyzed by WGC (1979). Seismograms for these events from John Carroll University station (Fig. 6), however, provide instrumental control on the epicentral locations. Weston Geophysical (1979) noted that the locations are in good agreement with the epicentral distance (≈ 20 km) and azimuth (southeast of John Carroll) estimated by Dr. E. Walter from seismograms (see also Fig.6). This agreement suggests that the epicentral uncertainties are probably (≈ 10 km) somewhat less than those (10 miles) assigned by Weston Geophysical on the basis of intensity data alone. Weston Geophysical (1979, 1986) assigned an MM intensity IV-V to the May 26 event and intensity IV to the June 29 shock, and lists a magnitude (mbLg) 3.6 for both events. A check of the short-period seismograms at the Lamont-Doherty Geological Observatory revealed that both shocks were recorded at Palisades, N.Y.; which suggests that perhaps some other stations in North America may also have recorded this event. We did not, however, make an effort to obtain any such data.

The Dec. 3, 1951 (MM intensity IV, mbLg 3.2) was located (41.60°N, 81.40°W) by Weston Geophysical (1979, 1986) on the basis of felt reports, with an estimated uncertainty of 5 miles. The event was felt in an area less than 10 miles in radius around Willoughby, and was recorded on a 3-component short-period station operated by John Carroll Universi-

ty (WGC 1979). The seismograms indicate an epicentral distance of about 30 km (WGC, 1979), whereas the epicentral distance from the WGC location is only about 15 km (See Figure 6). This discrepancy, combined with the observation that the shock was apparently not felt at Painesville or in Cleveland (Figure 6), suggests that the epicenter should be approximately 15 to 20 km ESE of the WGC location or possibly to the NW of Willoughby in Lake Erie. Consequently, in our judgement the WGC location is in error or uncertain by 10 miles or more.

In view of the fact that for events occurring relatively close to Lake Erie soil amplification effects and population density distribution would tend to bias (towards the lake) epicentral locations based solely on felt reports, it is not surprising that the WGC location for the 1951 event is not in accord with the instrumental data. In contrast, it is noteworthy that the WGC locations for the 1955 events discussed earlier are in good agreement with instrumental data; which suggests that for events occurring relatively far from Lake Erie their locations are not significantly affected by soil amplification or population concentration along Lake Erie's south shore.

Lastly, two events occurred near Akron about 85 km SSW of PNPP (Figure 6). The 1932 event (MM intensity IV) that occurred on Jan 21 was felt only on the west shore of Lake Summit situated within the city limits of Akron (WGC, 1979). Accordingly, Weston Geophysical assigned to its epicenter the coordinates (41.08°N, 81.50°W) of the lake as determined by Docekal (see WGC, 1979), and later adopted the epicenter (41.10°N, 81.60°W) obtained by EPB (see Table 3-2, WGC, 1986). The two locations are similar, and the relatively small difference appears to be due to rounding off errors in the coordinates (41.06°N, 81.55°W) of the lake. Weston Geophysical (1979) did not assign an epicentral uncertainty to this event. Judging from the observation that the event was apparently felt in a rather localized area within an urban environment, it is our opinion that the uncertainty in the epicentral location (41.06°N, 81.55°W) is probably 10 km or less.

Weston Geophysical lists another earthquake on Jan. 22, 1932 (magnitude 3.6) at essentially the same location (41.10°N, 81.50°W) as that on Jan. 21, 1932 referring to Nuttli as the source (see Table 3-2, WGC, 1986), but does not mention this event in its 1979 report. It is not clear whether the two events are one and the same earthquake with a possible error in the date in one of the catalogs, or two separate events one of which might have been initially missed by WGC in its 1979 catalog. In Figure 6, however, we have plotted




Fig. 6 — Map of Northeastern Ohio showing the epicenters [WGC, 1979, 1986; USGS, 1986] of local earthquakes (within 50 miles of PNPP) of MM intensity \geq IV or mag \geq 3, located with an uncertainty \leq 10 miles excepting the 1951 event (see text). Note the rather clear NNE trend in epicenters.

only one event using the coordinates of Summit Lake as its epicenter, and have assigned to it an uncertainty of 10 km.

The other event near Akron (Figure 6) occurred on January 18, 1885. This event (MM intensity IV) was relocated by Weston Geophysical (1979) on the basis of the distribution of felt reports. The WGC location (41.10°N, 81.45°W) is similar to that (41.10°N, 81.40°W) listed in the EPRI catalog with an epicentral intensity MM IV and magnitude 3.8 (see Table 3-1, WGC, 1986). The epicentral uncertainty of ± 10 miles estimated by Weston Geophysical appears to be adequate, although the distributions of felt reports suggests that the epicenter should be somewhat to the west or NW of the WGC epicenter plotted in Fig. 6 (see WGC, 1979).

All of the "local" earthquakes discussed above occurred during the past 100 years (1885-1986). During this time period there were possibly two additional local shocks (Sept. 29, 1928; Oct. 29, 1934) of MM intensity \geq IV, both of which are not used in this study. Not only is the location of the 1928 event poorly known, but also its nature (earthquake?) remains a mystery (WGC, 1979). The 1934 earthquake (MM V) was located (42.0°N, 80.2°W) by WGC (1979) at or near Erie, Pennsylvania, on the basis of felt reports from Erie obtained from newspapers in northeastern Ohio. The uncertainty in the location of this event is, however, unknown or difficult to estimate in the absence of felt reports from sources in Pennsylvania. Similarly, the locations of four much older (1836, 1850, 1857, and 1858) local earthquakes of MM \geq IV are in general poorly constrained (see WGC, 1979), and hence these events are also not used here.

Correlations

The epicentral distribution of earthquakes in Figure 6 shows a rather strong NNE trend or alignment. Clearly, the uncertainties in individual locations (≤ 16 km except for the 1951 event) discussed earlier are much smaller than the lateral extent (about 80 km) of the epicenters defining a NNE trend. Secondly, the distribution of population in northeastern Ohio does not exhibit a particular pattern that could reasonably be correlated with the trend observed in earthquake epicenters. Also, note that all but one (1951) of the events are either instrumentally located (1943, 1983, 1986) or occurred relatively far from Lake Erie (1885, 1932, and 2 in 1955). Consequently, biases resulting from soil amplification effects or population density along the lake shore cannot be invoked to either assign larger uncertainties to the locations or explain the trend in the epicentral

locations. Furthermore, these events are among the largest earthquakes known to have occurred in northeastern Ohio. We conclude that the NNE trend observed in the epicentral locations is not simply fortuitous, but represents an important if not a fundamental characteristic of the seismicity in this region.

In Figure 7 the epicenters of the better located events (uncertainty ≤ 16 km) are superimposed on a magnetic anomaly map of northeastern Ohio region compiled by Hildenbrand and Kucks (1984). Note that the 1951 event (Figure 6) which is less well located, as discussed earlier, is not plotted in Figure 7. The shaded area indicates the approximate location and the general trend of the northeastern Ohio section of a prominent magnetic boundary (Akron Magnetic Boundary) that separates an area of relatively smooth magnetic anomalies to the east from the region of rapidly varying magnetic anomalies to the west.

In Figure 7 we observe that the NNE trend in earthquake epicenters corresponds rather well with the general trend (NNE) of the magnetic boundary. Also, we note that the earthquake epicenters are located on or close to the magnetic boundary, and within the uncertainties of the data the earthquake epicenters correlate well with the location of the boundary.

This correlation is particularly clear where the data are the most precise. For example, in the case of the 1986 event the strike ($\approx N30^\circ E$) of its fault plane, inferred earlier from seismological data, is almost identical to the trend of the Akron Magnetic Boundary just south of the epicenter where the boundary trend is particularly well defined (Figure 7). Also, the epicenter of this event having a probable uncertainty of only about 1 km (WGC, 1986, also Figure 1a) is essentially located on the magnetic boundary (within the uncertainties inherent in the demarcation of the boundary). We note that the correlation of the 1986 event with this magnetic boundary was also observed by Seeber (1986).

The next best located event is perhaps the 1983 (January 22) earthquake that was recently relocated by Weston Geophysical (1986) with an uncertainty of about 3 km using instrumental data. Figure 8 shows the location of this event in relation to that of the 1986 shock. The box denotes the epicenter of the 1983 event obtained by Weston Geophysical (1986) by averaging the various epicenters (crosses) computed with different velocity models and/or different weighting schemes. Figure 8 shows that the epicenter of the 1983 shock is located essentially on strike of the fault plane for the 1986 event some 13 km north of the later. Unfortunately, the P-wave first motions for the 1983 earthquake recorded at several stations (see seismograms, WGC, 1986) are not clear




Fig. 7 — Residual total magnetic map of northeastern Ohio region (Hildenbrand and Kucks, 1984). Epicenters (WGC, 1979, 1986; USCS, 1986) of the better located (uncertainty ≤ 16 km) local earthquakes (within 50 miles of PNPP) of MM intensity \geq IV or mag ≥ 3 are superimposed on the magnetic map. The strike of the fault plane and the sense of motion on it for the 1986 shock are shown. The shaded area shows the approximate location of the magnetic boundary observed in the data. Note that the epicenters are located on or close to this boundary




Fig. 8 — Map showing the location of the January 22, 1983 event (WCC, 1986) in relation to that of the 1986 earthquake and its focal mechanism. Crosses indicate individual locations of the 1983 event obtained using different velocity models and/or weighting schemes, and the box indicates the average of these solutions with its uncertainty (bars) adopted by Weston as the epicenter of the 1983 event. Note that the 1983 event lies essentially on strike (broken line) of the 1986 fault plane.

enough to determine whether or not the first motions are consistent with the right-lateral strike-slip motion determined for the 1986 event.

It is also noteworthy that the epicenters of the two earthquakes in 1955, although less well constrained (± 10 km), are apparently located on the magnetic boundary. Since these events were recorded by the John Carroll station, the epicentral distances (≈ 20 km for both events) from this station provide constraints on the locations of these events in the NW-SE direction (see Figure 6). As discussed earlier the locations of the 1955 events are in good agreement with the instrumental data. This constraint and the distribution of the intensity data (WGC, 1979) indicate that the uncertainty is largely in the NE-SW direction or basically along the magnetic boundary; which strengthens the correlation of these events with the magnetic boundary.

The three older events (1885, 1932 and 1943) are located sufficiently close to the magnetic boundary with uncertainties acceptably small as to render their correlation with the magnetic boundary reasonably credible (Figure 7). The 1943 event (mbLg 4.7) is the second largest earthquake known to have occurred in this region, and its instrumentally determined location is close to that of the 1986 event (Figure 7). The 1932 event was felt only on the west shore of Lake Summit (discussed earlier) located near the western edge of Akron, the city that lent its name to the magnetic boundary. Lastly, the distribution of the intensity data for the 1885 event (see WGC, 1979) suggests, as discussed earlier, that this event probably occurred somewhat to the west or northwest of the WGC epicenter shown in Figure 7, which would place it even closer to the magnetic boundary.

The above observations strongly suggest a causal relationship between seismicity and the Akron Magnetic Boundary in northeastern Ohio, indicating that the magnetic boundary marks the locus of a pre-existing fault or fault zone. Surficial geologic data apparently do not show the trace of such a fault, and its presence at depth is probably masked by the sedimentary cover. The magnetic data, in contrast, reflect changes in the basement rocks aiding in the understanding of the structure of the upper crust. In this context, it is noteworthy that the well constrained hypocentral locations of the aftershocks of the 1986 event are located at depths of 5 to 7 km (Figure 1); implying that the events occurred in the brittle zone beneath the sedimentary cover.

The lateral (ENE) extent of the magnetic boundary (Figure 7) suggests that the active portion of this fault (zone) is at least about 100 km long. Judging from the focal mechanism solu-

tions for the 1986 event and its aftershocks it appears that this fault is predominantly a right-lateral strike-slip fault, and probably has a down-dip width of 10-15 km as is generally the case for major strike-slip faults.

IMPLICATIONS

The preceding results raise important safety issues and concerns regarding the level of earthquake hazard to which PNPP might be exposed. The design basis or the safe-shutdown earthquake (SSE) for PNPP was established prior to the 1986 event on the basis of the tectonic province approach detailed in Appendix A, 10 CFR 100 of the Nuclear Regulatory Commission. This approach is used in the absence of "capable faults", and/or where locations of historically reported earthquakes of highest intensity cannot be reasonably correlated with tectonic structures. In our opinion the results of this study demonstrate with reasonable certainty i) that a major active fault or fault zone exists in the proximity of PNPP, and ii) that an SSE of MM intensity VII or mb about 5.3 adopted for PNPP does not provide the margin of safety required for nuclear power plants.

It is clear that the SSE for PNPP is only marginally larger than the 1986 event, bearing in mind that the intensity of the latter approached VII, albeit in a few places. More importantly, however, Appendix A mandates that *in the event seismological and geological data warrant, the SSE shall be larger than that derived by use of the procedures set forth in section IV and V of the appendix* (see paragraph IV, section V). These procedures include the tectonic province approach. Hence, notwithstanding the issue of whether or not the fault zone identified here on the basis of seismological and magnetic data is a "capable fault" as defined in Appendix A, it is clear that the results of this study warrant an SSE substantially larger than that adopted for PNPP regardless of the approach used.

The rupture area associated with the 1986 event (mb 5.0) was inferred to be about 2 to 4 km². In contrast, the estimated fault area ($\approx 70 \times 10$ km²) potentially available for rupture is more than 2 orders of magnitude larger than that associated with the 1986 event. Theoretically, the available fault area is sufficient to accommodate a magnitude 7 or

ever, larger earthquake. Conservatively, however, the occurrence of a magnitude 6.5 earthquake must be considered a realistic possibility for the purposes of determining an SSE for PNPP. Furthermore, Figure 7 suggests that the fault zone extends NNE of the 1986 event passing close to PNPP, which potentially places PNPP within the near field of a strong earthquake generated by this fault. The likelihood of occurrence of such an earthquake is, however difficult to quantify, and any efforts to do the same would be meaningless in light of the shortness of the historical record of earthquakes and the absence of geological data extending the record backward in time.

As to whether the fault zone identified here is a "capable fault" within the context and meaning of Appendix A, we are of the opinion that the evidence favors such a designation. According to Appendix A if *macro-seismicity instrumentally determined with records of sufficient precision demonstrates a direct relationship with a fault*, then that fault must be considered to be a capable fault. First, the events used in our correlation (Figure 7) range in magnitude from about 3.0 to 5.0, and hence constitute macro-seismicity. Secondly, the locations of the 1986, 1983 and 1943 earthquakes are instrumentally determined and those of the two 1955 events are partially constrained by instrumental data. As to whether these locations are determined with "sufficient precision to demonstrate a direct relationship", it is a matter of opinion, and we leave it to the reader to draw his or her own conclusions.

RECOMMENDATIONS

We recommend that the following confirmatory studies be undertaken to both verify the results of this study and seek geologic evidence (which might or might not be available) for the existence of the fault zone discerned here on the basis of the association of earthquakes with the Akron Magnetic Boundary.

- i) The magnetic data for northeastern Ohio should be reexamined in an effort to define the magnetic boundary as accurately as possible. In particular, the trend and the extension of this boundary north of the 1986 event should be defined (if possible) more accurately than at present.

- ii) Using the magnetic data as a reference, the structural geology along this boundary should be studied carefully not only in the epicentral area of the 1986 event but also elsewhere. Sites that might be suitable for this purpose are rivers, streams and lakes that apparently follow the boundary. Some examples are: Bass Lake and the river associated with it just SW of Chardon, the river and lakes or ponds between the towns of Geauga Lake and Burg just NW of Aurora, and a NNE trending river (we do not know the name) about 5 km west of Akron.
- iii) Several high resolution seismic reflection profiles should be conducted across the magnetic boundary. It appears that the inferred fault zone is essentially vertical and its possible that vertical displacements may have occurred on it during its geologic history. Such vertical displacements, if substantial, should be discernable on the seismic profiles. Tentatively we recommend four such profiles: NW of Akron, near Aurora, near the epicenter of the 1986 event, and near Madison east of PNPP.
- iv) We also recommend that an attempt be made to further reduce uncertainties in the locations of earthquakes that occurred prior to 1980.
 - The 1943 event should be relocated using the 1986 earthquake as a master event. The inclusion of data from John Carroll station would be useful for this purpose.
 - The available seismograms for the 1955 events should be procured and analyzed, and the events should be relocated using both the instrumental and intensity data.
 - The felt reports for the older historical earthquakes of $MM \geq IV$ should be reanalyzed and where possible additional data procured. The relocations should be obtained using computer based programs, and uncertainties should be ascertained taking into account the population distribution prevailing close to the time of the occurrence of the event.

Lastly, this study clearly reiterates the desirability and need of seeking a spectrum of professional opinions, especially from those investigators not party to the issues involved. Bearing this in mind, we strongly recommend that the unprocessed data resulting from any confirmatory investigations be made available to disinterested investigators and that funds be provided by governmental agencies to such investigators to facilitate the analyses and interpretation of the data.

NOTES AND ACKNOWLEDGEMENTS

We did not address the issue of whether or not the 1986 and 1983 events were triggered by injection of fluids at Calhio wells because of lack of sufficient funds. It is our opinion, however, that in order to clarify this issue and understand any spatio-temporal relationships of these earthquake to fluid injection, one must take into account the location of the fault zone identified here and its possible influence on fluid flow.

This study was partially funded by the Ohio Citizens For Responsible Energy. The author contributed a substantial portion of his time to this study. We thank AQ Graphics Inc. for donating their valuable graphic services used in preparing this report.

REFERENCES

- Coffman, J.L., and von Hake, C.A.**, Earthquake History of the United States, PUB. No. 41-1, U.S. Dept. of Commerce/N.O.A.A., Boulder, CO., 1973.
- Hermann, R.B., and Nguyen, B.V.**, Focal Mechanism Studies of the January 31, 1986 Perry, Ohio, Earthquake, Abstracts, Seis. Soc. Am., East. Section, page 32, 1986.
- Hildenbrand, T.G., and Kucks, R.P.**, Residual Total Intensity Map of Ohio, Map GP-961, U.S. Geol. Survey, Reston, VA., 1984.
- Seeber, L.**, The January 31, 1986 Earthquake near Chardon, Ohio and its significance for the Perry Nuclear Power Plant and for Earthquake Hazard in the Eastern U.S., Testimony before subcommittee on Energy and Environment, U.S. House of Rep., Washington, D.C., April 18, 1986.
- U.S. Geological Survey**, Studies of the January 31, 1986 Northeastern Ohio Earthquake, Wesson, R.L., and C. Nicholson Editors, USGS Open File Report, 86-336, 1986.
- Weston Geophysical Corporation (WGC)**, Evaluation of Local Seismicity around the Perry Nuclear Power Plant Site, Appendix D, FSAR, prepared for Cleveland Electric Illuminating Co., 1979.
- Weston Geophysical Corporation**, Investigations of Confirmatory Seismological and Geological Issues, Northeastern Ohio Earthquake of January 31, 1986, prepared for Cleveland Electric Illuminating Co., June 1986.

APPENDIX B

SEISMIC CAPABILITY OF THE 8x8 FUEL SPACER

General Electric's 1975 Nuclear Reactor Study, known as the Reed Report, identifies the fuel as having the smallest seismic margin in the BWR/6. See attached page 39 of the Nuclear Systems Task Final Report. The fuel spacer is required to withstand an acceleration of 0.3 g. Doubt is expressed by GE as to whether the BWR/6 design would meet seismic design requirements in excess of 0.3 g. In NUREG-1285, "NRC Staff Evaluation of the General Electric Company Nuclear Reactor Study ("Reed Report")", it is stated that fuel spacer failure could result in loss of core coolability during a loss of coolant accident (LOCA) (p. 22). That GE's standard plant design, GESSAR II, has as its maximum site SSE an acceleration of 0.3 g is indicative of this continuing seismic limitation in the BWR/6 design. (NUREG-0979, p. 15-2)

To illustrate that a near-field magnitude 6.5 earthquake would likely result in accelerations greater than 0.3 g, OCRE used the same correlations relied upon by the licensees in the FSAR. Represented graphically in FSAR Figure 2.5-74 (attached) are the relationships between acceleration and Modified Mercalli intensity developed by Trifunac and Brady (Reference 2 in FSAR Section 2.5), Gutenberg and Richter (FSAR Reference 151) and Newman (FSAR Reference 218). To correlate magnitude with epicentral Modified Mercalli intensity a number of relationships were employed. These are listed in Table 1. The mean of the values of intensity calculated for an earthquake of $m_b = 6.5$ is 9.5. From FSAR Figure 2.5-74, a Modified Mercalli

intensity of 9.5 yields an acceleration of 500 cm/sec² for the relationship of Gutenberg and Richter, of 700 cm/sec² for that of Trifunac and Brady, and of 800 cm/sec² for that of Newman. Taking 1.0 g to be 980 cm/sec², these values translate to 0.51 g, 0.71 g, and 0.82 g.

REFERENCES

Bernreuter et al., NUREG/CR-3756, Seismic Hazard Characterization of the Eastern United States: Methodology and Interim Results for Ten Sites, 1984.

Campbell, K.W., NUREG/CR-3839, An Empirical Assessment of Near-Source Strong Ground Motion for a 6.6 mb (7.5 Ms) Earthquake in the Eastern United States, 1984.

General Electric Co. Nuclear Reactor Study ("Reed Report"), 1975

Gutenberg and Richter, Earthquake Magnitude, Intensity, Energy, and Acceleration, Bull. Seismol. Soc. Am., 32: 163-191, 1942.

Newman, Earthquake Intensity and Related Ground Motion, Univ. of Washington Press, Seattle, Washington, 1954.

NRC, NUREG-0979, Supplement 3, Safety Evaluation Report Related to the Final Design Approval of the GESSAR II BWR/6 Nuclear Island Design, 1985.

NRC, NUREG-1285, NRC Staff Evaluation of the General Electric Company Nuclear Reactor Study ("Reed Report"), 1987.

Street and Turcotte, A Study of Northeastern North American Spectral Moments, Magnitudes, and Intensities, Bull. Seismol. Soc. Am., 67: 599-614, 1977.

Trifunac and Brady, On the Correlation of Seismic Intensity Scales with the Peaks of Recorded Strong Ground Motion, Bull. Seismol. Soc. Am., 65: 139-162, 1975.

There are at least five major areas that have a direct bearing on the overall safety with regard to seismic design. These areas are: definition of seismic loads, mathematical models, analysis procedures, design criteria and assuring quality control during fabrication and construction. Statistical data is lacking on which to assess the accuracy of assumptions in these areas in any design. Therefore conservatism is appropriate.

BWRSD and BWRPD currently exercise parallel responsibilities in some areas of seismic design since BWRPD is responsible for the STRIDE design which is currently being developed through C. F. Braun. BWRSD has responsibility for the requisitions plants and most of the areas of responsibility regarding seismic design. However, within BWRSD these responsibilities are diffused since some are assigned to development, others to design engineering, with essential responsibility assigned to the responsible design engineer even though he may not be sufficiently cognizant of the "state of the art" design basis that is characteristic of seismic design.

The component of BWR/6 having the smallest seismic margin for the present method of RPV support is the fuel. The fuel-spacer-channel combination is required to meet the 0.3g ground acceleration seismic requirements. Since it has been difficult to design the spacer to meet seismic margin together with thermal and nuclear design requirements, there is question whether the BWR/6 design would meet seismic conditions for sites where the requirements are in excess of 0.3g. Because many models (mostly analytical) and not many tests have been used to establish this seismic design, future tests will be required to verify adequacy should it be discovered that one of the models exercised in the fuel performance trade-off study is inadequate. While the seismic analyses have concluded that the fuel-spacer-channel design is adequate for 0.3g, tests performed for 0.3g seismic conditions indicate some deformation which is not in accordance with the design criteria, therefore, the criteria, test conditions or the spacer design must change.

In many cases, seismic requirements are specified by GE for GE supplied equipment but the A/E has control over how (or if) the requirements are met.

The PWR design is inherently more seismic resistant because of lower reactor vessel placement and the need to design for larger LOCA loadings.

4.4.4 Radiological Contamination


Finding:


The uncovered suppression pool of Mark III causes Mark III to be more susceptible than previous designs to loss of availability due to present occupational dose limits and a fortiori to more stringent regulations which are anticipated. Mark I and Mark II designs may also be affected by increased difficulty in performing required maintenance and backfit if required.

TABLE 1

Relationship	Reference	I_o for $mb=mbLg=6.5$
$mbLg = 0.49I_o + 1.66$ or $I_o = 2.04 mbLg - 3.39$	Eq. 3, p. 605 of Street & Turcotte	9.87
$I_o = 2.07 mb - 3.97$	Eq. 16a, p. 15 of NUREG/CR-3839	9.49
$I_o = 1.98 mb - 3.41$	Eq. 16b, p. 15 of NUREG/CR-3839	9.46
$I_o = 2 mb - 3.5$	Eq. 19, p. 18 of NUREG/CR-3839	9.5
$I_o = 2.16 mbLg - 4.4$	p. A-67 of NUREG/CR-3756	9.64
$mb = 0.44 + 0.67 I_o$ or $I_o = 1.49 mb - 0.657$	p. A-75 of NUREG/CR-3756	9.03

Mean $I_o = 9.5$




PERRY NUCLEAR POWER PLANT
 THE CLEVELAND ELECTRIC
 ILLUMINATING COMPANY

Intensity Acceleration Relationships

Figure 2.5-74



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

April 28, 1988

1321
Tim C -
up

Background

MEMORANDUM FOR: ~~Kenneth E. Perkins, Director~~
Project Directorate III-3
Division of Reactor Projects III/IV/V and
Special Projects

FROM: Goutam Bagchi, Chief
Structural and Geosciences Branch
Division of Engineering and Systems Technology

SUBJECT: OCRE 2.206 PETITION FOR IMMEDIATE ACTION TO RELIEVE UNDUE
RISK POSED BY THE INADEQUATE SEISMIC DESIGN OF THE PERRY
NUCLEAR POWER PLANT (TAC NO. 67131)

References: Petition by the Ohio Citizens for Responsible Energy, Inc.
(OCRE), dated January 22, 1988

In reply to your request for assistance on the subject matter, we have prepared a Safety Evaluation Report (attached) which addresses the assertions made in the above referenced petition regarding the adequacy of the Perry Nuclear Power Plant (PNPP) seismic design. We find that the arguments stated in the OCRE petition indicating the presence of a large capable fault which could generate a magnitude 6.5 or greater earthquake in the vicinity of the PNPP cannot be substantiated. Therefore, we find that the request for a suspension of the license in order to conduct additional geological and geophysical studies and engineering evaluations is unwarranted.

Goutam Bagchi, Chief
Structural and Geosciences Branch
Division of Engineering and Systems
Technology

Attachment: As stated

cc: L. Shao
J. Richardson
G. Holahan
T. Colburn
R. McMullen

8805030507
SPP

2.206 Petition On Perry Nuclear Power Plant Seismic Design
Safety Evaluation Report
Structural and Geosciences Branch

By a Petition submitted pursuant to 10CFR Section 2.206 and dated January 22, 1988, Ohio Citizens for Responsible Energy, Inc. (OCRE) requested that the Director of the Office of Nuclear Reactor Regulation suspend the Operating License (OL) and the Construction Permit (CP) for the Perry Nuclear Power Plants.

The petition alleged that:

1. The January 31, 1986 Chardon, Ohio earthquake and the historic seismicity near the Perry Nuclear Power Plants (PNPP) could be associated with a tectonic structure (fault), revealed by magnetic data.
2. The tectonic structure so identified is capable of a magnitude 6.5 or greater earthquake.
3. The present Safe Shutdown Earthquake (magnitude 5.3 ± 0.5) does not provide the margin of safety required.
4. The licensee, Cleveland Electric Illuminating Company (CEI) is therefore in violation of regulations promulgated under the Code of Federal Regulations 10 CFR 50, Appendix A, General Design Criterion 2 and 10 CFR 100 Appendix A, Parts IV, V, and VI.

The basis for these contentions is a report by Dr. Yash P. Aggarwal on behalf of the petitioners. In the report Dr. Aggarwal asserts that an earthquake of magnitude 6.5 or larger is probable on a feature which, at its closest approach, is approximately 10 km south east of the PNPP site. This feature is a "boundary" in the magnetic map of the Ohio which separates a region of relatively high magnetic relief to the northwest from a region of relatively low magnetic relief to the southeast. Weston Geophysical Corporation (WGC) identified this boundary as the "Akron Magnetic Boundary" (AMB), (Reference 1, Figure 4-2). OCRE requested that the OL and CP remain suspended until the licensee performs additional geological and geophysical studies to evaluate systems, structures and components important to safety given the increased seismic loading. This evaluation should include the 8X8 fuel spacer specifically mentioned in Appendix B of the above petition.

Dr. Aggarwal based his findings, to a large extent, on recent studies performed by Weston Geophysical Corporation (Reference 1) on behalf of CEI, by the U.S. Geological Survey (Reference 2) on behalf of the U.S. Nuclear Regulatory Commission (NRC); and on testimony before the U.S. House of Representative by Dr. L. Seeber (Reference 3).

Since the occurrence of the January 31, 1986 earthquake in the vicinity of the PNPP site, numerous investigations have taken place with the sole purpose of studying the 1986 earthquake, its aftershocks, the possible causative structure, and by inference the relationship with deep-well fluid injection.

The concerns enumerated above have been discussed extensively in supplements to the Perry Safety Evaluation Report (SER) (Reference 4). The conclusions arrived at by the NRC staff after reviewing all available pertinent information on the geological and geophysical characteristics of the northeastern Ohio region

was that no discernable geological structure(s) had been identified which could be associated with the January 31, 1986 earthquake and that the earthquake by itself was not uncharacteristic of the general earthquake history of the tectonic province (Central Stable Region) in which the PNPP is located. The staff still considers these conclusions to be valid.

Since the publication of the above supplemental SER's the utility (CEI) has continued monitoring of the seismic activity in the vicinity of the PNPP site. To date, five quarterly reports have been submitted to the NRC (References 5-9) for review. The cumulative activity recorded by the network (Reference 9, Figure 4) exhibits some microseismic activity in the corridor covered by the network. The epicentral locations of these very small tremors (with magnitude range - 0.7 to 1.3) form a small cluster, parallel to and slightly offset from the AMB. Our experience indicates that the occurrence of earthquakes of this size are typical of many locations within the eastern U.S. at different times and are only detectable when a highly sensitive seismic network is used such as that employed by CEI. These events by themselves do not indicate potential for large and possibly damaging earthquakes.

The NRC has received also a preliminary report (Reference 10) which discusses the July 13, 1987 Ashtabula, Ohio earthquake and its aftershock sequence. In addition to the discussions on the 1987 Ashtabula events the preliminary report (Reference 10) mentions also the January 31, 1986 Chardon, Ohio earthquake. The authors, including Dr. Seeber who originally proposed it, (Reference 3) recognize, as Dr. Aggarwal did, the association of this event with the NNE trending AMB and assert that the correlation indicates that the magnetic feature could be an expression of a (reactivated) fault of considerable length on which earthquakes much larger than the 1986 event could occur. However, it should be pointed out that the authors themselves state that because of the lack of any evidence of the extension of this postulated fault into the paleozoic platform cover (upper 2km of rock strata) very large ruptures involving much of the fault are unlikely.

Dr. Aggarwal argues that the main shock and aftershock focal mechanisms indicate a fault approximately N30°E colinear with the AMB. While a general NNE trend of the main shock and aftershock focal mechanisms appears to be inferred, the uncertainty associated with Dr. Aggarwal's preferred orientation is larger than he indicates. For example the most recent study of the 1986 earthquake (Reference 11) indicates that the northeast trending plane of the main shock could vary from N22°E to N55°E depending upon the type of seismic wave analyzed. Dr. Aggarwal appears to be incorrect in his assertion that Hermann & Nguyen (Reference 13) defined a possible source of the earthquake as being a N28°E westward dipping fault (82°). Dr. Hermann (personal communication 1988) indicated that this possible source would be a N21°E eastward dipping fault. Similarly Reference 11 states that the variations in the trend of preferred nodal planes (fault planes) is probably due to the fact that more than one favorably oriented weak fracture is being reactivated by the change in stress associated with the main shock.

Dr. Aggarwal suggests that several of the earthquakes which occurred in recent history have a sufficient error band in their epicentral location that they can be also associated with the AMB. Dr. Aggarwal asserts that the error in location can be attributed to soil amplification effects, bias as a result of population density and/or errors in methods of locating earthquake epicenters on the basis of felt reports or insufficient instrumental data.

While the staff agrees with Dr. Aggarwal's assertions that most historical earthquakes discussed have poorly located epicenters, we disagree with his assertion that they can be correlated with the Akron Magnetic Boundary. *By that, he infers* inferring a fault on which the occurrence of an earthquake much larger than the magnitude 5.0 earthquake of January 31, 1986 "must be considered a realistic possibility". The staff bases this conclusion on the following observations: *2 p.*

1. The January 31, 1986 earthquake itself is not uncharacteristic of the general earthquake history of the tectonic province which includes the 1937 Anna Ohio earthquake, the 1982 Sharpsburg Kentucky earthquake, and many other earthquakes in the magnitude 5.0 to 5.5 range.
2. The nature and depth of the geologic feature or features manifested by the AMB have not been determined. Throughout the eastern U.S. there are many magnetic features and many earthquakes the size of the 1986 Ohio event. Some of these earthquakes are near anomalous magnetic features and others are not. Magnetic boundaries indicate changes in rock properties. However there is no basis to assume, as Dr. Aggarwal does, that these changes in rock properties necessarily indicate faults and that they are capable of large ruptures.
3. Dr. Aggarwal uses the macroseismicity criterion in Appendix A to 10 CFR, Part 100 to identify the AMB as a capable fault. Past use of macroseismicity to identify capable faults has proven to be a difficult process. Macroscopicity has been considered to be a level of seismicity that implies significant, sustained, and coherent tectonic activity representative of major deformational movement within the earth's crust (Reference 12). Dr. Aggarwal has identified six historic earthquakes, one of magnitude 4.7 and five in the magnitude 2.7 to 3.8 range that have occurred since 1885 which, because of location uncertainties of this correlation is highly questionable since he neglects to show that there are other earthquake occurrences in northeastern Ohio whose location cannot be associated with the AMB. These include many earthquakes to the west, in the vicinity of Cleveland, Ohio and most recently the magnitude 3.6, July 13, 1987 earthquake, discussed in Reference 10. This very well located event, apparently triggered by fluid injection, occurred some 25 km east of the AMB on an east-west trending fault. Therefore the small number of earthquakes, most of which are less than magnitude 4, the large uncertainty in their location and the occurrence of earthquakes in areas not associated with the AMB do not, in the staff's opinion, constitute an appropriate use of macroseismicity to identify a capable fault. *2 p.*

In conclusion, we find that the arguments stated in the OCRE petition indicating the presence of a large capable fault which could generate a magnitude 6.5 or greater earthquake in the vicinity of the PNPP cannot be substantiated. Therefore the request for a suspension of the license in order to conduct additional geological and geophysical studies and engineering evaluations is unwarranted.

The NRC staff however is aware that the northeastern Ohio region is an area of continuing investigation by the NRC, university groups and CEI which, as indicated previously, is monitoring microseismicity in the vicinity of the plant. The staff is keeping informed of studies being performed in the region and will evaluate the resulting reports with respect to changes in the above conclusions and any impact they might have upon the seismic safety of the PNPP.

While the staff agrees with Dr. Aggarwal's assertions that most historical earthquakes discussed have poorly located epicenters, we disagree with his assertion that they can be correlated with the Akron Magnetic Boundary inferring a fault on which the occurrence of an earthquake much larger than the magnitude 5.0 earthquake of January 31, 1986 "must be considered a realistic possibility". The staff bases this conclusion on the following observations:

1. The January 31, 1986 earthquake itself is not uncharacteristic of the general earthquake history of the tectonic province which includes the 1937 Anna Ohio earthquake, the 1982 Sharpsburg Kentucky earthquake, and many other earthquakes in the magnitude 5.0 to 5.5 range.
2. The nature and depth of the geologic feature or features manifested by the AMB have not been determined. Throughout the eastern U.S. there are many magnetic features and many earthquakes the size of the 1986 Ohio event. Some of these earthquakes are near anomalous magnetic features and others are not. Magnetic boundaries indicate changes in rock properties. However there is no basis to assume, as Dr. Aggarwal does, that these changes in rock properties necessarily indicate faults and that they are capable of large ruptures.
3. Dr. Aggarwal uses the macroseismicity criterion in Appendix A to 10 CFR, Part 100 to identify the AMB as a capable fault. Past use of macroseismicity to identify capable faults has proven to be a difficult process. Macroscopicity has been considered to be a level of seismicity that implies significant, sustained, and coherent tectonic activity representative of major deformational movement within the earth's crust (Reference 12). Dr. Aggarwal has identified six historic earthquakes, one of magnitude 4.7 and five in the magnitude 2.7 to 3.8 range that have occurred since 1885 which, because of location uncertainties of this correlation is highly questionable since he neglects to show that there are other earthquake occurrences in northeastern Ohio whose location, cannot be associated with the AMB. These include many earthquakes to the west, in the vicinity of Cleveland, Ohio and most recently the magnitude 3.6, July 10, 1987 earthquake, discussed in Reference 10. This very well located event, apparently triggered by fluid injection, occurred some 25 km east of the AMB on an east-west trending fault. Therefore the small number of earthquakes, most of which are less than magnitude 4, the large uncertainty in their location and the occurrence of earthquakes in areas not associated with the AMB do not, in the staff's opinion, constitute an appropriate use of macroseismicity to identify a capable fault.

← OMISSION
2/24

In conclusion, we find that the arguments stated in the OCRE petition indicating the presence of a large capable fault which could generate a magnitude 6.5 or greater earthquake in the vicinity of the PNPP cannot be substantiated. Therefore the request for a suspension of the license in order to conduct additional geological and geophysical studies and engineering evaluations is unwarranted.

The NRC staff however is aware that the northeastern Ohio region is an area of continuing investigation by the NRC, university groups and CEI which, as indicated previously, is monitoring microseismicity in the vicinity of the plant. The staff is keeping informed of studies being performed in the region and will evaluate the resulting reports with respect to changes in the above conclusions and any impact they might have upon the seismic safety of the PNPP.