Duquesne Light Company Beaver Valley Power Statics

PO. Box 4 Shippingport, PA 15077-0004

JOHN D. SIEBER Vice President - Nuclear Group

(412) 643-5255

A09' w/check \$150 #664900

August 11, 1988

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 2 BV-2 Docket No. 50-412, License No. NPF-73 Proposed Operating License Change Request No. 4

Gentlemen:

Enclosed are:

1. An Application for Amendment to the above Operating License to revise the Supplementary Leak Collection and Release System (SLCRS) filter testing surveillance requirements of specification 4.7.8.1.b. This surveillance requirement currently requires both a charcoal iodine removal efficiency test and a leak test of the HEPA and charcoal filter following painting, fire or chemical releases in any ventilation zone communicating with the SLCRS. The proposed amendment would only require the charcoal iodine removal efficiency test following filter exposure to these conditions. The proposed amendment would also revise the SLCRS flow rate from 59,000 CFM +10% to 57,000 CFM +10%.

This change has been reviewed by the OSC and ORC and determined to be safe and does not involve an unreviewed safety question.

 Documents designated Attachments A, B and C which setforth the change in Technical Specifications, the safety analysis and the no significant hazards evaluation.

A check in the amount of \$150.00 is attached as payment of the license amendment application fee in accordance with 10 CFR 170.

Very truly yours,

J. D. Sieber Vice President Nuclear Group

8809010115 880811 PDR ADOCK 05000412 PNU

.

Beaver Valley Power Station, Unit No. 2 BV-2 Docket No. 50-412, License No. NPF-73 Proposed Operating License Change Request No. 4 Page 2

cc: Mr. J. Beall, Sr. Resident Inspector Mr. W. T. Russell, NRC Region I Administrator Mr. P. Tam, Project Manager Director, Safety Evaluation & Control (VEPCO) Mr. T. M. Gerusky, Director BRP/DER