

NRC Operations Center
U. S. Nuclear Regulatory Commission
Washington, D. C.

Attachment to Siemens Power Corporation - Nuclear Division 10 CFR 21 Report
(Fuel Cycle and Materials Event Notification Worksheet/NRC Form 361A) of
September 17, 1998

**10 CFR Part 21 Notification of Defect Relative to MCPR Operating Limits as
Impacted by Gap Conductance of Co-Resident BWR Fuel**

For BWR reactors where SPC provides reload fuel, postulated transient events are analyzed each cycle to establish MCPR operating limits. During transition cycles, SPC establishes limits for SPC fuel and also for co-resident fuel manufactured by other fuel vendors. Transient analyses are required to address co-resident fuel as well as SPC fuel because previous co-resident fuel transient analyses and limits may no longer be valid due to changes in core neutronic characteristics. Inputs to the transient analyses include the fuel pellet to cladding gap heat transfer coefficient for both SPC fuel and co-resident fuel. The gap heat transfer coefficient is calculated using the RODEX2 computer code.

An SPC internal licensing methodology review was performed and concerns were identified relative to the values for several fuel rod characteristics used in the RODEX2 analyses to calculate gap conductance values for input to the transient analyses for co-resident fuel. An evaluation of these concerns determined there exists reportable defects. The defects were a consequence of modeling the co-resident fuel with cold-worked cladding - typical of SPC cladding - instead of annealed cladding as it should have been. The gap conductance behavior of the co-resident fuel affected the core wide neutronic behavior through void reactivity feedback during certain transients and, consequently, the calculation of the transient Δ CPR for the limiting SPC fuel.

The defects are non-conservative MCPR operating limits previously provided to ComEd for LaSalle Unit 2 Cycle 8 and Quad Cities Unit 2 Cycle 15. The previously calculated and reported operating limit for LaSalle will be revised before the reactor starts up (anticipated startup in March 1999). The previously calculated and reported operating limits for Quad Cities Unit 2 Cycle 15 were determined at the limiting EOC exposure conditions. Corrected analyses have been performed which demonstrate that the current operating limits are bounding from BOC to a cycle exposure of 8 GWd/MTU. The Quad Cities Unit 2 operating limits will be revised before the cycle reaches 8 GWd/MTU.

9809240167 980917
PDR ADOCK 05000265
S PDR

11
JE20

FUEL CYCLE FACILITY

EVENT NUMBER: 34791

FACILITY: SIEMENS POWER CORPORATION RXTYPE: URANIUM FUEL FABRICATION COMMENTS: LEU CONVERSION (UF6 to UO2) FABRICATION & SCRAP RECOVERY COMMERICAL LWR FUEL		NOTIFICATION DATE: 09/17/98 NOTIFICATION TIME: 18:31 [ET] EVENT DATE: 09/17/98 EVENT TIME: 12:00 [PDT] LAST UPDATE DATE: 09/17/98
CITY: RICHLAND COUNTY: BENTON LICENSE#: SNM-1227 DOCKET: 07001257	REGION: 4 STATE: WA AGREEMENT: Y	NOTIFICATIONS
NRC NOTIFIED BY: HARVEY CURAT HQ OPS OFFICER: DICK JOLLIFFE		MONTE PHILLIPS RDO VERN HODGE NRR
EMERGENCY CLASS: NOT APPLICABLE 10 CFR SECTION: CCCC 21.21 UNSPECIFIED PARAGRAPH		

EVENT TEXT

- 10CFR PART 21 REPORT - DEFECT RELATED TO MCPR OPERATING LIMITS -

FOR BWR REACTORS WHERE SIEMENS POWER CORPORATION (SPC) PROVIDES RELOAD FUEL, POSTULATED TRANSIENT EVENTS ARE ANALYZED EACH FUEL CYCLE TO ESTABLISH MINIMUM CRITICAL POWER RATIO (MCPR) OPERATING LIMITS. DURING TRANSITION CYCLES, SPC ESTABLISHES LIMITS FOR SPC FUEL AND ALSO FOR CO-RESIDENT FUEL MANUFACTURED BY OTHER FUEL VENDORS. TRANSIENT ANALYSES ARE REQUIRED TO ADDRESS CO-RESIDENT FUEL AS WELL AS SPC FUEL BECAUSE PREVIOUS CO-RESIDENT FUEL TRANSIENT ANALYSES AND LIMITS MAY NO LONGER BE VALID DUE TO CHANGES IN CORE NEUTRONIC CHARACTERISTICS. INPUTS TO THE TRANSIENT ANALYSES INCLUDE THE FUEL PELLETT TO CLADDING GAP HEAT TRANSFER COEFFICIENT FOR BOTH SPC FUEL AND CO-RESIDENT FUEL. THE GAP HEAT TRANSFER COEFFICIENT IS CALCULATED USING THE RODEX2 COMPUTER CODE.

AN SPC INTERNAL LICENSING METHODOLOGY REVIEW WAS PERFORMED AND CONCERNS WERE IDENTIFIED RELATIVE TO THE VALUES FOR SEVERAL FUEL ROD CHARACTERISTICS USED IN THE RODEX2 ANALYSES TO CALCULATE GAP CONDUCTANCE VALUES FOR INPUT TO THE TRANSIENT ANALYSES FOR CO-RESIDENT FUEL. AN EVALUATION OF THESE CONCERNS DETERMINED THAT REPORTABLE DEFECTS EXIST. THE DEFECTS WERE A CONSEQUENCE OF MODELING THE CO-RESIDENT FUEL WITH COLD-WORKED CLADDING, TYPICAL OF SPC CLADDING, INSTEAD OF ANNEALED CLADDING, AS IT SHOULD HAVE BEEN. THE GAP CONDUCTANCE BEHAVIOR OF THE CO-RESIDENT FUEL AFFECTED THE CORE WIDE NEUTRONIC BEHAVIOR THROUGH VOID REACTIVITY FEEDBACK DURING CERTAIN TRANSIENTS AND, CONSEQUENTLY, THE CALCULATION OF THE TRANSIENT DIFFERENTIAL CRITICAL POWER RATIO FOR THE LIMITING SPC FUEL.

THE DEFECTS ARE NON-CONSERVATIVE MCPR OPERATING LIMITS PREVIOUSLY PROVIDED TO COMMONWEALTH EDISON FOR LASALLE UNIT 2 CYCLE 8 AND QUAD CITIES UNIT 2

(Continued on next page)

CYCLE 15. THE PREVIOUSLY CALCULATED AND REPORTED OPERATING LIMIT FOR LASALLE WILL BE REVISED BEFORE THE REACTOR STARTS UP (ANTICIPATED STARTUP IN MARCH, 1999). THE PREVIOUSLY CALCULATED AND REPORTED OPERATING LIMITS FOR QUAD CITIES UNIT 2 CYCLE 15 WERE DETERMINED AT THE LIMITING END-OF-CYCLE EXPOSURE CONDITIONS. CORRECTIVE ANALYSES HAVE BEEN PERFORMED WHICH DEMONSTRATE THAT THE CURRENT OPERATING LIMITS ARE BOUNDING FROM BEGINNING-OF-CYCLE TO A CYCLE EXPOSURE OF 8 GWd/MTU. THE QUAD CITIES UNIT 2 OPERATING LIMITS WILL BE REVISED BEFORE THE CYCLE REACHES 8 GWd/MTU.

SPC EVALUATED THIS ISSUE UNDER SPC CONDITION REPORT #6565, DATED 03/02/98, AND PREVIOUSLY INFORMED THE NRC OF THIS ISSUE VIA SPC INTERIM REPORT #98-004, DATED 07/22/98.

NRC FORM 361A (11/94)		U.S. NUCLEAR REGULATORY COMMISSION				PAGE 1 OF 2 LICENSE NUMBER	
FUEL CYCLE AND MATERIALS EVENT NOTIFICATION WORKSHEET						SNM-1227 (NRC Docket No. 70-1257)	
REPORT TIME 1831	FACILITY OR ORGANIZATION SIEMENS POWER CORPORATION - NUC. DIV.		NAME OF CALLER HARVEY H. D. Curet		CALLBACK TELEPHONE NUMBER (509) 375-8563		
EVENT TIME N/A	EVENT DATE ** 9 / 17 / 98	LOCATION OF EVENT (INCLUDE COUNTY AND STATE) Richland, Benton County, WA			PORTION OF PLANT AFFECTED N/A		
EVENT CLASSIFICATION		EVENT TYPES		INCIDENT REPORTS (30, 52, 40, 60, 70, 50)			
<input type="checkbox"/> GENERAL EMERGENCY*	<input checked="" type="checkbox"/>	FUEL CYCLE	20 2201	LOSS/THEFT	(a)	PROTECTIVE ACTION PREVENTED	
<input type="checkbox"/> SITE AREA EMERGENCY		MEDICAL/ACADEMIC	20 2202	ACTUAL/THREATENED OVEREXPOSURE	(b) (1)	UNPLANNED CONTAMINATION	
<input type="checkbox"/> ALERT		TRANSPORTATION	20 2202	ACTUAL/THREATENED RELEASE	(b) (2)	SAFETY EQUIPMENT FAILURE	
<input type="checkbox"/> NOTIFICATION OF UNUSUAL EVENT*		WASTE MANAGEMENT	<input checked="" type="checkbox"/> 21 21	DEFECT/ NONCOMPLIANCE	(b) (3)	MEDICAL TREATMENT WITH CONTAMINATION	
<input checked="" type="checkbox"/> INCIDENT REPORT		INDUSTRIAL/COMMERCIAL	26 73	FITNESS FOR DUTY	(b) (4)	FIRE / EXPLOSION	
<input type="checkbox"/> TRANSPORTATION EVENT		FOREIGN EVENT	35 33	MISADMINISTRATION	70 52	CRITICALITY / SNM LOST	
<input type="checkbox"/> INFORMATION ONLY		OTHER (Specify)	36 83	IRRADIATOR EVENT	70 52	ACTUAL / ATTEMPTED THEFT	
<input type="checkbox"/> OTHER (Specify)			39 77	RUPTURED WELL LOGGING SOURCE		CRITICALITY CONTROL + 4-HOUR (BULLETIN 91-01)	
			39 77	IRRETRIEVABLE WELL LOGGING SOURCE		CRITICALITY CONTROL + 24-HOUR (BULLETIN 91-01)	
* ONLY UNDER OLD 1981 ORDER			40 26	TAILINGS/WASTE DAM FAILURE		OTHER NON-CFR REQUIREMENT	
NOTIFICATIONS	YES	NO	WILL BE	ANYTHING UNUSUAL OR		YES (Explain below)	
NRC REGION?			<input checked="" type="checkbox"/>	NOT UNDERSTOOD?	<input checked="" type="checkbox"/>	NO	
STATE?		<input checked="" type="checkbox"/>		DID ALL SYSTEMS FUNCTION		YES (N/A)	
LOCAL?		<input checked="" type="checkbox"/>		AS REQUIRED		NO (Explain below)	
OTHER GOVERNMENT AGENCIES?		<input checked="" type="checkbox"/>		ADDITIONAL INFORMATION ON BACK?	<input checked="" type="checkbox"/>	YES (Attached)	
PRESS RELEASE?		<input checked="" type="checkbox"/>				NO	
EVENT DESCRIPTION (Continue on separate sheet if necessary)							
<p>See attached summary of defect related to MCPR operating limits. Affected customer (Commonwealth Edison / Quad Cities Unit 2 (operating) and LaSalle Unit 2 (not operating)). The NRC was previously informed of the issue via SPC Interim Report 98-004 (7/22/98).</p>							
200007							
<p>** Date of reporting to NRC Operation Center. Defect was evaluated under SPC Condition Report 6565 initiated March 2, 1998.</p>							
Duty Officer:				Report #			

I E 20