

UNITED STATES NUCLEAR REGULATORY COMMISSIONFLORIDA POWER CORPORATIONDOCKET NO. 50-302NOTICE OF ISSUANCE OF AMENDMENT TOFACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 106 to Facility Operating License No. DRP-72 to the Florida Power Corporation (the licensee), which revised the Technical Specifications for operation of the Crystal River 3 Nuclear Generating Plant, located in Citrus County, Florida. The amendment was effective as of the date of its issuance.

The amendment revised the Technical Specifications to provide specific actions to be taken when one of the batteries supplying D.C. control power to the 230 kv switchyard breakers is inoperable, and revised the time the plant may operate with one inoperable battery. The amendment also more explicitly defined the surveillances to be performed in Nodes 5 and 6.

The application for amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.


Notice of Consideration of Issuance of Amendment and Opportunity for Hearing in connection with this action was published in the FEDERAL REGISTER on March 22, 1988 (53 FR 9386).

Also in connection with this action, the Commission prepared an Environmental Assessment and Finding of No Significant Impact, which was published in the FEDERAL REGISTER on April 19, 1988 (53 FR 12836).

For further details with respect to the action, see (1) the application for amendment dated January 20, 1988, (2) Amendment No. 105 to License No. DPR-72, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C., and at the Crystal River Public Library, 668 N.W., First Avenue, Crystal River, Florida 32629.

Dated at Rockville, Maryland this 22nd day of April , 1988.

FOR THE NUCLEAR REGULATORY COMMISSION



Harley Silver, Sr. Project Manager  
Project Directorate II-2  
Division of Reactor Projects-I/II  
Office of Nuclear Reactor Regulation