



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PUBLIC SERVICE ELECTRIC & GAS COMPANY

PHILADELPHIA ELECTRIC COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-272

SALEM NUCLEAR GENERATING STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 88
License No. DPR-70

1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Public Service Electric & Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated May 3, 1988 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-70 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 88, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/S/

Walter R. Butler, Director
Project Directorate I-2
Division of Reactor Projects I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 29, 1988

PDI-2/LA
MD: BrLen
8/10/88

PDI-2/PM
DR: Scher:tr
8/10/88

OGC
8/16/88

PDI-2/D
WButler
8/22/88


WB

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 88, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Walter R. Butler, Director
Project Directorate I-2
Division of Reactor Projects I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 29, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 88

FACILITY OPERATING LICENSE NO. DPR-70

DOCKET NO. 50-272

Revise Appendix A as follows:

Remove Page

3/4 8-12

Insert Page

3/4 8-12

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

2. The pilot cell specific gravity, corrected to 77°F, and full electrolyte level, is greater than or equal to 1.200.
 3. The pilot cell voltage is greater than or equal to 2.08 volts.
 4. The overall battery voltage is greater than or equal to 27 volts.
- b. At least once per 92 days by verifying that:
1. The voltage of each connected cell is greater than or equal to 2.13 volts under float charge and has not decreased more than 0.27 volts from the value observed during the original acceptance test.
 2. The specific gravity, corrected to 77°F and full electrolyte level, of each connected cell is greater than or equal to 1.200 and has not decreased more than 0.02 from the value observed during the previous test.
 3. The electrolyte level of each connected cell is between the minimum and maximum level indication marks.
- c. At least once per 18 months by verifying that:
1. The cells, cell plates and battery racks show no visual indication of physical damage or abnormal deterioration.
 2. The cell-to-cell and terminal connections are clean, tight, and coated with anti-corrosion material.
 3. The battery charger will supply at least 150 amperes at 28 volts for at least 4 hours.
- d. At least once per 18 months, during shutdown, by verifying that the battery capacity is adequate to supply and maintain in OPERABLE status all of the actual emergency loads for 8 hours when the battery is subjected to a battery service test.
- e. At least once per 60 months, during shutdown, by verifying that the battery capacity is at least 80% of the manufacturer's rating when subjected to a performance discharge test. Satisfactory completion of this performance discharge test shall also satisfy the requirements of Specification 4.8.2.5.2.d if the performance discharge test is conducted during a shutdown where that test and the battery service test would both be required.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PUBLIC SERVICE ELECTRIC & GAS COMPANY

PHILADELPHIA ELECTRIC COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-311

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 61
License No. DPR-75

1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Public Service Electric & Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated May 3, 1988 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-75 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 61, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/S/

Walter R. Butler, Director
Project Directorate I-2
Division of Reactor Projects I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 29, 1988

PDI-2/LA
MO'Brien
8/10/88

PDI-2/PE
DRitscher:tr
8/10/88

OGC
B
8/11/88

PDI-2/D
WButler
8/22/88


WB

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 61, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Walter R. Butler, Director
Project Directorate I-2
Division of Reactor Projects I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 29, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 61

FACILITY OPERATING LICENSE NO. DPR-75

DOCKET NO. 50-311

Revise Appendix A as follows:

Remove Page

3/4 8-14

Insert Page

3/4 8-14

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

2. The pilot cell specific gravity, corrected to 77°F, and full electrolyte level, is greater than or equal to 1.200.
 3. The pilot cell voltage is greater than or equal to 2.08 volts.
 4. The overall battery voltage is greater than or equal to 27 volts.
- b. At least once per 92 days by verifying that:
1. The voltage of each connected cell is greater than or equal to 2.13 volts under float charge and has not decreased more than 0.27 volts from the value observed during the original acceptance test.
 2. The specific gravity, corrected to 77°F and full electrolyte level, of each connected cell is greater than or equal to 1.200 and has not decreased more than 0.02 from the value observed during the previous test.
 3. The electrolyte level of each connected cell is between the minimum and maximum level indication marks.
- c. At least once per 18 months by verifying that:
1. The cells, cell plates and battery racks show no visual indication of physical damage or abnormal deterioration.
 2. The cell-to-cell and terminal connections are clean, tight, and coated with anti-corrosion material.
 3. The battery charger will supply at least 150 amperes at 28 volts for at least 4 hours.
- d. At least once per 18 months, during shutdown, by verifying that the battery capacity is adequate to supply and maintain in OPERABLE status all of the actual emergency loads for 8 hours when the battery is subjected to a battery service test.
- e. At least once per 60 months, during shutdown, by verifying that the battery capacity is at least 80% of the manufacturer's rating when subjected to a performance discharge test. Satisfactory completion of this performance discharge test shall also satisfy the requirements of Specification 4.8.2.5.2.d if the performance discharge test is conducted during a shutdown where that test and the battery service test would both be required.