


Log # TXX-4700
File # 10110
903.8

TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER · 400 NORTH OLIVE STREET, L.B. 81 · DALLAS, TEXAS 75201

February 12, 1986

WILLIAM G. COUNCIL
EXECUTIVE VICE PRESIDENT

Mr. Eric H. Johnson, Acting Director
Division of Reactor Safety and Projects
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76012



SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 AND 50-446
PROXIMITY PLACEMENT - RICHMOND INSERTS TO EMBEDDED PLATE
SDAR: CP-86-04

Dear Mr. Johnson:

On January 13, 1986, we verbally notified your Mr. T. Westerman of a deficiency regarding the placement of Richmond inserts in the proximity of embedded plates which could compromise the structural integrity of adjacent shear cones. This is an interim report of a potentially reportable item under the provisions of 10CFR50.55(e).

Evaluation of the issue will require an assessment - by field survey - of all potential spacing violations involving Richmond inserts in the proximity of embedded plates. At this point, the Unit 2 Safeguard building survey results have been completed without the identification of adverse conditions. Unit 1 efforts and the balance of Unit 2 efforts are scheduled to be completed by late June, 1986. Actions to preclude recurrence of the issue have been identified and are in preparation.

We are continuing our evaluation and anticipate completion of our final report by July 18, 1986.

Very truly yours,

A handwritten signature in cursive script that reads "W. G. Council".

W. G. Council

8602250005 860212
PDR ADOCK 03000445
S PDR

JCH/arm

c - NRC Region IV (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

86-145

1/0
IE-27