



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PACIFIC GAS AND ELECTRIC COMPANY
DIABLO CANYON NUCLEAR POWER PLANT, UNIT 1
DOCKET NO. 50-275
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 31
License No. DPR-80

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Pacific Gas & Electric Company (the licensee), dated October 29, 1986, as supplemented by letter dated July 5, 1988 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-80 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 31, are hereby incorporated in the license. Pacific Gas & Electric Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan, except where otherwise stated in specific license conditions.

3. This license amendment becomes effective at the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

H. Reed GK

George W. Knighton, Director
Project Directorate V
Division of Reactor Projects - III/IV/V
and Special Projects
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 29, 1988



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PACIFIC GAS AND ELECTRIC COMPANY
DIABLO CANYON NUCLEAR POWER PLANT, UNIT 2
DOCKET NO. 50-323
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 30
License No. DPR-82

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Pacific Gas & Electric Company (the licensee), dated October 29, 1986, as supplemented by letter dated July 5, 1988 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-82 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 30, are hereby incorporated in the license. Pacific Gas & Electric Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan, except where otherwise stated in specific license conditions.

3. This license amendment becomes effective at the time of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

H. Reed for G.K.

George W. Knighton, Director
Project Directorate V
Division of Reactor Projects - III/IV/V
and Special Projects
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 29, 1988

ATTACHMENT TO LICENSE AMENDMENT NOS. 31 AND 30
FACILITY OPERATING LICENSE NOS. DPR-80 and DPR-82
DOCKET NOS. 50-275 AND 50-323

Replace the following pages of the Appendix "A" Technical Specifications with the attached page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change.

Remove Page

3/4 6-19

Insert Page

3/4 6-19

TABLE 3.6-1 (Continued)

<u>VALVE NO.</u>	<u>FUNCTION</u>	<u>ISOLATION TIME (Seconds)</u>
1. Phase "A" Isolation Valves (Continued)		
9357B	Accumulator Sample OC	< 10
8100	RCP Seal Water Return OC	< 10
8112	RCP Seal Water Return IC	< 10
2. Phase "B" Isolation Valves		
FCV-356	CCW Supply to RCP's and Support Coolers OC	N.A.
FCV-357	RCP Thermal Barrier CCW Return OC	N.A.
FCV-363	RCP Oil Cooler/Support Cooler CCW Return OC	N.A.
FCV-749	RCP Oil Cooler/Support Cooler CCW Return IC	N.A.
FCV-750	RCP Thermal Barrier CCW Return IC	N.A.
3. Containment Ventilation Isolation Valves		
FCV-660##	Containment Purge Supply IC	< 2
FCV-661##	Containment Purge Supply OC	< 2
FCV-662	Containment Vacuum/Pressure Relief IC	< 5
FCV-663	Containment Pressure Relief OC	< 5
FCV-664	Containment Vacuum Relief OC	< 5
FCV-678	Containment Air Sample Supply IC	< 10
FCV-679	Containment Air Sample Supply OC	< 10
FCV-681	Containment Air Sample Return OC	< 10
RCV-11##	Containment Purge Exhaust IC	< 2
RCV-12##	Containment Purge Exhaust OC	< 2