

DmB



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

February 20, 1986

MEMORANDUM FOR: Region III Files
FROM: R. N. Gardner, Section Chief, Braidwood Project, Division
of Reactor Projects
SUBJECT: ACTION ITEMS RESULTING FROM BRAIDWOOD SEMINAR-ASLB OL HEARING
ISSUES

The following action items were identified during the Braidwood Seminar on ASLB OL hearing issues:

Contention item 9A

Danielson's section to inspect AWS welding at Braidwood and document the results in a report.

Contention Item 9B

Muffett will pursue the idea of replacement of subject connection.

CAT Inspection

Licensee needs to docket a commitment to invoke the Byron interference procedure at Braidwood.

Mr. Keppler, Regional Administrator, recommends that the CAT team visit Region III to review corrective actions pertaining to CAT findings.

Intimidation and Harrassment

Need to question Mr. X to see if he signed records under pressure.

HVAC

Need to verify NRC acceptance of 50% weld issue (50.55(e)).

82-05

Need to review equipment installations performed only in part by Phillips Getchow.

8602250071 860220
PDR ADOCK 05000456
A PDR

IE 1/0

February 20, 1986

Need a satisfactory response to citation on pump bolting issued in 1983 (Report No. 83-07).

Maintenance of equipment - analyze what affect the lack of preventative maintenance had on equipment.

R. N. Gardner

R. N. Gardner, Section Chief
Braidwood Project

cc: W. S. Little
J. Muffett
D. Danielson
L. McGregor
T. Tongue
W. Kropp
J. Harrison