

RECEIVED
NRC

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

FEB 18 AM 10:35

REGION V NRC

H. E. MORGAN
STATION MANAGER

TELEPHONE
(714) 368-6241

February 13, 1986

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - January 1986
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC),
dated January 14, 1986

In accordance with our referenced letter, this submittal provides the follow-up report of fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in January 1986.

Fire doors found inoperable during the January routine surveillances are identified in the Attachment and include: 5 latching mechanism failures and 8 closure mechanism failures. No doors were found blocked open in January. As each of these deficiencies was identified, compensatory fire watches, pursuant to Technical Specification 3.7.9, Action Statement 'a', were established. We are continuing previously reported corrective actions to upgrade door latches and closure mechanisms.

8602250203 860213
PDR ADOCK 05000361
S PDR

1/1
IF-01


Mr. J. B. Martin

-2-

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in February 1986 will be submitted by March 17, 1986.

If you require any additional information, please so advise.

Sincerely,

Handwritten signature of H. E. Morgan in cursive script, followed by a horizontal line.

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)

U. S. Nuclear Regulatory Commission
Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF JANUARY 1986
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 5, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-114	12/09/85	1/14/86
AC-402	1/22/86	1/26/86
AC-416	11/28/85	1/16/86
AC-442	1/12/86	1/26/86
AR-301	10/24/85	---

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF JANUARY 1986
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

II. Closure Mechanism Failures:

Number of doors inoperable - 8, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-332	1/23/86	---
AC-442	12/26/85	1/10/86
AC-459	12/28/85	1/08/86
AR-502	12/12/85	1/27/86
FH3-103	1/18/86	---
FH3-207	1/18/86	---
FH3-304	1/24/86	1/25/86
FH3-304	1/29/86	---

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF JANUARY 1986
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

III. Doors Blocked Open:

Number of doors blocked open - None