

FEB 19 1986

In Reply Refer To:
Docket: 50-382/85-23

Louisiana Power & Light Company
ATTN: R. S. Leddick, Sr. Vice President
Nuclear Operations
142 Delaronde Street
New Orleans, Louisiana 70174

Gentlemen:

Thank you for your letter of December 13, 1985, in response to our letter and
and the attached Notice of Violation dated November 14, 1985. In response to
your comment on the validity of the Notice of Violation, the NRC inspectors
determined by observation during the operational walk-through that the two
shift supervisors and control room supervisors had not been adequately trained
to properly perform emergency response duties; therefore, a violation of the
requirement did occur. We have reviewed the corrective actions that you have
proposed and find them responsive to the concerns raised in our Notice of
Violation. We will review the implementation of your corrective actions
during a future inspection to determine that full compliance has been achieved
and will be maintained.

Sincerely,

Original Signed by:"

J. E. Gagliardo, Chief
Reactor Projects Branch

cc: (continued on next page)

8602250336 860219
PDR ADCK 05000382
PDR
Q

RIV:EP&SPS
CAHackney
2/11/86

C:EP&SPS
LAYandetti
2/11/86

D:DRS&S
RLBangart
02/11/86

C:RPSC
GLConstable
2/13/86

C:RPB
JEGagliardo
2/14/86

IE35
1/1

cc: Louisiana Power & Light Company
ATTN: G. E. Wuller, Onsite
Licensing Coordinator
P. O. Box B
Killona, Louisiana 70066

Louisiana Power & Light Company
ATTN: R. P. Barkhurst, Plant Manager
P. O. Box B
Killona, Louisiana 70066

Middle South Services
ATTN: Mr. R. T. Lally
P. O. Box 61000
New Orleans, Louisiana 70161

Louisiana Power & Light Company
ATTN: K. W. Cook, Nuclear Support
and Licensing Manager
142 Delaronde Street
New Orleans, Louisiana 70174

Louisiana Radiation Control Program Director

bcc to DMB (IE35)

bcc distrib. by RIV:

RPB
Resident Inspector
Section Chief (RPB/C)
R&SPB
MIS SYSTEM
RSTS Operator
RIV File

D. Weiss, LFMB (AR-2015)
R. D. Martin, RA
DRSP
RSB
C. A. Hackney
L. A. Yandell