



LOUISIANA
POWER & LIGHT / WATERFORD 3 SES • P.O. BOX 8 • KILLONA, LA 70066-0751

May 4, 1988

W3A88-0043
A4.05
QA

U.S. Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, D.C. 20555

SUBJECT: Waterford 3 SES
Docket No. 50-382
License No. NPF-38
Reporting of Special Report

Attached is Special Report Number SR-88-004-00 for Waterford Steam Electric Station Unit 3. This Special Report is submitted per 10CFR50.36(c)(2) and Technical Specifications 4.4.4.5 and 6.9.2.

Very truly yours,

N.S. Carns
Plant Manager - Nuclear

NSC/WEM:rk

Attachment

cc: R.D. Martin, NRC Resident Inspectors Office, INPO Records Center (J.T. Wheelock), E.L. Blake, W.M. Stevenson, D.L. Wigginton

8805100281 880504
PDR ADOCK 05000382
S DCD

"AN EQUAL OPPORTUNITY EMPLOYER"

IE22
/

SPECIAL REPORT

SR-88-004-00

Steam Generator Eddy Current Examination (2nd Refueling)

Inservice eddy current examination of the Steam Generator (S/G) tubing was completed at the Waterford Steam Electric Station Unit 3 on April 20, 1988. This report is submitted in accordance with Technical Specification (TS) 4.4.4.5.a which requires reporting of the number of tubes plugged in each S/G within 15 days following the completion of inservice inspection of S/G tubes pursuant to TS 6.9.2. A followup report will be submitted in accordance with TS 4.4.4.5.b by April 20, 1989.

The total number of tubes which have been plugged in each steam generator are shown below:

	<u>S/G #1</u>	<u>S/G #2</u>
Manufacturing/Preservice	6	20
Batwing (Preventive Plugging)	149	149
First Refueling	0	1
Second Refueling	<u>3</u>	<u>2</u>
TOTAL	158	172

PLANT CONTACT

L.L. Bass, Technical Support Supervisor, 504/467-2791, Extension 327.