

[REDACTED]

ET-NRC-93-3990

OCTOBER 20, 1993

[REDACTED]

**AP600
REACTOR COOLANT SYSTEM LEAK
PRA EVALUATION**

October 1993

9809290090 980922
PDR ADOCK 05200003
A PDR

Table of Contents

	<u>PAGE</u>
1.0 Introduction	1
2.0 Purpose	1
3.0 Analysis	2
3.1 Create the RCS Leak Event Tree	2
3.2 Quantify the Core Damage Frequency for the RCS Leak Event	3
3.3 Update the Containment Event Trees (CET)	3
4.0 Conclusion	3

1.0 INTRODUCTION

During an NRC/EPRI meeting on the Regulatory Treatment of Non-Safety Systems (RTNSS) held on November 18, 1992, R. Youngblood of Brookhaven National Laboratories presented an evaluation of reliability goals and safety systems performance. This presentation included the identification of 39 reactor coolant system (RCS) leakage events with leak rates between 1 and 100 gallon per minute (gpm) and 48 events with leak rates less than 1 gpm at pressurized water reactors (PWR) during the period from 1987 to 1992 which included approximately 421 reactor years of PWR operation. Apparent concern over such events with respect to the AP600 design is that since the AP600 chemical and volume control system is a nonsafety-related system, these leakage events are not adequately addressed by the AP600 Probabilistic Risk Assessment (PRA). The analysis presented in the AP600 PRA report covers the range of loss of coolant accidents from a 100 gpm leak (very small LOCA category) up through the double-ended severance of the largest pipe in the primary coolant system. This RCS leakage event is now included in the AP600 baseline PRA which improves accuracy of the focused PRA for the regulatory treatment of nonsafety systems.

2.0 PURPOSE

The purpose of this document is to discuss the resolution of the RCS leakage issue identified above. The two ranges of leak rates identified are addressed separately.

For the 0 to 1 gpm leak range, a qualitative evaluation is performed. For a 1 gpm leak, with no makeup flow, it takes more than 60 hours to empty the pressurizer and more than 190 hours to drain the volume of water from a core makeup tank (CMT) to the automatic depressurization system (ADS) actuation water level setpoint. That is, with both CMTs operating, it would take more than 18 days to get to the ADS actuation setpoint. Failure to recognize and identify such a leak and neither correct the situation nor manually bring the plant to a safe shutdown condition is sufficiently unlikely that it is not in the scope of typical risk assessment studies.

For the 1 to 100 gpm leak rate range, a quantitative evaluation of the RCS leakage event is performed. The analysis includes: calculating a leakage initiating event frequency, calculating the probability of repairing the chemical and volume control system (CVCS) makeup system, developing an RCS leak event tree, quantifying the event tree, and finally incorporating the results into the current Baseline PRA results. The release frequency is also reanalyzed due to the additional core damage sequences that propagate through to the containment event trees.

This RCS leakage event is an addition to the other initiating events currently included in the baseline AP600 PRA. The core damage frequency and the release frequency associated with this event are a small addition to those values submitted to the NRC on June 26, 1992 in the AP600 Probabilistic Risk Assessment Report. The AP600 PRA report tables dealing with core damage frequency (i.e., Tables 7-1 and 8-1) change as a result of including the RCS leak event. The revisions to those tables are included in this letter as Tables 1 and 2. The increase in release frequency is sufficiently small that it does not change any reported results.

3.0 ANALYSIS

The analysis of core damage frequency and release frequency for the RCS leakage event is performed in the distinct steps described in Subsections 3.1, 3.2 and 3.3.

3.1 Create the RCS Leak Event Tree

The RCS leak event, defined as an RCS leak rate less than or equal to 100 gpm combined with failure of the CVCS to provide makeup to the RCS, is actually a very small loss of coolant accident with the distinction that the leak is sufficiently small that a "long" period of time is required to deplete the primary coolant system to the extent that the water level in the core makeup tanks will cause actuation of the ADS. The length of this time period is a function of the leak rate but in any case is long enough to permit repair of the CVCS. A new event tree, Reactor Coolant System Leak, was created and is shown in Figure 1. This event tree is based on Figure F-18 of the AP600 PRA report (very small loss of coolant accident event tree). Figure F-18 was modified to account for the possibility of repairing the CVCS if the core makeup tanks operated successfully. The RCS leak initiating event is given the acronym of SL.

This study is done for a breach of the primary coolant system of such size that results in an initial leak flow rate of 50 gpm. For such a leak, successful operation of the CMTs would preclude ADS actuation for more than 5 hours, during which time the CVCS could be repaired. This time is calculated on the basis of the pressurizer emptying to the safety injection signal setpoint and then one CMT injecting to get to the ADS actuation setpoint for CMT water level. By using 1 out of 2 CMTs as the success criterion, fault tree CM2SL from the "June 26, 1992" PRA could be used for this study. The probability of failing to repair the CVCS in 4 to 6 hours was calculated to be 0.50 and this value is used in the core damage frequency analysis. Repair of the CVCS is given the basic event identifier OTH-CVCSFIX.

The initiating event frequency for the RCS leak event (IEV-SL) is based on data reported by EPRI for PWRs operating during the 1987 to 1992 time period. These data include 39 leakage events that had a leak rate in the 1 gpm to 100 gpm range. These 39 events were evaluated to determine whether or not each event was possible on the AP600 design. As a result, 30 of the events were screened out (for example, RCS pump seal leaks were eliminated because AP600 does not have RCP seals) leaving nine events that are possible on the AP600. Of these 9 RCS leakage events, 5 occurred at-power and 4 occurred during shutdown. The impact of these leaks is different for at-power and shutdown operation; The time available for corrective action at shutdown is significantly longer than at-power and therefore contribute less to any change in core damage frequency. The maximum leak flow rate of the 5 at-power leakage events that could have occurred on the AP600 is 10 gpm. Because of this, using a leak flow rate of 50 gpm in the calculations to represent the 1 to 100 gpm range is reasonable and conservative with respect to historical data.

The RCS leak initiating event is defined as an event having leakage from the RCS less than 100 gpm combined with failure of the chemical and volume control system (CVCS) makeup pumps. The 5 events from the EPRI data base represent 421 reactor years of PWR operation so the frequency of an RCS leak for AP600 is $5/421 = 1.2E-2$ events per year.

The unavailability of the makeup system (where success of the system is either of the two makeup pumps starting and running for 24 hours) is simply taken as the failure probability of the CSLOCA fault tree from the June 26, 1992 PRA. This value is $5.4E-3$. Therefore, the RCS leak initiating event frequency is

$$(1.2E-2) (5.4E-3) = 6.5E-5 \text{ events per year.}$$

A revised list of AP600 initiating event group frequencies is shown in Table 1.

3.2 Quantify the Core Damage Frequency for the RCS Leak Event

The RCS leak event tree was quantified and the resulting core damage frequency is $1.6E-9$ events per year. The core damage frequency associated with the RCS leak initiating event is combined with the other AP600 initiating events and the revised total core damage frequency is $3.4E-7$ events per year. Table 2 shows the revised list of initiating events contributing to core damage (Baseline, at-power conditions) and Table 3 shows the revised dominant accident sequence cutsets for this case. An importance analysis is done to rank the revised set of initiating events and the results are shown in Table 4.

3.3 Update the Containment Event Trees (CET)

The revised release frequency is calculated by quantifying the containment event trees with the core damage frequency information that includes the RCS leak event. The only containment event tree release frequency that was changed by the addition of the RCS leak initiating event is impaired containment (CI). The CI release frequency was $2.013E-8$ in the June 26, 1992 analysis and increases to $2.017E-8$ in this revised analysis due to the addition of the RCS leak event.

4.0 CONCLUSION

The evaluation of relatively small reactor coolant system leaks was performed in a conservative manner with respect to the assumed leak rate and probability of returning the failed primary coolant makeup system back into service. The results of this study show a 0.5 percent increase in core damage frequency and a 0.2 percent increase in the frequency of release from containment. This category of initiating events will be included in future AP600 PRA studies and PRA reports.

TABLE 1
AP600 INITIATING EVENT GROUP FREQUENCIES

EVENT	FREQUENCY (Event/Year)
Manual Shutdown	negligible
Transients	
Turbine trip or spurious reactor trip	1.40
Loss of feedwater flow	0.46
Secondary to primary side power mismatch	0.054
Core power excursion	4.47E-3
Spurious S-signal	0.085
Loss of component cooling system	0.014
Loss of service water system	0.026
Loss of compressed air	0.014
Main steam line break downstream of main steam isol. valves	6.0E-4
Main steam line break upstream of main steam isol. valves	3.7E-4
Main steam line safety valve stuck open	1.2E-3
Loss of Offsite Power	0.086
Loss of Coolant Accidents	
Large loss of coolant accident	9.7E-5
Medium loss of coolant accident	5.6E-4
Core makeup tank line break	1.3E-4
Safety injection line break	1.2E-4
Small loss of coolant accident	5.2E-4
Very small loss of coolant accident	5.5E-4
Reactor coolant system leak	6.5E-5
Passive residual heat removal tube rupture	5.0E-3
Steam generator tube rupture	5.2E-3
Reactor vessel rupture	3.0E-8
Interfacing loss of coolant accidents	negligible
Large break outside containment	negligible
Anticipated Transients Without Scram	0.53

TABLE 2
INITIATING EVENTS CONTRIBUTING TO CORE DAMAGE
(Base Case - At Power)

INITIATING EVENT	CORE DAMAGE FREQUENCY (Events per Year)	PERCENTAGE OF TOTAL
Transients (except LOOP):		
Turbine/reactor trip (TT)	4.3E-8	12.8
Others	2.9E-8	8.9
LOOP (TE)	3.0E-9	0.9
Small LOCA (S2)	2.3E-8	6.9
Very small LOCA (S2S)	1.2E-8	3.5
Reactor coolant system leak (SL)	1.6E-9	0.5
PRHR tube rupture (S2P)	4.2E-8	12.4
Medium LOCA (S1)	1.2E-8	3.5
Safety injection line break (S1S)	7.3E-8	21.6
CMT line break (S1C)	2.7E-9	0.8
Large LOCA (A)	1.6E-8	4.7
SG tube rupture (V2)	2.6E-9	0.8
ATWS (TFA)	4.6E-8	13.8
Vessel rupture (VR)	3.0E-8	8.9
 TOTAL	 3.4E-7	 100.0

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

SEQUENCE NUMBER	PERCENT PROBABILITY	PERCENT CONTFIB	SEQUENCE DESCRIPTION	SEQUENCE IDENTIFIER
1	6.80E-08	18.89	SAFETY INJECTION LINE BREAK FAILURE OF 1 OF 1 GRAVITY	INITIATING EVENT OCCURS INJECTION LINE IEV-S1S SYS-IW1A
2	4.62E-08	12.83	LOSS OF FEEDWAT. WITHOUT SCRAM REACTOR TRIP FUNCTION FAILURE AMSAC SYSTEM FAILS	INITIATING EVENT OCCURS IEV-TFA SYS-CE SYS-AMSAC
3	3.23E-08	8.97	PASSIVE RHR TUBE RUPTURE CSLOCA AND PRI TOP EVENT NODES AUTOMATIC ADS ACT. FAILS FULL RNS FAILS TO OPERATE IN	INITIATING EVENT OCCURS FAIL RCS DEPRESSURIZ. (S2 W/PRHR & CMT INJECTION MODE (LOCA/TRANSIENT) IEV-S2P SYS-XCSP SYS-ADS SYS-RNR
4	3.06E-08	8.49	TURBINE/REACTOR TRIP /L RCS FLOW COND AND SFW AND PRT SYSTEMS FAILURE OF 2/2 CMTS FOR MANUAL ADS ACT. FAILS FULL MANUAL ADS ACTUA FAILS PART'L RCS	INITIATING EVENT OCCURS FAIL TRANSIENTS RCS DEPRESSURIZ. (TRANS W/O CMT) DEPRESSURIZATION (TRANS W/O CMT) IEV-TT SYS-XCSP SYS-CM2AB SYS-ADT SYS-ADI
5	3.00E-08	8.33	VESSEL RUPTURE	INITIATING EVENT OCCURS IEV-VR
6	2.58E-08	7.15	CLASS 2 EARLY CONTAINMENT FAILURE TO RECOVER CONTAIN. FAILURE OF IRWST WATER MAKEUP FOR	LEAK OCCURS ISOLATION IN THE LONG TERM CORE COOLING IEV FREQUENCY THE LONG TERM COOLING SYS-IEC2E SYS-CIR SYS-IWTM
7	1.51E-08	4.19	LARGE LOCA INITIATING EVENT FAILURE OF 2 OF 2 GRAVITY	OCCURS INJECTION LINES IEV-A SYS-IW2AB
8	1.40E-08	3.87	SMALL LOCA INITIATING EVENT AUTOMATIC ADS ACT. FAILS FULL AUTOMATIC ADS ACT. FAILS PARTL	OCCURS RCS DEPRESSURIZ. (S2 W/PRHR & CMT RCS DEPRESSURIZ. (S2 W/PRHR & CMT IEV-S2 SYS-ADS SYS-ADV
9	1.11E-08	3.08	LOSS OF FW TO STEAM GENERATOR COND AND SFW AND PRT SYSTEMS FAILURE OF 2/2 CMTS FOR MANUAL ADS ACT. FAILS FULL MANUAL ADS ACTUA FAILS PART'L RCS	INITIATING EVENT OCCURS FAIL TRANSIENTS RCS DEPRESSURIZ. (TRANS W/O CMT) DEPRESSURIZATION (TRANS W/O CMT) IEV-TF SYS-XCSP SYS-CM2AB SYS-ADT SYS-ADI
10	8.32E-09	2.31	TURBINE/REACTOR TRIP /L RCS FLOW COND AND SFW AND PRT SYSTEMS AUTOMATIC ADS ACT. FAILS FULL RNS FAILS TO OPERATE IN	INITIATING EVENT OCCURS FAIL RCS DEPRESSURIZ. (TRANS WITH CMT) INJECTION MODE (LOCA/TRANSIENT) IEV-TT SYS-XCSP SYS-ADA SYS-RNR
11	6.62E-09	1.84	CONSEQUENTIAL SG TUBE RUPTURE	INITIATING EVENT OCCURS SYS-IECV2

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

		DELETE NON-AUTOMATIC ADS AUTOMATIC ADS	SENSICAL CUTSETS FROM V2 ACT. FAILS FULL RCS DEPRESSURIZ. ACT. FAILS PARTL RCS DEPRESSURIZ.	SEQUENCES (S2 W/PRHR & CMT) (S2 W/PRHR & CMT)	DEL-V2DEL SYS-ADS SYS-ADV
12	6.13E-09	1.70 MEDIUM LOCA RNS FAILS TO AUTOMATIC ADS	INITIATING EVENT OCCURS OPERATE IN INJECTION MODE ACT. FAILS FULL RCS DEPRESSURIZ.	(LOCA/TRANSIENT) (S1 WITH CMT)	IEV-S1 SYS-RNR SYS-ADM
13	5.44E-09	1.51 MEDIUM LOCA RNS FAILS TO FAILURE OF	INITIATING EVENT OCCURS OPERATE IN INJECTION MODE 2 OF 2 GRAVITY INJECTION LINES	(LOCA/TRANSIENT)	IEV-S1 SYS-RNR SYS-IW2AB
14	5.33E-09	1.48 VERY SMALL LOCA RNS FAILS TO FAILURE OF	INITIATING EVENT OCCURS OPERATE IN INJECTION MODE 2 OF 2 GRAVITY INJECTION LINES	(LOCA/TRANSIENT)	IEV-S2S SYS-RNR SYS-IW2AB
15	5.23E-09	1.45 PASSIVE RHR TUBE RUPTURE ADV EVENT TREE NODE IS	INITIATING EVENT OCCURS SUCCESSFUL	(AUTO DEPRESS.)	IEV-S2P DEL-ADV

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

NUMBER	SEQUENCE PROBABILITY	PERCENT CONTRIB	SEQUENCE DESCRIPTION	SEQUENCE IDENTIFIER	
			PRI AND RNR AUTOMATIC ADS	TOP EVENT NODES FAIL ACT. FAILS FULL RCS DEPRESSURIZ. (S2 W/PRHR & CMT)	SYS-XPRI RNR SYS-ADS
16	5.04E-09	1.40	SMALL LOCA RNS FAILS TO FAILURE OF	INITIATING EVENT OCCURS OPERATE IN INJECTION MODE (LOCA/TRANSIENT) 2 OF 2 GRAVITY INJECTION LINES	IEV-S2 SYS-RNR SYS-IW2AB
17	3.55E-09	.98	VERY SMALL LOCA CVCS MAKE-UP AUTOMATIC ADS RNS FAILS TO	INITIATING EVENT OCCURS FAILS DURING S2S/S2P (VERY SMALL LOCA) ACT. FAILS FULL RCS DEPRESSURIZ. (S2 W/PRHR & CMT) OPERATE IN INJECTION MODE (LOCA/TRANSIENT)	IEV-S2S SYS-CSLOCA SYS-ADS SYS-RNR
18	3.49E-09	.97	SAFETY INJECTION AUTOMATIC ADS	LINE BREAK ACT. FAILS FULL RCS DEPRESSURIZ. (S1 WITH CMT)	IEV-S1S SYS-ADM
19	3.01E-09	.84	LOSS OF FW TO COND AND SFW AUTOMATIC ADS RNS FAILS TO	STEAM GENERATOR AND PRT SYSTEMS ACT. FAILS FULL OPERATE IN INJECTION MODE (LOCA/TRANSIENT)	IEV-TF SYS-XCSP SYS-ADA SYS-RNR
20	2.57E-09	.71	PASSIVE RHR TUBE PRI AND RNR FAILURE OF	RUPTURE TOP EVENT NODES FAIL 2 OF 2 GRAVITY INJECTION LINES	IEV-S2P SYS-XPRI RNR SYS-IW2AB
21	2.39E-09	.66	STEAM GENERATOR DELETE NON- SGTR CONTINUES AUTOMATIC ADS AUTOMATIC ADS	TUBE RUPTURE SENSICAL CUTSETS FROM V2 ACT. FAILS FULL RCS DEPRESSURIZ. (S2 W/PRHR & CMT) ACT. FAILS PARTL RCS DEPRESSURIZ. (S2 W/PRHR & CMT)	IEV-V2 DEL-V2DEL SYS-V2CONT SYS-ADS SYS-ADV
22	2.13E-09	.59	CONSEQUENTIAL FAILURE OF THE FAULURE OF 2/2 MANUAL ADS MANUAL ADS ACTUA	MSL SV STUCK PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (TRANS) CMTS FOR SMALL LOCAS ACT. FAILS FULL FAILS PART'L RCS RCS DEPRESSURIZ. (TRANS W/O CMT) DEPRESSURIZATION (TRANS W/O CMT)	SYS-IECTSOV SYS-PRT SYS-CH2SL SYS-ADT SYS-ADI
23	1.73E-09	.48	SMALL LOCA FAILURE TO MANUAL ADS ACTUA MANUAL ADS ACT	INITIATING EVENT OCCURS TRIP ALL FOUR RCS PUMPS FAILS FULL RCS DEPRESSUR. SLOCA W/PRHR, W/O CMT) FAILS PARTL RCS DEPRESSUR. (S2 W/PRHR W/O CMT)	IEV-S2 SYS-RCSL SYS-ADN SYS-ADZ
24	1.41E-09	.39	CMT LINE BREAK RNS FAILS TO AUTOMATIC ADS	INITIATING EVENT OCCURS OPERATE IN INJECTION MODE (LOCA/TRANSIENT) ACT. FAILS FULL RCS DEPRESSURIZ. (S1 WITH CMT)	IEV-S1C SYS-RNR SYS-ADM
25	1.25E-09	.35	CMT LINE BREAK	INITIATING EVENT OCCURS	IEV-S1C

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

		RNS FAILS TO FAILURE OF	OPERATE IN 2 OF 2 GRAVITY	INJECTION MODE INJECTION LINES	(LOCA/TRANSIENT)	SYS-RNR SYS-IW2AB
26	1.19E-09	.33 SMALL LOCA FAILURE OF 2/2 MANUAL ADS ACTUA MANUAL ADS ACT.	INITIATING EVENT OCCURS CMTS FOR SMALL FAILS FULL RCS FAILS PARTL RCS	LOCAS DEPRESSUR. SLOCA W/PRHR, W/O CMT) DEPRESSUR. (S; W/PRHR W/O CMT)		IEV-S2 SYS-CM2SL SYS-ADN SYS-ADZ
27	1.19E-09	.33 SPURIOUS "S" SFW AND PRT FAILURE TO MANUAL ADS MANUAL ADS ACTUA	SIGNAL SYSTEMS FAIL TRIP ALL FOUR ACT. FAILS FULL FAILS PART'L RCS	INITIATING EVENT OCCURS RCS PUMPS RCS DEPRESSURIZ. (TRANS W/O CMT) DEPRESSURIZATION (TRANS W/O CMT)		IEV-TS SYS-XWF SYS-RCSL SYS-ADT SYS-AD1
28	1.18E-09	.33 SECONDARY TO COND AND SFW FAILURE OF 2/2	PRIMARY SIDE AND PRT SYSTEMS CMTS FOR	POWER MISMATCH FAIL TRANSIENTS	IN. EVENT OCCURS	IEV-TM SYS-XCSP SYS-CM2AB

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

NUMBER	SEQUENCE PROBABILITY	PERCENT CONTRIB	SEQUENCE DESCRIPTION	SEQUENCE IDENTIFIER
			MANUAL ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS W/O CMT)	SYS-ADT
			MANUAL ADS ACTUA FAILS PART'L RCS DEPRESSURIZATION (TRANS W/O CMT)	SYS-ADI
29	1.16E-09	.32	VERY SMALL LOCA INITIATING EVENT OCCURS CVCS MAKE-UP FAILS DURING S2S/S2P (VERY SMALL LOCA) FAILURE TO TRIP ALL FOUR RCS PUMPS MANUAL ADS ACTUA FAILS FULL RCS DEPRESSUR. SLOCA W/PRHR, W/O CMT) MANUAL ADS ACT. FAILS PARTL RCS DEPRESSUR. (S2 W/PRHR W/O CMT)	IEV-S2S SYS-CSLOCA SYS-RCSL SYS-ADN SYS-ADZ
30	1.11E-09	.31	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS GRID IS NOT RECOVERED WITHIN 30 MINUTES FOLLOWING LOSP FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (LOSP) FAILURE OF SFW TO SUPPLY SG A FROM CST - NO DST FAULURE OF 2/2 CMTS FOR TE MANUAL ADS ACTUA FAILS FULL RCSL DEPRESSURIZATION (TE W/O CMT) MANUAL ADS ACT. FAILS PARTL RCS DEPRESSURIZ. (TE W/O CMT)	IEV-TE OTH-RO5 SYS-PRP SYS-SFWP SYS-CM2P SYS-ADL SYS-ADR
31	9.07E-10	.25	LOSS OF COMPRES AIR SYSTEM INITIATING EVENT OCCURS FAILURE OF 2/2 SFW TRAINS -NO INSTRUMENT AIR- FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (TRANS) FAILURE OF 2/2 CMTS FOR TRANSIENTS MANUAL ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS W/O CMT) MANUAL ADS ACTUA FAILS PART'L RCS DEPRESSURIZATION (TRANS W/O CMT)	IEV-TCA SYS-SFM SYS-PRT SYS-CM2AB SYS-ADT SYS-ADI
32	8.34E-10	.23	IEV-SL OTH-CVCSFIX AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (S2 W/PRHR & CMT) AUTOMATIC ADS ACT. FAILS PARTL RCS DEPRESSURIZ. (S2 W/PRHR & CMT)	IEV-SL OTH-CVCSFIX SYS-ADS SYS-ADV
33	8.30E-10	.23	SECONDARY TO PRIMARY SIDE POWER MISMATCH IN. EVENT OCCURS STEAM DUMP AND MAIN CONDENSOR AVAILABLE FRACTION OF POWER MISMATCH EVENTS IN WHICH SFW IS ALSO LOST FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (TRANS) FAILURE OF 2/2 CMTS FOR TRANSIENTS MANUAL ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS W/O CMT) MANUAL ADS ACTUA FAILS PART'L RCS DEPRESSURIZATION (TRANS W/O CMT)	IEV-TM DEL-COND OTH-VAL3 SYS-PRT SYS-CM2AB SYS-ADT SYS-ADI
34	8.24E-10	.23	SPURIOUS "S" SIGNAL INITIATING EVENT OCCURS FRACTION OF SPURIOUS S SIGN. EVENTS IN WHICH SFW IS ALSO LOST FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (TRANS) FAULURE OF 2/2 CMTS FOR LOCAS MANUAL ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS W/O CMT) MANUAL ADS ACTUA FAILS PART'L RCS DEPRESSURIZATION (TRANS W/O CMT)	IEV-TS OTH-VAL4 SYS-PRT SYS-CM2L SYS-ADT SYS-ADI
35	7.14E-10	.20	PASSIVE RHR TUBE RUPTURE INITIATING EVENT OCCURS ADZ EVENT TREE MODE IS SUCCESSFUL (AUTO DEPRESS.)	IEV-S2P DEL-ADZ

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

		FAILURE TO PRHR ISOLATION MANUAL ADS ACTUA	TRIP ALL FOUR FAILURE FOLLOW. FAILS FULL RCS	RCS PUMPS PRHR TUBE RUPT. DEPRESSUR. SLOCA	CVS UNAVAILABLE W/PRHR, W/O CMT)	SYS-RCSL SYS-PRI1 SYS-ADN
		RNS FAILS TO	OPERATE IN	INJECTION MODE	(LOCA/TRANSIENT)	SYS-RNR
36	6.88E-10	.19 VERY SMALL LOCA ADV EVENT TREE AUTOMATIC ADS RNS FAILS TO	INITIATING EVENT MODE IS ACT. FAILS FULL OPERATE IN	OCCURS SUCCESSFUL RCS DEPRESSURIZ. INJECTION MODE	(AUTO DEPRESS) (S2 W/PRHR & CMT (LOCA/TRANSIENT)	IEV-S2S DEL-ADV SYS-ADS SYS-RNR
37	6.64E-10	.18 CONSEQUENTIAL FAILURE OF RNS FAILS TO	SG TUBE RUPTURE 2 OF 2 GRAVITY OPERATE IN	INITIATING EVENT INJECTION LINES INJECTION MODE	OCCURS (LOCA/TRANSIENT)	SYS-IECV2 SYS-IW2AB SYS-RNR
38	6.50E-10	.18 SMALL LOCA AUTOMATIC ADS RNS FAILS TO	INITIATING EVENT ACT. FAILS FULL OPERATE IN	OCCURS RCS DEPRESSURIZ. INJECTION MODE	(S2 W/PRHR & CMT (LOCA/TRANSIENT)	IEV-S2 SYS-ADS SYS-RNR

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

NUMBER	SEQUENCE PROBABILITY	PERCENT CONTRIB	SEQUENCE DESCRIPTION	SEQUENCE IDENTIFIER
39	6.43E-10	.18	LOSS OF SERVICE WATER SYSTEM SFW AND PRT SYSTEMS FAIL FAILURE OF 2/2 CMTS FOR TRANSIENTS MANUAL ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS W/O CMT)	IEV-TSW SYS-XWP SYS-CM2AB SYS-ADT
40	6.18E-10	.17	SPOURIOUS "S" SIGNAL SFW AND PRT SYSTEMS FAIL AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS WITH CMT) AUTOMATIC ADS ACT. FAILS PART' RCS DEPRESSURIZ. (TRANS WITH CMT)	IEV-TS SYS-XWP SYS-ADA SYS-ADIA
41	5.82E-10	.16	VERY SMALL LOCA INITIATING EVENT OCCURS CVCS MAKE-UP FAILS DURING S2S/S2P (VERY SMALL LOCA) AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (S2 W/PRHR & CMT) AUTOMATIC ADS ACT. FAILS PARTL RCS DEPRESSURIZ. (S2 W/PRHR & CMT)	IEV-S2S SYS-CSLOCA SYS-ADS SYS-ADV
42	5.80E-10	.16	LOSS OF OFFSITE POWER GRID IS NOT RECOVERED WITHIN 30 MINUTES FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (LOSP) FAILURE OF SFW TO SUPPLY SG A FROM CST - NO DST AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (LOSP WITH CMT) AUTOMATIC ADS ACT. FAILS PARTL RCS DEPRESSURIZ. (TE WITH CMT)	IEV-TE OTH-R05 SYS-PRP SYS-SFWP SYS-ADAL SYS-ADRA
43	5.38E-10	.15	TURBINE/REACTOR TRIP /L RCS FLOW INITIATING EVENT OCCURS STEAM DUMP AND MAIN CONDENSOR AVAILABLE FWT AND SFWTD AND PRT SYSTEMS FAIL FAILURE OF 2/2 CMTS FOR TRANSIENTS MANUAL ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS W/O CMT) MANUAL ADS ACTUA FAILS PART'L RCS DEPRESSURIZATION (TRANS W/O CMT)	IEV-TT DEL-COND SYS-XFSP SYS-CM2AB SYS-ADT SYS-ADI
44	5.22E-10	.14	CONSEQUENTIAL MSL SV STUCK OPEN INITIATING EVENT OCCURS FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (TRANS) AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS WITH CMT) AUTOMATIC ADS ACT. FAILS PART' RCS DEPRESSURIZ. (TRANS WITH CMT)	SYS-IECTSOV SYS-PRT SYS-ADA SYS-ADIA
45	3.54E-10	.10	CONSEQUENTIAL MEDIUM LOCA INITIATING EVENT OCCURS RNS FAILS TO OPERATE IN INJECTION MODE (LOCA/TRANSIENT) AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (S1 WITH CMT)	SYS-IECS1 SYS-RNR SYS-ADM
46	3.53E-10	.10	CONSEQUENTIAL MEDIUM LOCA INITIATING EVENT OCCURS RNS FAILS TO OPERATE IN INJECTION MODE (LOCA/TRANSIENT) FAILURE OF 2 OF 2 GRAVITY INJECTION LINES	SYS-IECS1 SYS-RNR SYS-IW2AB
47	3.19E-10	.09	SECONDARY TO PRIMARY SIDE POWER MISMATCH IN. EVENT OCCURS COND AND SFW AND PRT SYSTEMS FAIL AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS WITH CMT)	IEV-TM SYS-XCSP SYS-ADA

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

		RNS FAILS TO	OPERATE IN	INJECTION MODE (LOCA/TRANSIENT)	SYS-RNR
48	3.06E-10	.08 LOSS OF FW TO	STEAM GENERATOR	INITIATING EVENT OCCURS	IEV-TF
		FRACTION OF LOSS OF FW EVENTS IN WHICH CONDENSOR IS ALSO LOST			OTH-VAL2
		SFW AND PRT SYSTEMS FAIL			SYS-XWP
		FAILURE OF 2/2 CMTS FOR TRANSIENTS			SYS-CM2AB
		MANUAL ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS W/O CMT)			SYS-ADT
		MANUAL ADS ACTUA FAILS PART'L RCS DEPRESSURIZATION (TRANS W/O CMT)			SYS-AD1
49	2.92E-10	.08 LOSS OF COMPONE. COOLING SYSTEM INITIATING EVENT OCCURS			IEV-TCW
		COND AND SFW AND PRT SYSTEMS FAIL			SYS-XCSP
		FAILURE OF 2/2 CMTS FOR TRANSIENTS			SYS-CM2AB
		MANUAL ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS W/O CMT)			SYS-ADT
50	2.91E-10	.08 IEV-SL			IEV-SL
		OTH-CVCSFIX			OTH-CVCSFIX
		RNS FAILS TO OPERATE IN INJECTION MODE (LOCA/TRANSIENT)			SYS-RNR
		FAILURE OF 2 OF 2 GRAVITY INJECTION LINES			SYS-IW2AB

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

NUMBER	SEQUENCE PROBABILITY	PERCENT CONTRIB	SEQUENCE DESCRIPTION	SEQUENCE IDENTIFIER
51	2.85E-10	.08	SPURIOUS "S" SIGNAL INITIATING EVENT OCCURS SFW AND PRT SYSTEMS FAIL FAILURE OF 2/2 CMTS FOR LOCAS MANUAL ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS W/O CMT) MANUAL ADS ACTUA FAILS PART'L RCS DEPRESSURIZATION (TRANS W/O CMT)	IEV-TS SYS-XWP SYS-CH2L SYS-ADT SYS-AD1
52	2.71E-10	.08	PASSIVE RHR TUBE RUPTURE INITIATING EVENT OCCURS CSLOCA AND PRII TOP EVENT MODES FAIL AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (S2 W/PRHR & CMT) AUTOMATIC ADS ACT. FAILS PART'L RCS DEPRESSURIZ. (S2 W/PRHR & CMT)	IEV-S2P SYS-XCSLPRI1 SYS-ADS SYS-ADV
53	2.59E-10	.07	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS COMMON CAUSE FAILURE BATTERY FAILURE OF PRHR TO REMOVE DECAY HEAT FROM RPV (ATWS)	IEV-TE CCX-BY-PN SYS-PRW
54	2.55E-10	.07	IEV-SL TRIP ALL FOUR RCS PUMPS FAILURE TO MANUAL ADS ACTUA FAILS FULL RCS DEPRESSUR. SLOCA W/PRHR, W/O CMT) MANUAL ADS ACT. FAILS PARTL RCS DEPRESSUR. (S2 W/PRHR W/O CMT)	IEV-SL SYS-RCSL SYS-ADN SYS-ADZ
55	2.52E-10	.07	CONSEQUENTIAL SC TUBE RUPTURE INITIATING EVENT OCCURS FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (S2) FAILURE OF 2/2 CMTS FOR SMALL LOCAS RNS FAILS TO OPERATE IN INJECTION MODE (LOCA/TRANSIENT)	SYS-IECV2 SYS-PRL SYS-CH2SL SYS-RNR
56	2.47E-10	.07	MAIN STEAMLINE SV STUCK OPEN INITIATING EVENT OCCURS FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (TRANS) FAILURE OF 2/2 CMTS FOR SMALL LOCAS MANUAL ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS W/O CMT) MANUAL ADS ACTUA FAILS PART'L RCS DEPRESSURIZATION (TRANS W/O CMT)	IEV-TSOV SYS-PRT SYS-CH2SL SYS-ADT SYS-AD1
57	2.27E-10	.06	LOSS OF COMPRES. AIR SYSTEM INITIATING EVENT OCCURS FAILURE OF 2/2 SFW TRAINS -NO INSTRUMENT AIR- FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (TRANS) AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS WITH CMT) AUTOMATIC ADS ACT. FAILS PART' RCS DEPRESSURIZ. (TRANS WITH CMT)	IEV-TCA SYS-SFM SYS-PRT SYS-ADA SYS-AD1A
58	2.20E-10	.06	CONSEQUENTIAL SC TUBE RUPTURE INITIATING EVENT OCCURS DELETE NON- SENSICAL CUTSETS FROM V2 SEQUENCES FAILURE TO TRIP ALL FOUR RCS PUMPS MANUAL ADS ACTUA FAILS FULL RCS DEPRESSUR. SLOCA W/PRHR, W/O CMT) MANUAL ADS ACT. FAILS PARTL RCS DEPRESSUR. (S2 W/PRHR W/O CMT)	SYS-IECV2 DEL-V2DEL SYS-RCSL SYS-ADN SYS-ADZ
59	1.95E-10	.05	SECONDARY TO PRIMARY SIDE POWER MISMATCH IN. EVENT OCCURS STEAM DUMP AND MAIN CONDENSOR AVAILABLE	IEV-TM DEL-COND

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

	FRACTION OF FAILURE OF THE AUTOMATIC ADS	POWER MISMATCH PRHR SYSTEM TO ACT. FAILS FULL	EVENTS IN WHICH REMOVE DEC. HEAT FROM RPV (TRANS) RCS DEPRESSURIZ. (TRANS WITH CMT)	SFW IS ALSO LOST (TRANS WITH CMT)	OTH-VAL3 SYS-PRT SYS-ADA
		AUTOMATIC ADS	ACT. FAILS PART'	RCS DEPRESSURIZ. (TRANS WITH CMT)	SYS-AD1A
60	1.95E-10	.05 TURBINE/REACTOR COND AND SFW AUTOMATIC ADS AUTOMATIC ADS	TRIP /L.RCS FLOW AND PRT SYSTEMS ACT FAILS FULL ACT. FAILS PART'	INITIATING EVENT OCCURS RCS DEPRESSURIZ. (TRANS WITH CMT) RCS DEPRESSURIZ. (TRANS WITH CMT)	IEV-TT SYS-XCSP SYS-ADA SYS-AD1A
61	1.95E-10	.05 SPURIOUS "S" FFACTION OF FAILURE OF THE AUTOMATIC ADS AUTOMATIC ADS	SIGNAL SPURIOUS S SIGN. PRHR SYSTEM TO ACT. FAILS FULL ACT. FAILS PART'	INITIATING EVENT OCCURS EVENT. IN WHICH SFW IS ALSO LOST REMOVE DEC. HEAT FROM RPV (TRANS) RCS DEPRESSURIZ. (TRANS WITH CMT) RCS DEPRESSURIZ. (TRANS WITH CMT)	IEV-TS OTH-VAL4 SYS-PRT SYS-ADA SYS-AD1A
62	1.90E-10	.05 PASSIVE RHR TUBE CSLOCA AND PRI1	RUPTURE TOP EVENT NODES	INITIATING EVENT OCCURS FAIL	IEV-S2P SYS-XCSLPRI1

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

NUMBER	SEQUENCE PROBABILITY	PERCENT CONTRIB	SEQUENCE DESCRIPTION	SEQUENCE IDENTIFIER	
			FAULURE OF 2/2 CMTS FOR SMALL MANUAL ADS ACTUA FAILS FULL RCS MANUAL ADS ACT. FAILS PARTL RCS	LOCAS DEPRESSUR. SLOCA W/PRHR, W/O CMT) DEPRESSUR. (S2 W/PRHR W/O CMT)	SYS-CM2SL SYS-ADN SYS-ADZ
63	1.85E-10	.05	STEAM GENERATOR TUBE RUPTURE SGTR CONTINUES FAULURE OF 2/2 CMTS FOR SMALL MANUAL ADS ACTUA FAILS FULL RCS MANUAL ADS ACT. FAILS PARTL RCS	INITIATING EVENT OCCURS LOCAS DEPRESSUR. SLOCA W/PRHR, W/O CMT) DEPRESSUR. (S2 W/PRHR W/O CMT)	IEV-V2 SYS-V2CONT SYS-CM2SL SYS-ADN SYS-ADZ
64	1.76E-10	.05	CONSEQUENTIAL SG TUBE RUPTURE FAULURE OF 2/2 CMTS FOR SMALL MANUAL ADS ACTUA FAILS FULL RCS MANUAL ADS ACT. FAILS PARTL RCS	INITIATING EVENT OCCURS LOCAS DEPRESSUR. SLOCA W/PRHR, W/O CMT) DEPRESSUR. (S2 W/PRHR W/O CMT)	SYS-IECV2 SYS-CM2SL SYS-ADN SYS-ADZ
65	1.73E-10	.05	LOSS OF SERVICE WATER SYSTEM SFW AND PRT SYSTEMS FAIL AUTOMATIC ADS ACT. FAILS FULL	INITIATING EVENT OCCURS RCS DEPRESSURIZ. (TRANS WITH CMT)	IEV-TSW SYS-XWP SYS-ADA
66	1.70E-10	.05	LOSS OF FW TO STEAM GENERATOR FRACTION OF LOSS OF FW EVENTS IN STEAM DUMP AND MAIN CONDENSOR AND PRT SYSTEMS FAIL FAILURE OF 2/2 CMTS FOR MANUAL ADS ACT. FAILS FULL MANUAL ADS ACTUA FAILS PART'L RCS	INITIATING EVENT OCCURS WHICH CONDENSOR IS AVAILABLE AVAILABLE FAIL TRANSIENTS RCS DEPRESSURIZ. (TRANS W/O CMT) DEPRESSURIZATION (TRANS W/O CMT)	IEV-TF SUC-VAL2 DEL-COND SYS-KWSP SYS-CM2AB SYS-ADT SYS-AD1
67	1.47E-10	.04	IEV-SL FAULURE OF 2/2 CMTS FOR SMALL MANUAL ADS ACTUA FAILS FULL RCS MANUAL ADS ACT. FAILS PARTL RCS	LOCAS DEPRESSUR. SLOCA W/PRHR, W/O CMT) DEPRESSUR. (S2 W/PRHR W/O CMT)	IEV-SL SYS-CM2SL SYS-ADN SYS-ADZ
68	1.34E-10	.04	PASSIVE RHR TUBE RUPTURE CSLOCA AND PRII TOP EVENT NODES FAULURE OF 2/2 CMTS FOR SMALL MANUAL ADS ACTUA FAILS FULL RCS RNS FAILS TO OPERATE IN	INITIATING EVENT OCCURS FAIL LOCAS DEPRESSUR. SLOCA W/PRHR, W/O CMT) INJECTION MODE (LOCA/TRANSIENT)	IEV-S2P SYS-KCSLPR11 SYS-CM2SL SYS-ADN SYS-RNR
69	1.28E-10	.04	LOSS OF FW TO STEAM GENERATOR FRACTION OF LOSS OF FW EVENTS IN STEAM DUMP AND MAIN CONDENSOR FRACTION OF LOSS OF FW WITH BOTH SFW AND PRT SYSTEMS FAIL FAILURE OF 2/2 CMTS FOR MANUAL ADS ACT. FAILS FULL MANUAL ADS ACTUA FAILS PART'L RCS	INITIATING EVENT OCCURS WHICH CONDENSOR IS AVAILABLE AVAILABLE FW PUMPS LOST TRANSIENTS RCS DEPRESSURIZ. (TRANS W/O CMT) DEPRESSURIZATION (TRANS W/O CMT)	IEV-TF SUC-VAL2 DEL-COND OTH-VAL1 SYS-XSP SYS-CM2AB SYS-ADT SYS-AD1

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

70	1.13E-10	.03	VERY SMALL LOCA ADZ EVENT TREE	INITIATING EVENT NODE IS	OCCURS SUCCESSFUL	(AUTO DEPRESS.)	IEV-S2S DEL-ADZ
			FAILURE TO MANUAL ADS ACTUA RNS FAILS TO	TRIP ALL FOUR FAILS FULL RCS OPERATE IN	RCS PUMPS DEPRESSUR. SLOCA W/PRHR, W/O CMT) INJECTION MODE (LOCA/TRANSIENT)		SYS-RCSL SYS-ADN SYS-RNR
71	1.07E-10	.03	SMALL LOCA FAILURE TO MANUAL ADS ACTUA RNS FAILS TO	INITIATING EVENT TRIP ALL FOUR FAILS FULL RCS OPERATE IN	OCCURS RCS PUMPS DEPRESSUR. SLOCA W/PRHR, W/O CMT) INJECTION MODE (LOCA/TRANSIENT)		IEV-S2 SYS-RCSL SYS-ADN SYS-RNR
72	9.86E-11	.03	PASSIVE RHR TUBE CSLOCA AND PRI1 FAILURE TO MANUAL ADS ACTUA RNS FAILS TO	RUPTURE TOP EVENT MODES TRIP ALL FOUR FAILS FULL RCS OPERATE IN	INITIATING EVENT OCCURS FAIL RCS PUMPS DEPRESSUR. SLOCA W/PRHR, W/O CMT) INJECTION MODE (LOCA/TRANSIENT)		IEV-S2P SYS-XCSLPR11 SYS-RCSL SYS-ADN SYS-RNR

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

NUMBER	SEQUENCE PROBABILITY	PERCENT CONTRIB	SEQUENCE DESCRIPTION	SEQUENCE IDENTIFIER
73	9.35E-11	.03	TURBINE/REACTOR TRIP /L RCS FLOW INITIATING EVENT OCCURS STEAM DUMP AND MAIN CONDENSOR AVAILABLE FWT AND SFWD AND PRT SYSTEMS FAIL AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS WITH CMT) AUTOMATIC ADS ACT. FAILS PART' RCS DEPRESSURIZ. (TRANS WITH CMT)	IEV-TT DEL-COND SYS-XFSP SYS-ADA SYS-ADIA
74	9.31E-11	.03	VERY SMALL LOCA INITIATING EVENT OCCURS FAULURE OF 2/2 CMTS FOR SMALL LOCAS FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (TRANS) MANUAL ADS ACT. FAILS FULL RCS DEPRESUR. S2 W/O PRHR & CMT) MANUAL ADS ACT. FAILS PARTL RCS DEPRESSURIZ. (S2 W/O PRHR/CMT)	IEV-S2S SYS-CM2SL SYS-PRT SYS-ADC SYS-ADY
75	9.17E-11	.03	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS GRID IS NOT RECOVERED WITHIN 30 MINUTES FOLLOWING LOSP GRID IS NOT RECOVERED WITHIN 24 HOURS FOLLOW- ING LOSP FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (S.B) FAULURE OF 2/2 CMTS FOR TE MANUAL ADS ACT. FAILS FULL RCS DEPRESSURIZ. (BLKOUT W/O CMT)	IEV-TE OTH-R05 OTH-R24 SYS-PRB SYS-CM2P SYS-ADB
76	8.10E-11	.02	LOSS OF COMPONE. COOLING SYSTEM INITIATING EVENT OCCURS COND AND SFW AND PRT SYSTEMS FAIL AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS WITH CMT)	IEV-TCW SYS-XCSP SYS-ADA
77	7.53E-11	.02	LOSS OF FW TO STEAM GENERATOR INITIATING EVENT OCCURS COND AND SFW AND PRT SYSTEMS FAIL AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS WITH CMT) AUTOMATIC ADS ACT. FAILS PART' RCS DEPRESSURIZ. (TRANS WITH CMT)	IEV-TF SYS-XCSP SYS-ADA SYS-ADIA
78	7.51E-11	.02	MAIN STEAMLINE BREAK U/MSIV INITIATING EVENT OCCURS FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (TRANS) FAULURE OF 2/2 CMTS FOR SMALL LOCAS MANUAL ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS W/O CMT) MANUAL ADS ACTUA FAILS PART'L RCS DEPRESSURIZATION (TRANS W/O CMT)	IEV-TSLU SYS-PRT SYS-CM2SL SYS-ADT SYS-ADI
79	7.11E-11	.02	MEDIUM LOCA INITIATING EVENT OCCURS RNS FAILS TO OPERATE IN INJECTION MODE (LOCA/TRANSIENT) FAILURE OF RECIRCULATION	IEV-S1 SYS-RNR SYS-RECIRC
80	6.77E-11	.02	SAFETY INJECTION LINE BREAK INITIATING EVENT OCCURS FAILURE OF 1/1 CMTS MANUAL ADS ACT. FAILS FULL RCS DEPRESSURIZATION (S1 W/O CMT)	IEV-S1S SYS-CM1A SYS-ADQ
81	6.77E-11	.02	VERY SMALL LOCA INITIATING EVENT OCCURS RNS FAILS TO OPERATE IN INJECTION MODE (LOCA/TRANSIENT) FAILURE OF RECIRCULATION	IEV-S2S SYS-RNR SYS-RECIRC

TABLE 3
 DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

82	4.75E-11	.02	LOSS OF FW TO FRACTION OF LOSS	STEAM GENERATOR OF FW EVENTS IN	INITIATING EVENT OCCURS WHICH CONDENSOR IS ALSO LOST	IEV-TF OTH-VAL2
			SFW AND PRT AUTOMATIC ADS	SYSTEMS FAIL ACT. FAILS FULL	RCS DEPRESSURIZ. (TRANS WITH CMT)	SYS-KWP SYS-ADA
			AUTOMATIC ADS	ACT. FAILS PART'	RCS DEPRESSURIZ. (TRANS WITH CMT)	SYS-ADIA
83	6.40E-11	.02	SMALL LOCA RNS FAILS TO FAILURE OF	INITIATING EVENT OCCURS OPERATE IN RECIRCULATION	INJECTION MODE (LOCA/TRANSIENT)	IEV-S2 SYS-RHR SYS-RECIRC
84	5.88E-11	.02	MAIN STEAMLINE FAILURE OF THE AUTOMATIC ADS	SV STUCK OPEN PRHR SYSTEM TO ACT. FAILS FULL	INITIATING EVENT OCCURS REMOVE DEC. HEAT FROM RPV (TRANS) RCS DEPRESSURIZ. (TRANS WITH CMT)	IEV-TSOV SYS-PRT SYS-ADA
			AUTOMATIC ADS	ACT. FAILS PART'	RCS DEPRESSURIZ. (TRANS WITH CMT)	SYS-ADIA
85	5.12E-11	.01	SECONDARY TO STEAM DUMP AND	PRIMARY SIDE MAIN CONDENSOR	POWER MISMATCH IN. EVENT OCCURS AVAILABLE	IEV-TM DEL-COND

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

NUMBER	SEQUENCE PROBABILITY	PERCENT CONTRIB	SEQUENCE DESCRIPTION	SEQUENCE IDENTIFIER
			SFWT AND PRT SYSTEMS FAIL	SYS-XSP
			FAILURE OF 2/2 CMTS FOR TRANSIENTS	SYS-CM2AB
			MANUAL ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS W/O CMT)	SYS-ADT
			MANUAL ADS ACTUA FAILS PART'L RCS DEPRESSURIZATION (TRANS W/O CMT)	SYS-ADI
86	5.05E-11	.01	CONSEQUENTIAL SG TUBE RUPTURE INITIATING EVENT OCCURS DELETE NON-SENSICAL CUTSETS FROM V2 SEQUENCES AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (S2 W/PRHR & CMT) RNS FAILS TO OPERATE IN INJECTION MODE (LOCA/TRANSIENT)	SYS-IECV2 DEL-V2DEL SYS-ADS SYS-RNR
87	4.24E-11	.01	VERY SMALL LOCA INITIATING EVENT OCCURS FAILURE TO TRIP ALL FOUR RCS PUMPS FAILURE OF 2 OF 2 ACCUMULATORS	IEV-S2S SYS-RCSL AC2AB-FAILS
88	4.02E-11	.01	SMALL LOCA INITIATING EVENT OCCURS FAILURE TO TRIP ALL FOUR RCS PUMPS FAILURE OF 2 OF 2 ACCUMULATORS	IEV-S2 SYS-RCSL AC2AB-FAILS
89	3.82E-11	.01	LOSS OF FEEDWAT. WITHOUT SCRAM INITIATING EVENT OCCURS SYS-XCM OTH-M	IEV-TFA SYS-XCM OTH-M
90	3.78E-11	.01	LARGE LOCA INITIATING EVENT OCCURS FAILURE OF RECIRCULATION	IEV-A SYS-RECIRC
91	3.47E-11	.01	SMALL LOCA INITIATING EVENT OCCURS FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (S2) AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS WITH CMT) AUTOMATIC ADS ACT. FAILS PART' RCS DEPRESSURIZ. (TRANS WITH CMT)	IEV-S2 SYS-PRL SYS-ADA SYS-ADIA
92	3.38E-11	.01	LOSS OF FW TO STEAM GENERATOR INITIATING EVENT OCCURS FRACTION OF LOSS OF FW EVENTS IN WHICH CONDENSOR IS AVAILABLE STEAM DUMP AND MAIN CONDENSOR AVAILABLE FWT AND SFWT AND PRT SYSTEMS FAIL AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS WITH CMT) AUTOMATIC ADS ACT. FAILS PART' RCS DEPRESSURIZ. (TRANS WITH CMT)	IEV-TF SUC-VAL2 DEL-COND SYS-XWSP SYS-ADA SYS-ADIA
93	3.34E-11	.01	SAFETY INJECTION LINE BREAK INITIATING EVENT OCCURS FAILURE OF 1/1 CMTS FAILURE OF 1 OF 1 ACCUMULATORS	IEV-S1S SYS-CM1A AC1A-FAILS
94	3.32E-11	.01	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS GRID IS NOT RECOVERED WITHIN 30 MINUTES FOLLOWING LOSP FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (LOSP) FAILURE OF SFW TO SUPPLY SG A FROM CST - NO DST RNS FAILS TO OPERATE IN INJECTION MODE (TE)	IEV-TE OTH-R05 SYS-PRP SYS-SFWP SYS-RNP

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

95	3.10E-11	.01	FAILURE OF IEV-SL	2 OF 2 GRAVITY INJECTION LINES	SYS-IW2AB IEV-SL
96	3.03E-11	.01	OTH-CVCSFIX AUTOMATIC ADS RNS FAILS TO CONSEQUENTIAL FAILURE OF THE FAILURE OF 2/2 FAILURE OF 2 OF	ACT. FAILS FULL OPERATE IN MSL SV STUCK PRHR SYSTEM TO CMTS FOR SMALL 2 ACCUMULATORS	RCS DEPRESSURIZ. (S2 W/PRHR & CMT INJECTION MODE (LOCA/TRANSIENT) OPEN INITIATING EVENT OCCURS REMOVE DEC. HEAT FROM RPV (TRANS) LOCAS SYS-IECTSOV SYS-PRT SYS-CM2SL AC2AB-FAILS
97	2.63E-11	.01	LOSS OF FW TO FRACTION OF LOSS STEAM DUMP AND FRACTION OF LOSS SFWT AND PRT	STEAM GENERATOR OF FW EVENTS IN MAIN CONDENSOR OF FW WITH BOTH SYSTEMS FAIL	INITIATING EVENT OCCURS WHICH CONDENSOR IS AVAILABLE AVAILABLE FW PUMP LOST IEV-TF SUC-VAL2 DEL-COND OTH-VAL1 SYS-XSP

TABLE 3
DOMINANT ACCIDENT SEQUENCE CUTSETS - INCLUDES RCS LEAK EVENT

NUMBER	SEQUENCE PROBABILITY	PERCENT CONTRIB	SEQUENCE DESCRIPTION	SEQUENCE IDENTIFIER
			AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS WITH CMT)	SYS-ADA
			AUTOMATIC ADS ACT. FAILS PART' RCS DEPRESSURIZ. (TRANS WITH CMT)	SYS-ADIA
98	2.51E-11	.01	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS	IEV-TE
			GRID IS NOT RECOVERED WITHIN 30 MINUTES FOLLOWING LOSP	OTH-R05
			FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (LOSP)	SYS-PRP
			FAILURE OF SFW TO SUPPLY SC A FROM CST - NO DST	SYS-SFWP
			FAILURE OF 2/2 CMTS FOR TE	SYS-CH2P
			MANUAL ADS ACTUAL FAILS FULL RCSL DEPRESSURIZATION (TE W/O CMT)	SYS-ADL
			RNS FAILS TO OPERATE IN INJECTION MODE (TE)	SYS-RNP
99	2.40E-11	.01	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS	IEV-TE
			GRID IS NOT RECOVERED WITHIN 30 MINUTES FOLLOWING LOSP	OTH-R05
			GRID IS NOT RECOVERED WITHIN 24 HOURS FOLLOWING LOSP	OTH-R24
			FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (S.B)	SYS-PRB
			AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (BLKOUT WITH CMT)	SYS-ADAB
100	2.36E-11	.01	VERY SMALL LOCA INITIATING EVENT OCCURS	IEV-S25
			FAILURE OF THE PRHR SYSTEM TO REMOVE DEC. HEAT FROM RPV (TRANS)	SYS-PRT
			AUTOMATIC ADS ACT. FAILS FULL RCS DEPRESSURIZ. (TRANS WITH CMT)	SYS-ADA
			AUTOMATIC ADS ACT. FAILS PART' RCS DEPRESSURIZ. (TRANS WITH CMT)	SYS-ADIA

TABLE 4
INITIATING EVENT IMPORTANCES FOR RISK DECREASE MEASURE

SYSTEM UNAVAILABILITY (Q) = 3.358E-07
 NUMBER OF BASIC EVENTS = 23
 NUMBER OF CUTSETS = 9900

BASIC EVENT	IMPORTANCE (XDECREASE)	NUMBER OF CUTSETS	DECREASE IN SYSTEM UNAVAILABILITY	BASIC EVENT PROBABILITY
1 IEV-S1S	21.60	284	7.2533E-08	1.2000E-04
2 IEV-TFA	13.78	378	4.6266E-08	5.3000E-01
3 IEV-TT	12.75	705	4.2808E-08	1.4000E+00
4 IEV-S2P	12.41	1601	4.1669E-08	5.0000E-03
5 IEV-VR	8.93	1	3.0000E-08	3.0000E-08
6 IEV-S2	6.85	877	2.3013E-08	5.2000E-04
7 IEV-TF	5.42	1225	1.8184E-08	5.0570E-01
8 IEV-A	4.73	114	1.5867E-08	9.7000E-05
9 IEV-S2S	3.54	897	1.1882E-08	5.5000E-04
10 IEV-S1	3.53	960	1.1836E-08	5.6000E-04
11 IEV-TS	1.31	399	4.4149E-09	8.5000E-02
12 IEV-TE	.86	956	2.8769E-09	8.6000E-02
13 IEV-TM	.83	242	2.7726E-09	5.4000E-02
14 IEV-S1C	.81	448	2.7079E-09	1.3000E-04
15 IEV-V2	.78	123	2.6053E-09	5.2000E-05
16 IEV-SL	.47	102	1.5733E-09	6.4800E-05
17 IEV-TCA	.40	145	1.3423E-09	1.4400E-02
18 IEV-TSW	.35	176	1.1766E-09	2.6200E-02
19 IEV-TSOV	.26	132	8.6466E-10	1.2000E-03
20 IEV-TP	.21	17	7.0750E-10	4.5000E-03
21 IEV-TCW	.11	44	3.7587E-10	1.3500E-02
22 IEV-TSLU	.06	60	2.1309E-10	3.3300E-04
23 IEV-TSLD	.02	14	8.0270E-11	6.0000E-04

TABLE 4
INITIATING EVENT IMPORTANCES FOR RISK - INCREASE MEASURE

SYSTEM UNAVAILABILITY (Q) = 3.358E-07
NUMBER OF BASIC EVENTS = 23
NUMBER OF CUTSETS = 9900

BASIC EVENT	IMPORTANCE (XINCREASE)	NUMBER OF CUTSETS	INCREASE IN SYSTEM UNAVAILABILITY	BASIC EVENT PROBABILITY
1 IEV-VR	2.978244E+08	1	1.0000E+00	3.0000E-08
2 IEV-SIS	179996.	284	6.047E-04	1.2000E-04
3 IEV-A	48712.4	114	1.6376E-04	9.7000E-05
4 IEV-S2	13173.7	877	4.4233E-05	5.2000E-04
5 IEV-SL	7230.46	102	2.4278E-05	6.4800E-05
6 IEV-S2S	6430.30	897	2.1591E-05	5.5000E-04
7 IEV-S1	6291.28	960	2.1124E-05	5.6000E-04
8 IEV-S1C	6202.89	448	2.0827E-05	1.3000E-04
9 IEV-S2P	2469.57	1601	8.2920E-06	5.0000E-03
10 IEV-TSOV	214.339	132	7.1968E-07	1.2000E-03
11 IEV-TSLU	190.518	60	6.3970E-07	3.3300E-04
12 IEV-V2	148.439	123	4.9841E-07	5.2000E-03
13 IEV-TP	46.6139	17	1.5651E-07	4.5000E-03
14 IEV-TSLD	39.8200	14	1.3370E-07	6.0000E-04
15 IEV-TCA	27.3614	145	9.1871E-08	1.4400E-02
16 IEV-TM	14.4661	242	4.8573E-08	5.4000E-02
17 IEV-TS	14.1541	399	4.7525E-08	8.5000E-02
18 IEV-TSW	13.0248	176	4.3733E-08	2.6200E-02
19 IEV-TFA	12.2192	378	4.1028E-08	5.3000E-01
20 IEV-TE	9.10615	956	3.0576E-08	8.6000E-02
21 IEV-TCW	8.18007	44	2.7466E-08	1.3500E-02
22 IEV-TF	5.29349	1225	1.7774E-08	5.0570E-01

13




FIGURE 1
REACTOR COOLANT SYSTEM LEAK EVENT TREE



Westinghouse
Electric Corporation

Energy Systems

Box 355
Pittsburgh Pennsylvania 15230-0355

DCP/NRC1413
NSD-NRC-98-5757
Docket No.: 52-003

August 14, 1998

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: T. R. Quay

SUBJECT: RESPONSE TO NRC LETTERS CONCERNING REQUEST FOR WITHHOLDING INFORMATION

- Reference:
1. Letter, Sebrosky to McIntyre, "Request for withholding information from public disclosure for Westinghouse AP600 design letter of October 20, 1993," dated June 18, 1998.
 2. Letter, Sebrosky to McIntyre, "Request for withholding information from public disclosure for Westinghouse AP600 design letter of January 17, 1994," dated June 18, 1998.
 3. Letter, Sebrosky to McIntyre, "Request for withholding information from public disclosure for Westinghouse AP600 letters of September 20, 1993, January 21, 1994, and February 3, 1994," dated July 10, 1998.
 4. Letter, Sebrosky to McIntyre, "Request for withholding proprietary information for Westinghouse letters dated April 18, 1995," dated July 15, 1998.
 5. Letter, Huffman to McIntyre, "Request for withholding information from public disclosure of Westinghouse report on AP600 function based task analysis," dated July 17, 1998.

Dear Mr. Quay:

Reference 1 provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated October 20, 1993, that contained the response to a staff request for additional information regarding the AP600 probabilistic risk assessment. The NRC assessment was that the material was similar to material that exists in the current (1998) nonproprietary version of the AP600 probabilistic risk assessment (PRA) report. In addition, the staff indicated the material was used by the staff in the development of the AP600 draft safety evaluation report and therefore should remain on the docket. At the time this request for additional information response was provided to the

3790a.wpf

~~9808200168~~ App

Enclosure 2

August 14, 1998

NRC technical staff, the information was considered to be proprietary by Westinghouse since it contained information that had commercial value to Westinghouse. If this request for additional information response was indeed used by the staff in development of the AP600 draft final safety evaluation report in November 30, 1994, then at this time, almost five years later this information is no longer considered to be proprietary by Westinghouse.

Reference 2 provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated January 17, 1994, that contained the response to a staff request for additional information regarding the AP600 instrumentation and control system. The NRC assessment was that the material was similar to material that exists in the current (1998) nonproprietary version of the AP600 standard safety analysis report. In addition, the staff indicated the material was used by the staff in the development of the AP600 draft safety evaluation report and therefore should remain on the docket. At the time this request for additional information response was provided to the NRC technical staff, the information was considered to be proprietary by Westinghouse since it contained information that had commercial value to Westinghouse. If this request for additional information response was indeed used by the staff in development of the AP600 draft final safety evaluation report in November 30, 1994, then at this time, over four years later, this information is no longer considered to be proprietary by Westinghouse.

Reference 3 provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated September 20, 1993, that contained information related to the AP600 PRA and WCAP-13795, which provided the PRA uncertainty analysis. The NRC assessment was that the material was similar to material that exists in the current (1998) nonproprietary version of the AP600 probabilistic risk assessment (PRA) report. In addition, the staff indicated the material was used by the staff in the development of the AP600 draft safety evaluation report and therefore should remain on the docket. At the time this information was provided to the NRC technical staff, it was considered to be proprietary by Westinghouse since it contained information that had commercial value to Westinghouse. If the information transmitted by the Westinghouse September 20, 1993, letter was indeed used by the staff in development of the AP600 draft final safety evaluation report in November 30, 1994, then at this time, almost five years later, this information is no longer considered to be proprietary by Westinghouse.

Reference 3 also provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated January 21, 1994, that contained WCAP-13913, "Framework for AP600 Severe Accident Management Guidance" (SAMG). The NRC assessment was that the material was similar to material that exists in current (1998) nonproprietary AP600 documents (e.g., WCAP-13914, "Framework for AP600 Severe Accident Management Guidance"). In addition, the staff indicated the material was used by the staff in the development of the AP600 draft safety evaluation report and therefore should remain on the docket. At the time this Framework for SAMG was provided to the NRC technical staff, the information was considered to be proprietary by Westinghouse since it contained information that had commercial value to Westinghouse. At this time, over four years later, this information is no longer considered to be proprietary by Westinghouse.

August 14, 1998

Reference 3 also provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated February 3, 1994, that contained additional copies of WCAP-13913, "Framework for AP600 Severe Accident Management Guidance" (SAM⁴G). The NRC assessment was that the material was similar to material that exists in current (1998) non-proprietary AP600 documents (e.g., WCAP-13914, "Framework for AP600 Severe Accident Management Guidance"). In addition, the staff indicated the material was used by the staff in the development of the AP600 draft safety evaluation report and therefore should remain on the docket. At the time this Framework for SAMG was provided to the NRC technical staff, the information was considered to be proprietary by Westinghouse since it contained information that had commercial value to Westinghouse. At this time, over four years later, this information is no longer considered to be proprietary by Westinghouse.

Reference 4 provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated April 18, 1995, that contained information for a MAAP4/RELAP comparison for the AP600 in response to a staff request for additional information. The NRC assessment was that the Westinghouse cover letter indicated that Enclosure 2 is a non-proprietary version of Enclosure 3, however, the staff could not find any portion of the enclosures marked as proprietary. The staff assessment further states the conventional bracketed-superscript notation also appears to be missing. Finally, the NRC assessment states the staff could not determine which part of the material enclosed with the Westinghouse letter was Enclosure 1, 2, or 3. It should be noted that the Westinghouse April 18, 1995, cover letter states "Enclosures 2 (nonproprietary) and 3 (proprietary) provide the requested information." The letter does not indicate that enclosure 2 was a duplicate of enclosure 3 minus the proprietary information. A cover sheet was provided just prior to each of the enclosures to the Westinghouse letter. The enclosures contained the following: Enclosure 1 provided a copy of the NRC's two-page request for information for the MAAP-RELAP comparison. Enclosure 2 provided the requested information, and was titled "Requested Information for AP600 MAAP4/RELAP Comparison." Under section 4, Initial Conditions, of Enclosure 2 it states the initial conditions information (which was proprietary) is provided in Enclosure 3 of the subject Westinghouse letter. Finally, Enclosure 3 contained the list of initial conditions. The information provided in Enclosure 3 was labeled as Westinghouse Proprietary Class 2 at the top of the page, however, the specific proprietary information was not indicated by the bracketed-superscripted notation. In addition to the initial conditions, a mark-up of AP600 PRA Figure K-1 was provided in Enclosure 3. Again, the information was labeled as Westinghouse Proprietary Class 2 at the top of the page, however, the specific proprietary information was not indicated by the bracketed-superscripted notation. At the time the information provided in Enclosure 3 of the subject Westinghouse letter was provided to the NRC technical staff, the information was considered to be proprietary by Westinghouse since it contained information that had commercial value to Westinghouse. At this time, over three years later, this information is no longer considered to be proprietary by Westinghouse.


Reference 5 provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated February 8, 1994, provided a copy of WCAP-13957, "AP600 Reactor Coolant System Mass Inventory: Function Based Risk Analysis." The NRC assessment was that the material was not "information that the staff customarily accepts as proprietary." In addition, the staff indicated the material was used by the staff in the development of the AP600 final safety evaluation report and therefore should remain on the docket. At the time this report was prepared, the

August 14, 1998

information was considered to be proprietary by Westinghouse since it contained information that had commercial value to Westinghouse and was of the type of information that was customarily held in confidence by Westinghouse. That the material was not information that the staff customarily accepts as proprietary is not relevant to making the proprietary determination. However, in an effort to expedite the issuance of the AP600 Final Safety Evaluation Report and Final Design Approval, Westinghouse agrees to no longer consider this information to be proprietary.

In a telephone call on July 8, 1998, the staff informed Westinghouse of a concern related to WCAP-13288 and WCAP-13289, which were associated with the AP600 check valve testing specification. The concern was that the proprietary report had no proprietary information identified and the nonproprietary report had been placed in the public document room. Westinghouse has reviewed these reports and, at this time, considers none of the information to be proprietary.

This response addresses the proprietary issues delineated in the references.



Brian A. McIntyre, Manager
Advanced Plant Safety and Licensing

jml

cc: J. W. Roe - NRC/NRR/DRPM
J. M. Sebrosky - NRC/NRR/DRPM
W. C. Huffman - NRC/NRR/DRPM
H. A. Sepp - Westinghouse