

9809290192 980922
FDR ADDCK 05200003
A PDR

2100002

Presentation to the
NRC Staff
on

AP600 TEST & ANALYSIS PROGRAMS
SCHEDULE UPDATE

by
E. J. Piplica, Manager
Test Engineering

Westinghouse Electric Corporation

December 14, 1992

ET-NRC-92-3783

AP600 TEST PROGRAMS

- PASSIVE CONTAINMENT COOLING SYSTEM TEST
- PASSIVE CORE COOLING SYSTEM TESTS
- COMPONENT DESIGN VERIFICATION TESTS

TEST CATEGORIES

· SAFETY RELATED TESTS

· NON-SAFETY RELATED EQUIPMENT TESTS

· BASIC RESEARCH TESTS

TEST CATEGORIES

- SAFETY RELATED TESTS
- NON-SAFETY RELATED EQUIPMENT TESTS
- BASIC RESEARCH TESTS

SAFETY RELATED TESTS

- PROVIDE DATA FOR COMPUTER CODES USED FOR SSAR ANALYSIS:
 - MODELS
 - CORRELATIONS
 - VERIFICATION
- GENERALLY, A THERMAL-HYDRAULIC TEST
 - UNDERSTAND AND EXPLAIN T/H PHENOMENA
 - CAN BE SYSTEM OR SEPARATE EFFECTS TEST
- HIGHEST QUALITY ASSURANCE PEDIGREE
 - NQA-1 APPLIES, 10CFR21 APPLIES
 - TEST SPECIFICATION REQUIRED
 - TEST OPERATING PROCEDURES REQUIRED
 - TEST FACILITY DESIGN DOCUMENTATION REQUIRED
 - QUALITY RECORDS REQUIRED
- EXAMPLES
 - LARGE SCALE PCCS HEAT TRANSFER TESTS
 - INTEGRAL SYSTEMS TEST (SPES-2, OSU)
 - SEPARATE EFFECT TESTS (ADS, CMT)

NON-SAFETY RELATED EQUIPMENT TESTS

- PROVIDE DESIGN INFORMATION ON SPECIFIC COMPONENTS
 - FEASIBILITY OF DESIGN
 - MANUFACTURABILITY
 - VERIFY COMPONENT PERFORMANCE


- GENERALLY, MECHANICAL TESTS
 - PERFORMANCE DATA
 - WEAR DATA

- HIGH QUALITY ASSURANCE STANDARDS
 - NQA-1 APPLIES
 - TEST SPECIFICATION OPTIONAL
 - TEST OPERATING PROCEDURES REQUIRED
 - TEST FACILITY DESIGN DOCUMENTATION REQUIRED
 - QUALITY RECORDS REQUIRED

- EXAMPLES
 - HIGH INERTIA ROTOR TESTS
 - RCP FLOW TESTS (AIR & WATER)
 - CHECK VALVE TESTS

BASIC RESEARCH TESTS

- EXPERIMENTAL IN NATURE
- GENERALLY BENCH TESTS PERFORMED AT UNIVERSITIES
 - INVESTIGATE SPECIFIC PHENOMENA IN DETAIL
 - ANSWER SPECIFIC QUESTIONS OF PERFORMANCE OR FEASIBILITY
 - PROVIDE GUIDANCE FOR FURTHER TESTING
- QUALITY REQUIREMENTS
 - TEST PLAN REQUIRED
 - TEST FACILITY DESIGN DOCUMENTS REQUIRED
- EXAMPLES
 - UNIVERSITY OF WISCONSIN CONDENSATION TESTS
 - UNIVERSITY OF TENNESSE REACTOR VESSEL AIR VISUALIZATION TE
 - BENCH WIND TUNNEL TEST





AP600 Test Objectives/Conclusions

Passive Containment Cooling Tests	Test Objective/Conclusion	Completion Date	Test Results Required		
			SSAR	FDA/DC	CV
Integral PCCS Test (Westinghouse STC)	Demonstrated operation of the PCCS over the full range design basis operating conditions	Completed, July 1992	X		
Large Scale PCCS (Westinghouse STC)	To demonstrate operation of the PCCS on a scaled structure which accurately models both the containment dome and sidewall heat transfer areas, and inside containment structures	Phase 1 - May 1992 Phase 2 - June 1993	X	X	
PCCS Water Distribution (Westinghouse AESD)					
Phase 1 - Center of Dome, 20' Diameter	Demonstrated the effectiveness of water distribution on the center of the containment dome	Completed, June 1991	X		
Phase 2 - Full Scale 1/8 Section	Demonstrated the effectiveness of water distribution on the containment dome and upper sidewall	Completed, January 1992	X		
Phase 3 - Full Scale 1/8 Section	Verify design of water distribution system	April 1993			
PCCS Wind Tunnel (University of Western Ontario)					
o Phase 1 - Overall building effects	Demonstrated the wind induced pressure on the containment shield building due to air inlet/outlet configurations and site structures	Completed, July 1991	X		
o Phase 2 - Detailed Model, Final Verification	Determined baffle loading and demonstrated the effect of wind on containment annulus air flow	Completed, February 1992	X		
o Phase 3/4	To demonstrate effects of site geography and to perform tests at higher Reynolds numbers	September 1993		X	



0 Test Objectives/Conclusions

Primary System Tests	Test Objective/Conclusion	Completion Date	Test Results Required for		
			SSAR	FDA/DC	Design Verification
HX (Westinghouse STC)	Determined heat transfer characteristics of the PRHR heat exchanger and mixing characteristics in the IRWST	Completed, December 1989	X		
		Completed, October 1990	X		
Depressurization System Test (Cesaccia, Italy)	To confirm the capacity of the sparger and to determine the dynamic effects on the IRWST structure	November 1992		X	
		December 1993		X	
Valve Performance	To simulate operation of the automatic depressurization system and to confirm the capacity and operability of the ADS valves	December 1993		X	
Tank (Westinghouse AESD)	To verify the gravity drain behavior of the core makeup tank over a full range of flow rates and pressures and to verify the operation of the tank level instrumentation	April 1993		X	
Sparging (1/4 Scale) (University)	To provide data to evaluate the operation of the PXS at low pressure	December 1993		X	
(University)	To extend the existing critical heat flux correlation for W fuel assemblies at lower flow conditions	February 1993		X	
Pressure Integral Systems Test (Italy)	To provide data to evaluate the operation of the PYS at high pressure, including response to small break LOCA, tube rupture and steamline break transients	November 1993		X	



600 Test Objectives/Conclusions

Test Name	Test Objective/Conclusion	Completion Date	Test Results Required for		
			SSAR	FDA/DC	Design Verification
RRR Suction Nozzle Test (East Pittsburgh)	Eliminated Suction Vortex	Completed, September 1988			X
Coolant Pump (RCP/SG Channelhead Air Westinghouse EMD)	No SG to Pump Flow Anomalies	Completed, March 1991			X
Water Flow (Westinghouse EMD)	To obtain flow, head and efficiency data to accurately predict the performance of the full scale AP600 reactor coolant pump	September 1994			X
Journal Bearing (Westinghouse STC)	Demonstrated manufacturability of depleted uranium rotor sections and large radial bearings and determined rotor drag losses	Completed, December 1989 Completed, February 1991			X
High Inertia Rotor (Westinghouse STC)	To optimize rotor drag losses	Completed, August 1992			X
Instrumentation Tests (ICIS)					
Electromagnetic Interference (Westinghouse EMD)	Demonstrated that system is not susceptible to Electromagnetic Interference from the CRDMs	Completed, September 1990			X
Induced Vibration (facility not chosen)	To demonstrate that the thimble is not subjected to excessive wear	May 1994			X



600 Test Objectives/Conclusions

Design Tests (Continued)	Test Objective/Conclusion	Completion Date	Test Results Required for		
			SSAR	FDA/DC	Design Verification
<ul style="list-style-type: none"> • Vessel Internals Test • Visualization (University of Tennessee) 	<p>Demonstrated that no abnormal flow distribution occurs in the reactor vessel downcomer and lower plenum</p> <p>To verify the hydraulic characteristics of the AP-600 vessel and internals</p>	<p>Completed, February 1992</p> <p>May 1987</p>			<p>X</p> <p>X</p>
<ul style="list-style-type: none"> • Scale Hydraulic (facility not chosen) • Valve (Westinghouse AESD) • Primary Hydraulic 	<p>Determined flow vs. dP for prototypic check valves</p> <p>To determine opening dP for check valves following prolonged exposure to plant conditions</p> <p>To assess check valve performance</p>	<p>Completed, June 1991</p> <p>December 1994</p> <p>(Later)</p>	X		<p>X</p> <p>X</p>
<ul style="list-style-type: none"> • Location Testing • Stage Valve Test (facility not chosen) 	<p>To verify valve and operator performance</p>	<p>December 1994</p>			X

N - N

ST PROGRAMS

● WITNESS POINT
▲ DATA REPORT

SCHEDULE AS OF 12/10/92

ITEM NAME	1988				1989				1990				1991				1992				1993			
	01	02	03	04	01	02	03	04	01	02	03	04	01	02	03	04	01	02	03	04	01	02	03	04
ION SYSTEMS																								
NOZZLE TEST																								
EXCHANGER TEST																								
EXCHANGER																								
VALVE STAGES LEAD																								
TANK TEST																								
COOLING TEST																								
SYSTEM TEST																								
VALVE																								
CRACKS																								
WELDS																								


3/1/94 ▲
3/1/94 ▲

PCCS LARGE SCALE TEST SCHEDULE

REVIEW/WITNESS POINTS

SCHEDULE AS OF 11/30/92

- - NRC
- ▼ - A & TRT
- - ENEL




ADS PHASE B TEST SCHEDULE

AS OF 11/30/92

REVIEW/WITNESS POINTS

- - NRC
- ▽ - A & TBT
- - EHEL




Legend:
 ○ - SCHEDULE
 ▨ - PROGRESS
 ■ - COMPLETE

DOU-LONG TERM COOLING TEST SCHEDULE
(Sheet 1 of 2)

AS OF 11/30/92

REVIEW/WITNESS POINTS

- - MRC
- ▽ - A & TRT
- - EHEL




SCHEDULE
 PROGRESS
 COMPLETE

AS OF 11/20/92

DU-LONG TERM COOLING TEST SCHEDULE
(Sheet 2 of 2)

REVIEW/WITNESS POINTS

- - MEC
- ▽ - A & T
- - ENCL




SCHEDULE
 PROGRESS
 COMPLETE

TES-2 TEST SCHEDULE (SHEET 2 OF 2)

SCHEDULE AS OF 11/30/92

REVIEW / WITNESS POINTS

- - MRC
- ▼ - A & TRT
- - ENCL



SCHEDULE
 PROGRESS
 COMPLETE

AP600 Test Documentation
(Westinghouse Proprietary Class 2 WCAPS)

PCCS Tests	Test Spec or Test Plan	Operating Procedures	Facility Design Report	Interim Data Report	Final Test Report
Bench Wind Tunnel Experiment					
Air Flowpath Delta P Test					13328 (0) 04/30/92
Heated Plate Test					12665 07/16/90 12665 (0) 04/30/92
Condensation Tests					13307 (0) 04/30/92
Integral (Small Scale) Tests					
Phase 1					12667 07/16/90 12667 (0) 04/30/92
Phase 2A	13315 (0) 04/30/92				
Phase 2B					
1/8th (Large Scale) Tests					
Phase 1	13267 (1) 04/30/92				
Phase 2	13267 (1) 04/30/92				
Water Distribution Tests					
Phase 1	13290 (0) 04/30/92		13292 (0) 04/30/92		13353 (0) 04/30/92
Phase 2	13290 (0) 04/30/92		13292 (0) 04/30/92		13796 (0) 04/30/92
Phase 3					
Wind Tunnel Tests					
Phase 1	13318 (0) 04/30/92				13294 (0) 04/30/92
Phase 2	13318 (0) 04/30/92				13323 (0) 10/02/92
Phase 3	13318 (0) 04/30/92				
Phase 4	13318 (0) 04/30/92				

AP600 Test Documentation
(Westinghouse Proprietary Class 2 WCAPS)

PXS Tests	Test Spec or Test Plan	Operating Procedures	Facility Design Report	Interim Data Report	Final Test Report
NRHR Suction Nozzle Test					
PRHR Heat Exchanger Tests					
Phase 1					12666 07/16/90
Phase 2					13368 (0) 06/07/92 12980 (0)
ADS Tests					
Phase A	13342 (0) 04/30/92				
Phase B	13342 (0) 04/30/92				
Core Makeup Tank Test	13345 (0) 04/30/92				
Long Term Cooling Test	13234 (0) 04/30/92				
FRFP Integral System Test	13277 04/03/92				

AP600 Test Documentation
 (Westinghouse Proprietary Class 2 WCAPS)

Component Tests	Test Spec or Test Plan	Operating Procedures	Facility Design Report	Interim Data Report	Final Test Report
RCP/SG Channel Head Air Flow Test					13298 (0) 04/30/92
RCP Journal Bearing Tests					
Phase 1	13309 (0) 04/30/92				12668 07/13/90 12668 (0) 04/30/92
Phase 2	13312 (0) 04/30/92				13319 (0) 04/30/92
RCP High Inertia Rotor Test	13313 (0) 04/30/92				13487 (0) 10/12/92
RCP Water Hydraulic Flow Test	13305 (0) 04/30/92				
Incore Instrumentation System ENI Test					12648 (0) 04/30/92
Incore Instrumentation System FIY Test					
RY Flow Visualization Test					13351 (0) 04/30/92
Check Valve Tests					
Mechanical	13288 (0) 04/30/92		13284 (0) 04/30/92		13286 (0) 04/30/92
In-Situ					
Qualification					



AP600 CHECK VALVE TEST

- o Verify hydraulic performance of swing check valve (provide valve design feasibility information)
 - Opening differential pressure
 - Differential pressure over the expected valve flow rate with prototypic valve arrangement

- o Develop a qualification plan
 - Contract Penn State University to review existing check valve data

- o Utility participation
 - Have contacted 5 utilities about the possibility of testing existing check valves



CS CHECK VALVE FLOW TEST

RPOSE

monstrate the capability of the Passive Safety Injections System Check
ves to open under low differential pressure conditions which exist under
ivity drain injection and natural circulation operation.

Verify differential pressure required to open the valve disk and to maintain
the disk full open


Verify data on flow versus differential pressure over the expected valve
operating range



PXS CHECK VALVE TESTS

- o INSTALL SINGLE CHECK VALVE (0 TO 600 GPM)
 - 4-INCH CHECK VALVE
 - EACH 6-INCH CHECK VALVE
- o 6-INCH CHECK VALVES IN SERIES (0 TO 600 GPM)
- o INSTALL 4-INCH AND 6-INCH VALVES IN SERIES (0 TO 600 GPM)


CHECK VALVE FLOW TEST FACILITY





PXS CHECK VALVE FLOW TEST DATA


4" CHECK VALVE TEST DATA - PRESSURE DROP vs. FLOWRATE






S CHECK VALVE FLOW TEST DATA

CHECK VALVE TEST DATA - PRESSURE DROP vs. FLOWRATE



3 CHECK VALVE FLOW TEST DATA

CHECK VALVES IN SERIES - PRESSURE DROP VS. FLOWRATE





00 CHECK VALVE TEST

RESULTS

Differential pressure required to initially open check valve is small (less than one inch of water)

Operation of each check valve is smooth under all flow rates, ranging from laminar to fully turbulent

Pressure drop vs. flow rate is predictable

There exists a critical flow rate for each check valve at which the disk is just opening

Interaction seen between valves in series when piping between valves is long. Interaction seen at 3 pipe diameters was very small.




AP600 CHECK VALVES

- o **Current PWRs Use Check Valves In Similar Service**
 - RCS chemistry
 - Stainless steel with stellite seats
 - Infrequent use, normally closed

- o **Well Designed, Simple Check Valves Are Reliable In Nuclear Power Plant Service**
 - Search of NPRDS failure records (1984 to 90) indicate 4500 check valve failures
 - Of these only 87 were failures to open
 - None of the failures was for a check valve with similar conditions to the IRWST valves
 - No indication of boric acid corrosion or self welding was found

- o **Check Valve Testing**
 - Performance tests show AP600 IRWST injection and recirculation check valves perform well
 - Further testing is being discussed to determine if in plant testing could be conducted to determine if corrosion bonding or other sticking failures would occur at IRWST opening pressures


**FAILURE TO OPEN OR ONLY PARTIALLY OPEN
PERCENTAGE OF FAILURES* IN WHICH
DESIGNATED MECHANISM WAS INVOLVED
-BWR'S AND PWR'S-**



* TOTAL NUMBER OF FAILURES EQUALS 87
SOURCE : NUCLEAR PLANT RELIABILITY DATA SYSTEM AVERAGE YEARS 1984-1990

Figure 3.1 Percentage of Failures as a Function of Failure Type - BWRs and PWRs

FAILURE TO OPEN OR ONLY PARTIALLY OPEN
PERCENTAGE OF FAILURES* IN WHICH
DESIGNATED MECHANISM WAS INVOLVED
-BOILING WATER REACTORS-



* TOTAL NUMBER OF FAILURES EQUALS 47


SOURCE : NUCLEAR PLANT RELIABILITY DATA SYSTEM - COVERAGE YEARS 1984-1990

Figure 3.2 Percentage of Failures as a Function of Failure Type - BWRs

Table 3.1 Failure Type Categorized by System - BWRs

FAILURE TYPE : INTERNAL FAILURE TYPE NO. :	WEAR/MECH DAMAGE [1]	CORROSION [1]	FOREIGN DEBRIS [2]	HUMAN ERRORS [3]	OTHER [4]	UNKNOWN [5]	UNSURE-REPLACED [6]	TOTALS [1]-[6]	# OF FAILURES
SYSTEM									
MAIN STEAM	11	1			4			16	16
REACTOR CORE ISOL COOLING	2		2		3	1		8	8
HIGH PRES COOLANT INJ	1	3	1					5	5
ESSENTIAL SERVICE WATER	1	1	3	1				6	3
ELECTRIC STARTING AIR	1		1					2	2
LOW PRES CORE SPRAY	1		1					2	2
CONDENSATION POOL SUPPORT	1			1				2	2
NON-COMBUSTIBLE GAS CONT-DIL			2					2	2
LOW PRES INJECT	1		1					2	2
ACT BLDG CCW	1				1			2	2
SEL FUEL OIL			1					1	1
ED WATER	1							1	1
CONTROL ROD DRIVE	1							1	1
TOTALS :	22	5	12	2	8	1	0	50	47
PERCENTAGES :	46.81%	10.64%	25.53%	4.26%	17.02%	2.13%	0.00%	106.38%	
NOTE: THE TOTAL PERCENTAGES EXCEED 100% DUE TO MORE THAN ONE MECHANISM BEING DESIGNATED IN SOME FAILURES									

**FAILURE TO OPEN OR ONLY PARTIALLY OPEN
PERCENTAGE OF FAILURES* IN WHICH
DESIGNATED MECHANISM WAS INVOLVED
-PRESSURIZED WATER REACTORS-**



* TOTAL NUMBER OF FAILURES EQUALS 40


SOURCE : NUCLEAR PLANT RELIABILITY DATA SYSTEM - COVERAGE YEARS 1984-1990

Figure 3.3 Percentage of Failures as a Function of Failure Type - PWRs

Table 3.2 Failure Type Categorized by System - PWRs

FAILURE TYPE :	WEAR/MECH DAMAGE	CORROSION	FOREIGN DEBRIS	HUMAN ERRORS	OTHER	UNKNOWN	UNSURE-REPLACED	TOTALS	# OF
FAILURE TYPE NO. :	[1]	[1]	[2]	[3]	[4]	[5]	[6]	[1]-[6]	FAILURES
SYSTEM									
COOLING WATER	4	2	1	1				8	8
EL STARTING AIR	1	1	2	1	1	2		8	8
LEAR SERVICE WATER	2	2						4	4
STEAM	2						1	3	3
LIARY FEEDWATER	1		1			1		3	3
TAINMENT SPRAY	2		1					3	3
DENSATE		2				1		3	3
PRESSURE INJECTION	2							2	2
BUSTIBLE GAS CONT-DIL		2						2	2
FEEDWATER SYSTEM				1		1		2	2
TOR COOLANT		1						1	1
ICAL & VOLUME CNTRL	1		1					2	1
LS :	15	10	6	3	1	5	1	41	40
ENTAGES :	37.50%	25.00%	15.00%	7.50%	2.50%	12.50%	2.50%	102.50%	
THE TOTAL PERCENTAGES EXCEED 100% DUE TO MORE THAN ONE MECHANISM BEIGN DESIGNATED IN SOME FAILURES									

FAILURE TO OPEN OR ONLY PARTIALLY OPEN
PERCENTAGE OF FAILURES* AS A FUNCTION OF
VALVE SIZE



* TOTAL NUMBER OF FAILURES EQUALS 87

SOURCE : NUCLEAR PLANT RELIABILITY DATA SYSTEM - COVERAGE YEARS 1984-1990

Figure 3.4 Percentage of Failures as a Function of Valve Size



WR CHECK VALVE FAILURE OBSERVATIONS

Most check valve failures occurred due to mechanical/wear damage (not applicable to AP600 valve application)

No failures to open due to corrosion observed for stainless steel valves

No failures to open due to foreign debris in water service for stainless steel valves

- **FOURTH STAGE ADS TEST PROGRAM**
 - **BACKGROUND**
 - **ORIGINAL ADS FOURTH STAGE VALVE WAS AN 8-INCH VALVE AND WOULD HAVE BEEN ADDRESSED IN THE CURRENT ADS TEST PROGRAM**
 - **THE ADS TESTS ARE COMPLEX EXPERIMENTS THAT EXAMINE THE ENTIRE ADS SYSTEM, VALVES, PIPING, AND SPARGER**
 - **AS A RESULT OF THE SSAR ANALYSIS, THE VALVE SIZE WAS INCREASED TO A 12-INCH VALVE TO PROVIDE INCREASED RCS VENTING CAPACITY**
 - **A SPECIFIC TEST WILL BE RUN ON THE FOURTH STAGE ADS VALVE, AS A COMPONENT DESIGN VERIFICATION TEST, NOT AS PART OF DESIGN CERTIFICATION**

- INFORMATION REQUIRED FROM FOURTH STAGE ADS VALVE PROGRAM
 - THE MAJORITY OF THE INFORMATION NEEDED FROM SUCH A PROGRAM IS SPECIFICALLY COMPONENT DESIGN RELATED:
 - OPENING TORQUES
 - SEALING CAPABILITY
 - SIZING OF VALVE OPERATOR

- INFORMATION IS ALSO NEEDED TO VERIFY THE FLOW BEHAVIOR OF THE VALVE - HOWEVER OTHER SOURCES/BASIS FOR THIS INFORMATION DOES/WILL EXIST TO REDUCE UNCERTAINTIES
 - FOURTH STATE ADS AND VALVE IS A SIMPLIFIED SYSTEM AND DISCHARGES DIRECTLY TO CONTAINMENT
 - DATA FROM THE 8-INCH ADS VALVES IN CURRENT PROGRAM WILL BE AVAILABLE
 - OTHER SOURCES OF CRITICAL FLOW DATA MARVIKEN, ETC

- IF CONCERNS EXIST ABOUT THE FLOW UNCERTAINTIES, THESE CAN BE ADDRESSED VIA SENSITIVITY STUDIES ON THE CRITICAL AND SUB-SONIC FLOW MODELS USED IN THE SSAR ANALYSIS
- IF NECESSARY, A MORE CONSERVATIVE MODEL COULD BE USED

Distribution: Mary Pat
Bill Hoffman



Westinghouse
Electric Corporation

Energy Systems

Box 355
Pittsburgh Pennsylvania 15230-0355

DCP/NRC1409
NSD-NRC-98-5753
Docket No. 52-003

August 13, 1998

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: T. R. QUAY

SUBJECT: RESPONSE TO NRC LETTERS CONCERNING REQUEST FOR WITHHOLDING
INFORMATION

- Reference:
1. Letter, Sebrosky to McIntyre, "Request for withholding proprietary information for Westinghouse letters dated December 14, 1992, and December 17, 1992," dated July 10, 1998.
 2. Letter, Huffman to McIntyre, "Request for withholding information from public disclosure of Westinghouse AP600 design letters of December 15, 1992," dated July 14, 1998.
 3. Letter, Sebrosky to McIntyre, "Request for withholding information from public disclosure for Westinghouse AP600 design letter of February 24, 1993, April 19, 1993, and July 14, 1993," dated June 18, 1998.
 4. Letter, McIntyre to Quay, "Status review of AP600 proprietary submittals," dated September 18, 1995.

Dear Mr. Quay:

Reference 1 provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated December 14, 1992, that provided the NRC with copies of presentation material from a management meeting held December 14, 1992, discussing the AP600 testing program. The NRC has no record of a nonproprietary version of the slides being provided. At the time this presentation was made, the information was proprietary since that description of the AP600 testing program had commercial value to Westinghouse. At this time, almost six years later, this information does not have commercial value and is no longer considered to be proprietary by Westinghouse.

Reference 1 also provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated December 17, 1992, that provided the NRC with copies of presentation material from a meeting with the technical staff held December 9-10, 1992, discussing the AP600

2787a wpl

~~9808200180~~ 3pp.

Enclosure 2

August 13, 1998

testing program. The NRC has no record of a nonproprietary version of the slides being provided. At the time this presentation was made, the information was proprietary since that description of the AP600 testing program had commercial value to Westinghouse. At this time, almost six years later, this information does not have commercial value and is no longer considered to be proprietary by Westinghouse.

Reference 2 provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated December 15, 1992, that contained a preliminary description of the AP600 refueling outage plan activities. The NRC assessment was that no material in the letter was specifically identified as being proprietary and that a nonproprietary version was not provided. At the time this subject was being discussed with the NRC technical staff, the information was considered to be proprietary by Westinghouse since it contained information that had commercial value to Westinghouse. At this time, almost six years later, this information does not have commercial value and is no longer considered to be proprietary by Westinghouse.

Reference 3 provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated February 24, 1993, that contained presentation materials from the February 24, 1993, Westinghouse/NRC AP600 senior management meeting. The NRC assessment was that the material was similar to material that exists in the current (1998) nonproprietary version of the AP600 probabilistic risk assessment and AP600 standard safety analysis report. In addition the staff indicated the material was used by the staff in the development of the AP600 draft safety evaluation report and therefore should remain on the docket. Our 1995 request, Reference 4, indicated that the material provided in the Westinghouse letter of February 24, 1993, was presentation material that was intended for clarification only, not part of the formal review material and requested that the material be returned to Westinghouse. At the time this subject was being discussed with the NRC technical staff, the information was considered to be proprietary by Westinghouse since it contained information that had commercial value to Westinghouse. If this presentation material was indeed used by the staff in development of the AP600 draft final safety evaluation report in November 30, 1994, then at this time, over five years later, this information is no longer considered to be proprietary by Westinghouse.

Reference 3 provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated April 19, 1993, that contained presentation materials from the April 20, 1993, AP600 overview. The NRC assessment was that the material was similar to material that exists in the current (1998) nonproprietary version of the AP600 probabilistic risk assessment and AP600 standard safety analysis report. In addition the staff indicated the material was used by the staff in the development of the AP600 draft safety evaluation report and therefore should remain on the docket. Our 1995 request, Reference 4, indicated that the material provided in the Westinghouse letter of April 19, 1993, was presentation material that was intended for clarification only, not part of the formal review material and requested that the material be returned to Westinghouse. At the time this subject was being discussed with the NRC technical staff, the information was considered to be proprietary by Westinghouse since it contained information that had commercial value to Westinghouse. If this presentation material was indeed used by the staff in development of the AP600 draft final safety evaluation report in November 30, 1994, then at this time, over five years later, this information is no longer considered to be proprietary by Westinghouse.

August 13, 1998

testing program. The NRC has no record of a nonproprietary version of the slides being provided. At the time this presentation was made, the information was proprietary since that description of the AP600 testing program had commercial value to Westinghouse. At this time, almost six years later, this information does not have commercial value and is no longer considered to be proprietary by Westinghouse.

Reference 2 provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated December 15, 1992, that contained a preliminary description of the AP600 refueling outage plan activities. The NRC assessment was that no material in the letter was specifically identified as being proprietary and that a nonproprietary version was not provided. At the time this subject was being discussed with the NRC technical staff, the information was considered to be proprietary by Westinghouse since it contained information that had commercial value to Westinghouse. At this time, almost six years later, this information does not have commercial value and is no longer considered to be proprietary by Westinghouse.


Reference 3 provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated February 24, 1993, that contained presentation materials from the February 24, 1993, Westinghouse/NRC AP600 senior management meeting. The NRC assessment was that the material was similar to material that exists in the current (1998) nonproprietary version of the AP600 probabilistic risk assessment and AP600 standard safety analysis report. In addition the staff indicated the material was used by the staff in the development of the AP600 draft safety evaluation report and therefore should remain on the docket. Our 1995 request, Reference 4, indicated that the material provided in the Westinghouse letter of February 24, 1993, was presentation material that was intended for clarification only, not part of the formal review material and requested that the material be returned to Westinghouse. At the time this subject was being discussed with the NRC technical staff, the information was considered to be proprietary by Westinghouse since it contained information that had commercial value to Westinghouse. If this presentation material was indeed used by the staff in development of the AP600 draft final safety evaluation report in November 30, 1994, then at this time, over five years later, this information is no longer considered to be proprietary by Westinghouse.

Reference 3 provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated April 19, 1993, that contained presentation materials from the April 20, 1993, AP600 overview. The NRC assessment was that the material was similar to material that exists in the current (1998) nonproprietary version of the AP600 probabilistic risk assessment and AP600 standard safety analysis report. In addition the staff indicated the material was used by the staff in the development of the AP600 draft safety evaluation report and therefore should remain on the docket. Our 1995 request, Reference 4, indicated that the material provided in the Westinghouse letter of April 19, 1993, was presentation material that was intended for clarification only, not part of the formal review material and requested that the material be returned to Westinghouse. At the time this subject was being discussed with the NRC technical staff, the information was considered to be proprietary by Westinghouse since it contained information that had commercial value to Westinghouse. If this presentation material was indeed used by the staff in development of the AP600 draft final safety evaluation report in November 30, 1994, then at this time, over five years later, this information is no longer considered to be proprietary by Westinghouse.

August 13, 1998

Reference 3 provided the NRC assessment of the Westinghouse claim that proprietary information was provided in a letter dated July 14, 1993, that contained presentation materials from the July 14, 1993, meeting where the AP600 main control room habitability was discussed. The NRC assessment was that the material was similar to material that exists in the current (1998) nonproprietary version of the AP600 probabilistic risk assessment and AP600 standard safety analysis report. In addition the staff indicated the material was used by the staff in the development of the AP600 draft safety evaluation report and therefore should remain on the docket. Our 1995 request, Reference 4, indicated that the material provided in the Westinghouse letter of July 14, 1993, was presentation material that was intended for clarification only, not part of the formal review material and requested that the material be returned to Westinghouse. At the time this subject was being discussed with the NRC technical staff, the information was considered to be proprietary by Westinghouse since it contained information that had commercial value to Westinghouse. If this presentation material was indeed used by the staff in development of the AP600 draft final safety evaluation report in November 30, 1994, then at this time, over five years later, this information is no longer considered to be proprietary by Westinghouse.

This response addresses the proprietary issues delineated in the references.



Brian A. McIntyre, Manager
Advanced Plant Safety and Licensing

jml

cc: J. W. Roc - NRC/NRR/DRPM
J. M. Sebrosky - NRC/NRR/DRPM
W. C. Huffman - NRC/NRR/DRPM
H. A. Sepp - Westinghouse