

August 31, 1988

Docket No. 50-440

DISTRIBUTION

<u>Docket File</u>	NRC & Local PDRs
PD3 r/f	KPerkins
GHolahan	PKreutzer
TColburn	OGC-OWF
EJordan	BGrimes
ACFS(10)	PDIII-3 Gray File

Mr. Alvin Kaplan, Vice President
 Nuclear Group
 The Cleveland Electric Illuminating
 Company
 10 Center Road
 Perry, Ohio 44081

Dear Mr. Kaplan:

SUBJECT: ITEMS 3.1.3 AND 3.2.3 OF GENERIC LETTER 83-28, POST-MAINTENANCE TESTING FOR REACTOR TRIP SYSTEM AND ALL OTHER SAFETY-RELATED COMPONENTS FOR PERRY NUCLEAR POWER PLANT, UNIT 1 (TAC NOS. 61706 AND 61707)

We have reviewed your February 23, 1988 response to the staff's November 7, 1987 request for additional information concerning the subject items. Based upon our review, we consider the subject items acceptably resolved for your facility.

Generic Letter 83-28, items 3.1.3 and 3.2.3, required that licensees review existing Technical Specifications (TS) and identify, if applicable, any post-maintenance test requirements which could degrade rather than enhance safety with respect to reactor trip system components and all other safety-related components, respectively. In the event that any existing TS were identified which would degrade rather than enhance safety, licensees were required to submit appropriate changes to the TS with supporting justification for staff review and approval. In your February 23, 1988 letter, you indicate that you have completed a review of the TS for the Perry Nuclear Power Plant and have determined that none of the post-maintenance testing requirements would degrade rather than enhance safety. Based upon our review, we have determined that you have adequately met the requirements of items 3.1.3 and 3.2.3 of Generic Letter 83-28 for your facility.

This completes the staff's review efforts under TAC 61706 and 61707. If you have any questions, please contact me at (301) 492-1369.

Sincerely,

151

Timothy G. Colburn, Project Manager
 Project Directorate III-3
 Division of Reactor Projects - III,
 IV, V and Special Projects

cc: See next page

Office: LA/PDIII-3	PM/PDIII-3	ICSB	PD/PDIII-3
Surname: PKreutzer	TColburn	SNewberry	KPerkins
Date: 8/26/88	8/26/88	8/31/88	8/31/88

DFD 1/0

8809070513 880831
 PDR ADOCK 05000440
 F PNU



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

August 31, 1988

Docket No. 50-440

Mr. Alvin Kaplan, Vice President
Nuclear Group
The Cleveland Electric Illuminating
Company
10 Center Road
Perry, Ohio 44081

Dear Mr. Kaplan:

SUBJECT: ITEMS 3.1.3 AND 3.2.3 OF GENERIC LETTER 83-28, POST-MAINTENANCE TESTING FOR REACTOR TRIP SYSTEM AND ALL OTHER SAFETY-RELATED COMPONENTS FOR PERRY NUCLEAR POWER PLANT, UNIT 1 (TAC NOS. 61706 AND 61707)

We have reviewed your February 23, 1988 response to the staff's November 7, 1987 request for additional information concerning the subject items. Based upon our review, we consider the subject items acceptably resolved for your facility.

Generic Letter 83-28, items 3.1.3 and 3.2.3, required that licensees review existing Technical Specifications (TS) and identify, if applicable, any post-maintenance test requirements which could degrade rather than enhance safety with respect to reactor trip system components and all other safety-related components, respectively. In the event that any existing TS were identified which would degrade rather than enhance safety, licensees were required to submit appropriate changes to the TS with supporting justification for staff review and approval. In your February 23, 1988 letter, you indicate that you have completed a review of the TS for the Perry Nuclear Power Plant and have determined that none of the post-maintenance testing requirements would degrade rather than enhance safety. Based upon our review, we have determined that you have adequately met the requirements of items 3.1.3 and 3.2.3 of Generic Letter 83-28 for your facility.

This completes the staff's review efforts under TAC 61706 and 61707. If you have any questions, please contact me at (301) 492-1369.

Sincerely,

Timothy G. Colburn

Timothy G. Colburn, Project Manager
Project Directorate III-3
Division of Reactor Projects - III,
IV, V and Special Projects

cc: See next page

Mr. Alvin Kaplan
The Cleveland Electric
Illuminating Company

Perry Nuclear Power Plant
Unit 1

cc:
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N.W.
Washington, D.C. 20037

Mr. James W. Harris, Director
Division of Power Generation
Ohio Department of Industrial
Relations
P.O. Box 825
Columbus, Ohio 43216

David E. Burke
The Cleveland Electric
Illuminating Company
P.O. Box 5000
Cleveland, Ohio 44101

The Honorable Lawrence Logan
Mayor, Village of Perry
4203 Harper Street
Perry, Ohio 44081

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
Parmly at Center Road
Perry, Ohio 44081

The Honorable Robert V. Orosz
Mayor, Village of North Perry
North Perry Village Hall
4778 Lockwood Road
North Perry Village, Ohio 44081

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43216

Frank P. Weiss, Esq.
Assistant Prosecuting Attorney
105 Main Street
Lake County Administration Center
Painesville, Ohio 44077

Radiological Health Program
Ohio Department of Health
1224 Kinnear Road
Columbus, Ohio 43212

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Ohio Environmental Protection
Agency
361 East Broad Street
Columbus, Ohio 43266-0558

Terry J. Lodge, Esq.
618 N. Michigan Street
Suite 105
Toledo, Ohio 43624

Mr. Phillip S. Haskell, Chairman
Perry Township Board of Trustees
Box 65
4171 Main Street
Perry, Ohio 44081

John G. Cardinal, Esq.
Prosecuting Attorney
Ashtabula County Courthouse
Jefferson, Ohio 44047

State of Ohio
Public Utilities Commission
180 East Broad Street
Columbus, Ohio 43266-0573

Eileen M. Buzzelli
The Cleveland Electric
Illuminating Company
P. O. Box 97 E-210
Perry, Ohio 44081

Mr. Murray R. Edelman
Centerior Energy
6200 Oaktræ Blvd.
Independence, Ohio 44131