

September 25, 1998

Mr. James W. Langenbach, Vice President
and Director - TMI
GPU Nuclear, Inc.
P.O. Box 480
Middletown, PA 17057

SUBJECT: THREE MILE ISLAND NUCLEAR STATION, UNIT NO. 1 - WITHDRAWAL OF
AN AMENDMENT REQUEST, TSCR NO. 243 (TAC NO. M95239)

Dear Mr. Langenbach:

By letter dated April 10, 1996, as supplemented May 24, 1996, you applied for an amendment to the Three Mile Island Nuclear Station, Unit No. 1 Operating License No. DPR-50. The proposed changes would have extended the surveillance interval on several instruments from 18 to 24 months +/- 25 percent (pursuant to technical specification (TS) allowances) in accordance with the guidance in Generic Letter (GL) 91-04, and would also have deleted certain surveillances related to the Makeup, Purification, and Chemical Addition Systems.

The staff issued a request for additional information (RAI) dated April 7, 1998, related to your application. Subsequently, by letter dated September 18, 1998, you withdrew the amendment request for reasons stated in your letter. You also indicated that you intend to re-address the request to delete certain surveillances in future correspondence.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

Original signed by
Timothy G. Colburn, Senior Project Manager
Project Directorate I-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

11
DFO1

Docket No. 50-289
Enclosure: Notice of Withdrawal
cc w/encl: See next page

DISTRIBUTION

Docket File	PUBLIC	PDI-3 Rdg.
JZwolinski	TClark	TColburn
OGC	ACRS	CHehl, RI

DOCUMENT NAME: G:\COLBURN\TMI95239.WDL

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PDI-3/PM	PDI-3/IA	PDI-3/D
NAME	TColburn	TClark	CThomas
DATE	09/25/98	09/25/98	09/25/98

OFFICIAL RECORD COPY

9809290371 980925
PDR ADOCK 05000289
P PDR

280092

NRC FILE CENTER COPY

J. Langenbach
Three Mile Island Nuclear Station, Unit No. 1

cc:

Michael Ross
Director, O&M, TMI
GPU Nuclear, Inc.
P.O. Box 4
Middletown, PA 17057

John C. Fornicola
Director, Planning and
Regulatory Affairs
GPU Nuclear, Inc.
100 Interpace Parkway
Parsippany, NJ 07054

Jack S. Wetmore
Manager, TMI Regulatory Affairs
GPU Nuclear, Inc.
P.O. Box 480
Middletown, PA 17057

Ernest L. Blake, Jr., Esquire
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW
Washington, DC 20037

Chairman
Board of County Commissioners
of Dauphin County
Dauphin County Courthouse
Harrisburg, PA 17120

Chairman
Board of Supervisors
of Londonderry Township
R.D. #1, Geyers Church Road
Middletown, PA 17057

Wayne L. Schmidt
Senior Resident Inspector (TMI-1)
U.S. Nuclear Regulatory Commission
P.O. Box 219
Middletown, PA 17057

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Robert B. Borsum
B&W Nuclear Technologies
Suite 525
1700 Rockville Pike
Rockville, MD 20852

William Dornsife, Acting Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P.O. Box 2063
Harrisburg, PA 17120

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

Peter W. Eselgroth, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406