

DCU

MAY 04 1988

Docket No. 50-341

CAL-RIII-88-009

Detroit Edison Company
ATTN: B. Ralph Sylvia
Group Vice President
Nuclear Operations
6400 North Dixie Highway
Newport, MI 48166

Dear Mr. Sylvia:

This refers to the NRC Confirmatory Action Letter dated April 19, 1988, and your written response dated April 23, 1988, providing an assessment of the effectiveness of Detroit Edison programs designed to improve personnel performance. We have reviewed your response, along with the actions you have taken regarding the Moisture Separator Reheater damage, and found them to be acceptable.

We have reviewed the actions you have taken regarding the Residual Heat Removal (RHR) pump event and found them acceptable. We understand that testing of the electrical relay suspected of causing the inadvertent isolation of valve E11-F015B has not been successful in reproducing the failure. We understand that you will continue testing of the relay, complete a failure analysis of the damaged relay, and develop corrective action to prevent recurrence based on the results of the subject testing and analysis. We further understand that pending the determination and implementation of corrective action to prevent recurrence, and prior to your returning to the shutdown cooling mode of RHR, you will revise your procedures to require frequent monitoring of shutdown cooling flow to ensure that the RHR system injection valves, when employed in the shutdown cooling mode of operation, do not inadvertently isolate and go unnoticed for a period of time that could result in the loss of shutdown cooling flow to the reactor vessel, the deadheading of the running RHR pump, or the pumpdown of the reactor vessel to the suppression pool through the miniflow line in the operating shutdown cooling loop.

As discussed in a telephone conversation between Mr. Orser of your staff and Dr. Paperiello of my staff on May 1, 1988, we concur with your decision to restart Fermi 2.

8805110250 880504
PDR ADDOCK 05000341
DCD

IEO

Should you have any questions, I will be glad to discuss them with you.

Sincerely,

Original signed by
A. Bert Davis

A. Bert Davis
Regional Administrator

- cc: Patricia Anthony, Licensing
- P. A. Marquardt, Corporate
Legal Department
- DCD/DCB (RIDS)
- Licensing Fee Management Branch
- Resident Inspector, RIII
- Ronald Callen, Michigan
Public Service Commission
- Harry H. Voight, Esq.
Michigan Department of
Public Health
- Monroe County Office of
Civil Preparedness
- J. Clifford, EDO
- W. Lanning, NRR
- F. Miraglia, NRR
- G. Holahan, NRR
- T. Quay, NRR
- J. Strasma, RIII
- J. Lieberman, OE
- L. Chandler, OGC

465
RIII
[Signature]
Cooper/pb
4/24/88

RIII
[Signature]
Knbp
4/24/88

[Signature]
R III
[Signature]
Probe
4/29/88

RIII & NRR
[Signature]
Greenman Crutchfield
4/24/88
T. HURLEY
by phone 4/18

RIII
[Signature]
Paperello

yes
435
572

RIII
[Signature]
Daulte