



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

ILLINOIS POWER COMPANY, ET AL

DOCKET NO. 50-461

CLINTON POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 9  
License No. NPF-62

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by the Illinois Power Company\* (IP), Soyland Power Cooperative, Inc. and Western Illinois Power Cooperative, Inc. (the licensees) dated February 5, 1988, as supplemented July 27, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-62 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised


\*Illinois Power Company is authorized to act as agent for Soyland Power Cooperative, Inc. and Western Illinois Power Cooperative, Inc. and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

8809080199 880902  
PDR ADOCK 05000461  
F PDC

through Amendment No. 9, are hereby incorporated into this license. IP shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Daniel R. Muller, Director  
Project Directorate III-2  
Division of Reactor Projects - III,  
IV, V and Special Projects

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: September 2, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 9

FACILITY OPERATING LICENSE NO. NPF-62

DOCKET NO. 50-461

Replace the following page of the Appendix "A" Technical Specifications with the attached page. The revised page is identified by amendment number and contains vertical lines indicating the area of change.

Remove

3/4 3-21

Insert

3/4 3-21

TABLE 3.3.2-2 (Continued)  
CRVICS INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
1. <u>PRIMARY AND SECONDARY CONTAINMENT ISOLATION (Continued)</u>		
k. Containment Pressure - High	$\leq 2.62$ psid	$\leq 3.00$ psid
l. Main Steam Line Radiation - High	$\leq 3.0$ x full power background	$\leq 3.6$ x full power background
m. Fuel Building Exhaust Radiation - High	$\leq 10$ mR/hr	$\leq 17$ mR/hr
n. Manual Initiation	NA	NA
2. <u>MAIN STEAM LINE ISOLATION</u>		
a. Reactor Vessel Water Level - Low Low Low, Level 1	$\geq -145.5$ in.*	$\geq -147.7$ in.
b. Main Steam Line Radiation - High	$\leq 3.0$ x full power background	$\leq 3.6$ x full power background
c. Main Steam Line Pressure - Low	$\geq 849$ psig	$\geq 837$ psig
d. Main Steam Line Flow - High	$\leq 170$ psid**	$\leq 178$ psid**
e. Condenser Vacuum - Low	$\geq 8.5$ in. Hg vacuum	$\geq 7.6$ in. Hg vacuum
f. Main Steam Line Tunnel Temp. - High	$\leq 165^{\circ}\text{F}$	$\leq 176^{\circ}\text{F}$
g. Main Steam Line Tunnel $\Delta$ Temp. - High	$\leq 54.5^{\circ}\text{F}$	$\leq 60^{\circ}\text{F}$
h. Main Steam Line Turbine Bldg. Temp. - High		
(1) 1E31 - N559 A, B, C, D	$\leq 131.2^{\circ}\text{F}$	$\leq 138^{\circ}\text{F}$
1E31 - N560 A, B, C, D		
1E31 - N561 A, B, C, D		
1E31 - N562 A, B, C, D		
(2) 1E31 - N563 A, B, C, D	$\leq 143.2^{\circ}\text{F}$	$\leq 150^{\circ}\text{F}$
i. Manual Initiation	NA	NA
3. <u>REACTOR WATER CLEANUP SYSTEM ISOLATION</u>		
a. $\Delta$ Flow - High	$\leq 59$ gpm	$\leq 66.1$ gpm
b. $\Delta$ Flow Timer	$\geq 45$ sec.	$\leq 47$ sec.