

ENCLOSURE 1

NOTICE OF VIOLATIONS

Florida Power Corporation
Crystal River Unit 3

Docket No. 50-302
License No. DPR-72

During the Nuclear Regulatory Commission (NRC) inspection conducted on March 12 - April 15, 1988, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1987), the violation is listed below:

Technical Specification 4.4.4.2 requires that the emergency power supply for the pressurizer heaters shall be demonstrated operable every 18 months by manually transferring power from the normal to the emergency power source and energizing the heaters.

Contrary to the above, on March 24, 1988, it was determined that the emergency power supply for the operable set of pressurizer heaters had never been periodically tested to ensure operability by manually transferring power from the normal to the emergency power source and energizing the heaters.

This is a Severity Level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Florida Power Corporation is hereby required to submit a written statement or explanation to the Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector, Crystal River 3, within 30 days of the date of the letter transmitting this Notice. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include [for each violation]: (1) admission or denial of the alleged violation, (2) the reason for the violation if admitted, (3) the corrective steps which have been taken and the results achieved, (4) the corrective steps which will be taken to avoid further violations, and (5) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time. If an adequate reply is not received within the time specified in this Notice, an order may be issued to show cause why the license should not be modified, suspended, or revoked or why such other action as may be proper should not be taken.

FOR THE NUCLEAR REGULATORY COMMISSION

Original Signed By
BRUCE A. WILSON

Bruce A. Wilson, Chief
Reactor Projects Branch 2
Division of Reactor Projects

Dated at Atlanta, Georgia
this 17th day of May 1988

8805110293 880504
PDR ADOCK 05000302
Q DCD