

APR 20 1988

Mr. Henry Bliss  
Nuclear Licensing Manager  
Commonwealth Edison Company  
P. O. Box 767  
Chicago, Illinois 60690

Dear Mr. Bliss:

SUBJECT: MISCELLANEOUS AMENDMENTS/SEARCH REQUIREMENTS  
LA SALLE COUNTY NUCLEAR POWER STATION, UNITS 1 AND 2  
(TAC #65376/65377)

This is to acknowledge receipt of the Commonwealth Edison Company letter, dated January 14, 1988, which transmitted revisions to a proposed amendment (November 26, 1986) to the La Salle County Nuclear Power Station, Units 1 and 2, Physical Security Plan, in response to the Miscellaneous Amendments and Search Requirements.

The enclosure to this letter contains those matters which require plan changes in order to satisfy regulatory requirements. Items not discussed in the enclosure (or previous letters on this subject) need no further response at this time and are considered acceptable.

It is requested that you provide your response to these comments within 30 days from receipt of this letter.

The reporting and/or record keeping requirements contained in this letter affect fewer than 10 respondents; therefore, OMB clearance is not required under P.L. 96-511.

Should you have any questions concerning the enclosed comments, please contact the reviewer, Robert Skelton, at (301) 492-3208.

Sincerely,

Paul Shemanski, Project Manager  
Project Directorate III-2  
Division of Reactor Projects III, IV, V  
and Special Projects  
Office of Nuclear Reactor Regulation

Enclosure:  
Physical Security Plan Comments

cc w/enclosure:  
See next page

DISTRIBUTION W/ENCLOSURES:

RSGB rf PStarcher  
RSkelton CBuracker (2)  
Region III LLuther  
PShemanski Docket File 50-373/374  
Case File NRC PDR  
RErickson wo/enc1 Local PDR  
LBush wo/enc1

8805110333 880406  
PDR ADOCK 05000373  
F PDR

\* SEE PREVIOUS CONCURRENCES

OFC	:RSGB	:RSGB	:RSGB	:RSGB	:PD	:PD
NAME	:RSkelton*	:CBuracker*	:LBush*	:RErickson*	:LLuther <i>LL</i>	:PShemanski
DATE	:04/12/88	:04/11/88	:04/11/88	:04/20/88	:04/26/88	:04/26/88

*p.s.*

Mr. Henry Bliss  
Commonwealth Edison Company

LaSalle County Nuclear Power Station  
Units 1 & 2

cc:  
Phillip P. Steptoe, Esquire  
Sidley and Austin  
One First National Plaza  
Chicago, Illinois 60603

John W. McCaffrey  
Chief, Public Utilities Division  
SOIC  
100 West Randolph Street  
Chicago, Illinois 60601

Assistant Attorney General  
100 West Randolph Street  
Chicago, Illinois 60601

Resident Inspector/LaSalle, NPS  
U.S. Nuclear Regulatory Commission  
Rural Route No. 1  
P. O. Box 224  
Marseilles, Illinois 61341

Chairman  
LaSalle County Board of Supervisors  
LaSalle County Courthouse  
Ottawa, Illinois 61350

Attorney General  
500 South 2nd Street  
Springfield, Illinois 62701

Chairman  
Illinois Commerce Commission  
Leland Building  
527 East Capitol Avenue  
Springfield, Illinois 62706

Mr. Michael C. Parker, Chief  
Division of Engineering  
Illinois Department of Nuclear Safety  
1035 Outer Park Drive, 5th Floor  
Springfield, Illinois 62704

Regional Administrator, Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Docket Nos. 373/374

COMMENTS ON PHYSICAL SECURITY PLAN CHANGES  
(MISCELLANEOUS AMENDMENTS AND SEARCH REQUIREMENTS)  
LA SALLE COUNTY NUCLEAR POWER STATION, UNITS 1 AND 2

Provide a commitment that all keys, locks, combinations, and related access control devices used to control access to protected and vital areas shall be changed whenever there is evidence or suspicion that any of these devices may have been compromised. Reference 10 CFR 73.55 (d)(9).

Provide a commitment that the secondary power supply systems for both the alarm annunciator equipment and non-portable communications equipment shall be located within a vital area. Reference 10 CFR 73.55(e)(1) and Generic Letter 87-08 (Q&A #16).

Indicate what components of the secondary power supply system will be protected as vital. Reference 10 CFR 73.55(e)(1) and Generic Letter 87-08 (Q&A #18).