

AUG 26 1988

Official

NOTICE OF SIGNIFICANT MEETING

Name of Licensee: Carolina Power and Light Company

Name of Facility: Brunswick 1 and 2

Docket Nos.: 30-325 and 50-324

Date and Time of Meeting: September 3, 1988, at 9:00 a.m.

Location of Meeting: Enforcement Conference to discuss: (1) recently discovered instrument installation deficiencies and non-conservatisms in the instrument settings associated with High Pressure Coolant Injection (HPCI)/Reactor Core Isolation Cooling (RCIC) high steam line flow isolation; (2) apparent inadequate corrective action related to operability of safety-related DC motor operated valves; and (3) electrical switchboard operability as it relates to the apparent inadequacy of actions taken to identify and correct silicon bronze bolt failures. This meeting had been previously rescheduled from July 7, to July 20, 1988.

NRC Attendees: M. Ernst, Deputy Regional Administrator
L. A. Reyes, Director, Division of Reactor Projects (DRP)
A. F. Gibson, Director, Division of Reactor Safety (DRS)
G. R. Jenkins, Director, Enforcement and Investigation Coordination Staff
D. M. Verrelli, Chief, Reactor Projects Branch 1, DRP
A. R. Hardt, Chief, Engineering Branch, DRS
P. E. Fredrickson, Chief, Projects Section 1A, DRP
W. H. Ruland, Senior Resident Inspector

Licensee Attendees: M. A. McDuffie, Senior Vice President, Nuclear Generation
P. W. Howe, Vice President, Brunswick Nuclear Project
J. L. Harness, General Manager, Brunswick
R. E. Enzor, Director, Regulatory Compliance
R. B. Richey, Manager, Licensing and Nuclear Fuel
R. E. Helme, Manager, Technical Support
L. I. Loflin, Section Manager, Nuclear Licensing

NOTE: Attendance by NRC personnel at this NRC/Licensee meeting should be made known by 2:00 p.m., September 7, 1988, via telephone call to P. Fredrickson FTS 242-5649.

Approved by: 151

P. E. Fredrickson, Section Chief
Division of Reactor Project

8809080379 880826
PDR ADOCK 05000324
PNU

118
IEV5

AUG 20 1988

2

Distribution: J. Taylor, Deputy Executive Director for Regional Operations
J. Lieberman, Director, Office of Enforcement
W. M. Truskoski, Regional Coordinator (EDO)
E. G. Adensam, Director, Directorate II-1
G. C. Lainas, Asst. Director for Region II Reactors, NRR

bcc: J. P. Stohr
R. J. Maley
K. M. Clark
P. J. Fillion
All NRC Attendees
Receptionist
NRC Resident Inspector
DRS, Technical Assistant
Document Control Desk
State of North Carolina

RII *MS*
BCarroll:tj
08/22/88

RII *PF*
PFredrickson
08/22/88

RII *DN*
DVerrelli
08/24/88

RII *ES*
ESobson
08/24/88

RII
out of town
WHehl
08/188

RII *ER*
EReyes
08/23/88

RII *BJ*
BJenkins
08/23/88

RII *ME*
MErnst
08/23/88