



Commonwealth Edison
 One First National Plaza, Chicago, Illinois
 Address Reply to: Post Office Box 767
 Chicago, Illinois 60690 - 0767

April 22, 1988

Handwritten notes:
 DMC
 [Signature]

Mr. Thomas E. Murley, Director
 Office of Nuclear Reactor Regulation
 U.S. Nuclear Regulatory Commission
 Washington, DC 20555

Subject: Braidwood Unit 1 and 2
 Limitorque Operator Lubrication
NRC Docket Nos. 50-456 and 50-457

- Reference: (a) L.O. DelGeorge letter to T.E. Murley,
 dated April 21, 1988
- (b) L.O. DelGeorge letter to T.E. Murley,
 dated April 4, 1988

Dear Mr. Murley:

Reference (a) provided supplemental information in response to an April 20, 1988 teleconference to discuss reference (b).

Upon the completion of the NRC staff's review of reference (a) it is our understanding that four valves were identified that will potentially see radiation values that are higher than the 2×10^7 . (The qualification value for the SUN EP 50)

We understand these valves to be 1CV112B, 1CV112C, 1CG057A and 1RY8000A as listed in Attachment 2 to reference (a).

To show that the valve operators for these valves will function as intended, Commonwealth Edison will perform a qualification test of a representative grease sample, that will be completed within 60 days from the date Braidwood Unit 2 enters Mode 2, currently scheduled for April 23, 1988.

It is our understanding per D. Muller of NRR, that an additional option exists, whereby if we can show that the specific radiation values seen by these valves is lower than presented in Attachment 2 that this information may resolve this matter in lieu of testing.

Please address any questions you may have regarding this matter to this office.

Very truly yours,

S. C. Hunsader
 S. C. Hunsader
 Nuclear Licensing Administrator

8805120066 880422
 PDR AD0CK 05000456
 P DCD

cc: S Sands (NRR)
 W. Forney (RIII)
 BWD Resident Inspector

gs/4537K

Handwritten: 1302/11



Commonwealth Edison

One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690 - 0767

April 22, 1988
(Corrected copy dated April 25, 1988)

Mr. Thomas E. Murley, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Braidwood Unit 1 and 2
Limitorque Operator Lubrication
NRC Docket Nos. 50-456 and 50-457

Reference: (a) L.O. DelGeorge letter to T.E. Murley,
dated April 21, 1988

(b) L.O. DelGeorge letter to T.E. Murley,
dated April 4, 1988

Dear Mr. Murley:

Reference (a) provided supplemental information in response to an April 20, 1988 teleconference to discuss reference (b).

Upon the completion of the NRC staff's review of reference (a) it is our understanding that four valves were identified that will potentially see radiation values that are higher than the 2×10^7 . (The qualification value for the SUN EP 50)

We understand these valves to be 1CV112B, 1CV112C, 1OG057A and 1RY8000A as listed in Attachment 2 to reference (a).

To show that the valve operators for these valves will function as intended, Commonwealth Edison will perform a qualification test of a representative grease sample, that will be completed within 60 days from the date Braidwood Unit 1 enters Mode 2, currently scheduled for April 23, 1988. |

It is our understanding per D. Muller of NRR, that an additional option exists, whereby if we can show that the specific radiation values seen by these valves is lower than presented in Attachment 2 that this information may resolve this matter in lieu of testing.

Please address any questions you may have regarding this matter to this office.

Very truly yours,

S. C. Hunsader
S. C. Hunsader

Nuclear Licensing Administrator

cc: S Sands (NRR)
W. Forney (RIII)
BWD Resident Inspector
gs/4537K

8804280476

2/11



Commonwealth Edison
Post Office Box 767
Chicago, Illinois 60690-0767

Mr. Thomas E. Muriey, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC. 20555

12G18 OWFN

