



Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

September 1, 1988

FILE: B09-13510C
SERIAL: BSEP/88-0853

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT UNITS 1 AND 2
DOCKET NOS. 50-325 AND 50-324
LICENSE NOS. DPR-71 AND DPR-62
FOLLOW-UP TO SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.7.2
AND PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (2-SR-87-003)

Gentlemen:

During power operation of Units 1 and 2, at 0820 hours on December 17, 1987, a limiting condition for operation (LCO) was established to permit the removal from service of the fire suppression sprinkler header in the units' common Radiological Waste Control System waste drumming room. This was done to allow replacement of the header flow switch 2-FP-FS-4059. During installation of a replacement switch, the switch housing was inadvertently cracked which prevented use of the device. Due to unavailability of an additional switch in the plant supply system, the 14-day time frame of the subject LCO was exceeded on December 28, 1987.

The subject flow switch has been repaired and was returned to service at 1400 hours on February 21, 1988.

Very truly yours,

J. L. Harness, General Manager
Brunswick Steam Electric Plant

MJP/bvc

Enclosure

cc: Mr. B. C. Buckley
Dr. J. N. Grace
BSEP NRC Resident Office

8809090073 880901
PDR ADOCK 05000324
S PDC

IE22
1/0