



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 97 ■ PERRY, OHIO 44081 ■ TELEPHONE (216) 259-3737 ■ ADDRESS-10 CENTER ROAD

Serving The Best Location in the Nation
PERRY NUCLEAR POWER PLANT

Al Kaplan

VICE PRESIDENT
NUCLEAR GROUP

May 4, 1988
PY-CEI/NRR-0839 L

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Perry Nuclear Power Plant
Docket No. 50-440
Response to NRC Bulletin 88-03

Dear Sir:

This letter provides The Cleveland Electric Illuminating Company's response to NRC Bulletin 88-03, "Inadequate Latch Engagement in HFA Type Latching Relays Manufactured by General Electric (GE) Company."

The subject relays are not used in Class 1E (safety-related) applications at the Perry Nuclear Power Plant. Therefore, no further actions are required by this Bulletin.

If there are any questions, please feel free to call.

Very truly yours,

Al Kaplan
Vice President
Nuclear Group

AK:cab

cc: T. Colburn
K. Connaughton
USNRC Region III

8805120121 880504
PDR ADOCK 05000440
Q DCD


IEI
10

Alvin Kaplan who, being duly sworn, deposed and said that (1) he is Vice President, Nuclear Group of The Cleveland Electric Illuminating Company, (2) he is duly authorized to execute and file this report on behalf of The Cleveland Electric Illuminating Company and as duly authorized agent for Duquesne Light Company, Ohio Edison Company, Pennsylvania Power Company and the Toledo Edison Company, and (3) the statements set forth therein are true and correct to the best of his knowledge, information and belief.



Alvin Kaplan

Sworn to and subscribed before me, this 4th day of May, 1988.



JANE E. MOTT

Notary Public, State of Ohio
My Commission Expires February 20, 1990
(Recorded in Lake County)