

PRESERVICE INSPECTION SUMMARY REPORT
OF STEAM GENERATOR TUBING

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION

UNIT NO. 2

USNRC DOCKET NO.: 50-499

OPERATING LICENSE NO.: N/A

COMMERCIAL OPERATION DATE: JUNE 1989 (EST)

Prepared by:

J. L. Haning 8-22-88
J. L. Haning ISI Engineer

Reviewed by:

R. L. Beverly 8/22/88
R. L. Beverly Supervising Engineer - PSI/ISI

Approved by:

A. C. McIntyre 8-22-88
A. C. McIntyre Manager - Support Engineering Dept.



**PRESERVICE INSPECTION SUMMARY REPORT
OF STEAM GENERATOR TUBING**

at the

**SOUTH TEXAS PROJECT
ELECTRIC GENERATING STATION-UNIT 2**

**P.O. Box 308
Bay City, Texas 77414**

Owner: Houston Lighting & Power Company
City Public Service Board
of San Antonio
Central Power and Light Company
City of Austin

Address: P.O. BOX 1700
Houston, Texas 77001

Issue Date: August 1988

TABLE OF CONTENTS

	<u>Page</u>
1.0 <u>INTRODUCTION</u>	2
1.1 Abbreviations.....	2
2.0 <u>DESCRIPTION OF THE PLANT</u>	2
3.0 <u>DESCRIPTION OF THE COMPONENTS EXAMINED</u>	2
4.0 <u>EXAMINATION SCHEDULES AND PLANS</u>	2
5.0 <u>EXAMINATIONS</u>	3
5.1 Scope of Examinations.....	3
5.2 Examination Equipment and Procedures.....	3
5.3 Examination and Analysis Personnel.....	4
6.0 <u>FLAWS NOTED</u>	4
6.1 Reductions in Tube Wall Thickness.....	4
6.2 Dents and Dings.....	4
6.3 Restrictions.....	4
6.4 Tube Expansion Anomalies in the Tubeshheet.....	5
6.5 Manufacturing Burnish Marks.....	5
7.0 <u>CORRECTIVE ACTIONS RECOMMENDED AND TAKEN</u>	5
8.0 <u>FORM NIS-1</u>	6

APPENDICES

- A. Dents and Dings
- B. Tube Sheet Anomalies
- C. Tubes Removed from Service
- D. Form NIS-1, "Owner's Report for Inservice Inspections"

1.0 INTRODUCTION

This document is the Summary Report of the Eddy Current Preservice Inspection (PSI) of the tubing in all four (4) of the steam generators at the South Texas Project Electric Generating Station (STPEGS) - Unit 2. The initial PSI examinations and follow-up examinations (i.e., reexaminations) were performed by Conam Inspection.

1.1 Abbreviations

- 1.1.1 ANII - Authorized Nuclear Inservice Inspector
- 1.1.2 ASME - The American Society of Mechanical Engineers
- 1.1.3 ASTM - American Society for Testing and Materials
- 1.1.4 HL&P - Houston Lighting and Power Company
- 1.1.5 HPIB - Hewlett Packard Interface Buss
- 1.1.6 ID - Inner Diameter
- 1.1.7 MWe - Megawatt Electric
- 1.1.8 OD - Outer Diameter
- 1.1.9 PSI - Preservice Inspection
- 1.1.10 STPEGS - South Texas Project Electric Generating Station

2.0 DESCRIPTION OF THE PLANT

The South Texas Pr. Electric Generating Station is located near Wadsworth, Texas. The plant Nuclear Regulatory Commission Docket Number is 30-499. The station is a two (2) unit pressurized water reactor plant. Each reactor is a Westinghouse 4-Loop System. The rated output of each unit is 1250 MWe. Unit 2 is scheduled to enter commercial operation in June 1989.

3.0 DESCRIPTION OF THE COMPONENTS EXAMINED

Each of the four (4) steam generators is a Westinghouse Model E2 recirculating design generator, designed and fabricated by Westinghouse Electric Corporation of Tampa, Florida. Each generator contains 4851 tubes. The tubing is ASTM SB-163 inconel material having a nominal outside diameter (OD) of 0.75 inches and a nominal wall thickness of 0.043 inches.

4.0 EXAMINATION SCHEDULES AND PLANS

Conam Inspection performed an eddy current examination of every tube in the scope of the PSI during the months of April and May 1987. Conam

Inspection performed these examinations in accordance with a PSI plan entitled "Eddy Current Preservice Examination Plan" dated April 13, 1987, (HL&P Document No. 300305-00007-B-8N). Based on the results of the PSI examinations, operations were performed in one (1) tube to remove a restriction to passage of the eddy current probe. Additional operations on portions of three (3) other tubes rendered the initial PSI data unacceptable as a baseline for comparison to future data. After corrective operations were performed, a follow-up examination was performed by Conam Inspection in September 1987 on these four (4) tube areas.

5.0 EXAMINATIONS

5.1 Scope of Examinations

The PSI scope identified to be examined by Conam Inspection consisted of all of the tubes in steam generator A, B, C, and D, not previously removed from service.

5.2 Examination Equipment and Procedures

Conam Inspection used the MIZ-18 eddy current examination system manufactured by Zetec, Inc. The MIZ-18 Data Acquisition System consists of a Hewlett Packard 9000 Series computer, a digital tape recorder, and a MIZ-18 remote acquisition unit with HPIB to MIZ-18 interface. The data was recorded on 600 foot pre-formatted data cartridges (Scotch DC 600HC). The cartridges contain 16 data tracks with each track having 4096 one (1) kilobyte blocks. This permits the recording of 67.1 megabytes of digital data on one cartridge. The MIZ-18 remote acquisition unit provides all primary tester functions, including test frequency generation, coil multiplexing, in-phase and quadrature signal digitization, and data communication with the Hewlett Packard computer.

All tubes were examined with a 0.610 inch diameter, magnetically-saturated, bobbin coil probe. The data was recorded using 400, 200, 100 and 10 KHz frequencies in both the differential and absolute mode.

ASME Boiler and Pressure Vessel Code, Nuclear Components Code Case N-401, "Eddy Current Examination-Section XI, Division 1", was used after the MIZ-18 and the eddy current technique was satisfactorily demonstrated to the Authorized Nuclear Inservice Inspector (ANII).

Procedure No. 42-EC-153 (Rev. 0) entitled, "Multifrequency Eddy Current Procedure, Westinghouse Series E2, Steam Generator Tubing, MIZ-18 Digital Eddy Current System, South Texas Project", and procedure No. 42-DA-011 (Rev. 1) entitled, "Guidelines for Data Analysis of MIZ-18 Data Utilizing DDA-4 Digital Data Analysis System Bobbin Coil Examination South Texas Project" were used to perform the examinations. These procedures are included in the "Eddy Current Preservice Examination Plan" (HL&P Document No. 300305-00007-B-8N). The equipment and techniques used are those expected to be used during subsequent inservice inspections.

Every system calibration and calibration verification has been recorded on a uniquely numbered digital magnetic tape which is stored as a record. The data sheets, which are also stored as records, include the row and column numbers of each tube examined, the associated unique magnetic tape numbers, and the time of the applicable system calibrations and calibration verifications.

5.3 Examination and Analysis Personnel

The Conam Inspection personnel who performed examinations and/or data analysis and their certification levels are listed below. Only Level III or Level IIA personnel were utilized to analyze examination data.

<u>Name</u>	<u>Level</u>
Marlow, R. E.	III
Chambers, D. M.	III
Herrera, G.	IIA
Landis, M.	IIA
Matheson, M.	IIA
Merriman, R.	IIA
Miller, M.	IIA
Mitchell, J. F.	IIA
Nye, L.	IIA
Tobin, J.	IIA
Caperello, M.	IIB
Douglas, J.	IIB
Dugas, K.	IIB
Ferguson, B.	IIB
Keneipp, M.	IIB
Sordini, J.	IIB

6.0 FLAWS NOTED

6.1 Reductions in Tube Wall Thickness

No flaw was detected with depth equal to or greater than 20 percent of the nominal tube wall thickness.

6.2 Dents and Dings

Lists of all dents and dings detected in each steam generator tube during the PSI examination are included in Appendix A.

6.3 Restrictions

One tube was encountered which was restricted to the degree that the eddy current probe would not pass. The tube restriction was in steam generator C row 40 column 63 between the 7th and 8th support plate locations. This tube was examined from both the hot and cold leg ends using a 0.610 inch diameter probe up to the restriction

from both sides. Additional examinations were made using smaller probes. The smallest probe used was a 0.520 inch diameter bobbin coil probe. This probe would not pass the restriction. A probe head was removed from a probe and the 0.375 inch diameter probe sheath was able to pass the restriction. After the restriction was removed, this tube was reexamined in September, 1987 with a 0.610 inch diameter probe. The 0.610 inch diameter probe passed the area that was previously restricted and no anomalies were noted.

6.4 Tube Expansion Anomalies in the Tubesheet

During the eddy current PSI, many anomalies were noted in or near the hydraulically expanded area of tubes within the tubesheet. These anomalies were characterized and given the following designations:

ETL = Expansion transition located above top of tube sheet
TMR = Top of the expansion below tubesheet secondary face
OXP = Area in expansion greater than normal expansion
SKR = Area in expansion less than normal expansion
NTE = No tube sheet expansion
PTE = Partial tube sheet expansion
BLG = Tube ID greater than nominal

The horizontal component of the 200 KHz absolute data was utilized to determine if these anomalies were present. A tube was considered to have a normal or typical expansion if the 200 KHz absolute signal response of the expansion differed from that of the unexpanded tube at the tubesheet face by approximately 40 volts. Any area in the tubesheet that displayed a response deviation of 20 volts or greater from that of a normal or typical expansion was reported. All tubesheet anomalies are listed in Appendix B.

6.5 Manufacturing Burnish Mark

Manufacturing burnishing marks (MBM) are believed to be the result of final hand polishing or grinding operations on tubing during manufacturing. Polishing or grinding may also cold work the tube causing permeability changes. This type of indication can occur anywhere on the tube. MBM indications typically have a strong absolute coil response with an axial extent on the order of an inch. Differential coil response is usually not pronounced or may not be evidenced at all. Additionally, MBM indications are not consistent in all frequencies. There were 215 burnishing marks noted during the PSI examination.

7.0 CORRECTIVE ACTIONS RECOMMENDED AND TAKEN

All of the tube expansion anomalies recorded were evaluated. It was concluded that additional expansion would be performed on the following tube locations:

<u>Steam Generator</u>	<u>Tube End</u>	<u>Row</u>	<u>Column</u>
B	Cold Leg	19	25
D	Hot Leg	29	13
D	Cold Leg	7	29

The expansions were performed by Westinghouse in September, 1987. The expansion equipment malfunctioned during the reexpansion of steam generator D row 7 column 29 raising a question, at the time, of whether the reexpansion of that tube had been effective. The equipment was returned to Westinghouse for repair. Conam Inspection reexamined these three (3) areas during September, 1987, and detected no recordable indications. The indication in steam generator D row 7 column 29 had been reduced to just below the recording threshold. After the expansion equipment was modified, Westinghouse returned in January, 1988, and applied the expansion process to this tube without any equipment malfunction. Comparison of diastest measurements taken before and after the final expansion effort indicates that the tube profile did not change due to the final expansion effort. Therefore, it was concluded that the eddy current reexamination performed by Conam Inspection in September, 1987, was an acceptable baseline.

In steam generator C, row 40 column 63, a restriction was removed. The tube was subsequently reexamined in September, 1987, in the area formerly restricted. Therefore, there are no limitations to the PSI in the entire length of all tubes not removed from service.

In steam generator C, row 3 column 24 was removed from service by plugging because the tube sheet expansion extended above the tube sheet interface 0.800 inch. The tubes which were removed from service prior to and after the PSI are listed in Appendix C.

8.0 FORM NIS-1

Copies of the completed Form NIS-1, "Owner's Report for Inservice Inspections" for each steam generator are included in Appendix D.

APPENDIX - A

Steam Generator A

Dents and Dings

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: A
LOCATION: ALL
CRITERIA: DNT,DNG

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:14:59

ROW	COL	HEAT#	EXTENT				PROBE	LOCATION	CURRENT			
			LEG	REQ	TST	REM			VOLTS	MIL	DEG	*
39	16		C	F/L	F/L		013	610SM TSC+	0.9	20.8	181	DNG
31	40		C	F/L	F/L		054	610SM 19C+	9.2	5.1	179	DNG
8	42		C	F/L	F/L		059	610SM 09H+	41.5	5.8	182	DNG
11	88		H	F/L	F/L		044	610SM 09H+	43.4	9.6	178	DNG
34	89		H	F/L	F/L		041	610SM 01H+	15.5	5.6	180	DNG
4	90		H	F/L	F/L		041	610SM 10H+	9.8	6.8	176	DNG
46	95		H	F/L	F/L		027	610SM 21C+	0.0	7.8	186	DNT M1

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 7

NO TREND ANALYSIS REQUESTED

APPENDIX - A

Steam Generator B

Dents and Dings

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: B
LOCATION: ALL
CRITERIA: DNT,DNG

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:24:19

ROW	COL	HEAT#	LEG	EXTENT			PROBE	LOCATION	CURRENT			
				REQ	TST	REM			VOLTS	MIL	DEG	*
2	70		H	F/L	F/L		050	610SM	10H+ 11.2	12.8	175	DNG M1
35	73		H	F/L	F/L		053	610SM	09H+ 42.9	4.4	182	DNG 1
41	90		H	F/L	F/L		089	610SM	11C+ 0.0	7.2	177	DNT M1
48	90		H	F/L	F/L		067	610SM	TSH+ 2.5	5.2	179	DNG 1
6	98		H	F/L	F/L		074	610SM	17C+ 30.0	5.5	188	DNG 1
8	115		H	F/L	F/L		086	610SM	TSC+ 0.0	43.4	7	DNT M2

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 6

NO TREND ANALYSIS REQUESTED

APPENDIX - A

Steam Generator C

Dents and Dings

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: C
LOCATION: ALL
CRITERIA: DNT,DNG

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:54:03

ROW	COL	HEAT#	LEG	EXTENT		REEL	PROBE	LOCATION	CURRENT			
				REQ	TST				VOLTS	MIL	DEG	*
30	10		H	F/L	F/L	004	610SM	20C+ 10.9	6.8	180	DNG	1
27	14		H	F/L	F/L	006	610SM	10H+ 0.0	15.2	185	DNT	M2
48	42		H	F/L	F/L	031	610SM	AV4+ 0.0	7.3	178	DNT	M1
11	53		H	F/L	F/L	094	610SM	0uH+ 42.7	5.3	11	DNG	1
1	71		C	10H	10H	097	610SM	11C+ 0.0	15.9	3	DNT	M1
31	33		H	F/L	F/L	065	610SM	03H+ 6.3	4.9	186	DNG	1
23	92		H	F/L	F/L	072	610SM	11C+ 0.0	8.6	178	DNT	M1
30	96		H	F/L	F/L	076	610SM	22C+ 12.6	6.2	180	DNG	1
2	107		H	F/L	F/L	085	610SM	04H+ 43.7	6.0	182	DNG	1

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 9

NO TREND ANALYSIS REQUESTED

APPENDIX - A

Steam Generator D

Dents and Dings

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: D
LOCATION: ALL
CRITERIA: DNT,DNG

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 15:03:39

ROW	COL	HEAT#	LEG	EXTENT		REEL	PROBE	LOCATION	CURRENT				
				REQ	TST				MIL	DEG	*	CH	
12	5		H	F/L	F/L	001	610SM	05H+	3.8	5.6	179	DNG	1
1	6		H	F/L	11C RIT	005	610SM	10H+	1.2	11.1	185	DNG	1
16	6		H	F/L F/L		002	610SM	10H+	0.0	20.8	183	DNT M1	
			H	F/L F/L		002	610SM	10H+	1.8	10.7	184	DNG	1
			H	F/L F/L		002	610SM	12C+	42.6	5.2	185	DNG	1
26	8		H	F/L F/L		003	610SM	11C+	0.0	7.4	186	DNT M1	
10	9		H	F/L F/L		003	610SM	05H+	2.8	5.2	182	DNG	1
			H	F/L F/L		003	610SM	16C+	3.7	6.3	183	DNG	1
1	10		H	F/L 11C RIT		005	610SM	10H+	10.6	11.5	185	DNG	1
6	10		H	F/L F/L		004	610SM	16C+	3.7	8.5	185	DNG	1
23	13		H	F/L F/L		006	610SM	10H+	0.0	8.1	185	DNT M1	
27	13		H	F/L F/L		006	610SM	10H+	0.0	6.4	185	DNT M1	
30	15		H	F/L F/L		007	610SM	10H+	0.0	7.6	185	DNT M1	
9	17		H	F/L F/L		008	610SM	09H+	32.8	5.7	185	DNG	1
15	19		H	F/L F/L		009	610SM	11C+	0.0	6.9	186	DNT M1	
13	51		H	F/L F/L		039	610SM	01H+	19.4	6.6	182	DNG	1
7	52		H	F/L F/L		039	610SM	08H+	33.4	5.8	185	DNG	1
			H	F/L F/L		039	610SM	08H+	35.6	5.3	184	DNG	1
38	66		H	F/L F/L		053	610SM	06H+	3.5	5.6	185	DNG	1
42	66		H	F/L F/L		053	610SM	05H+	3.7	7.7	183	DNG	1
19	77		H	F/L F/L		062	610SM	16C+	4.2	5.0	179	DNG	1
16	82		H	F/L F/L		066	610SM	10H+	4.6	5.5	181	DNG	1
11	101	C	F/L F/L			092	610SM	09H+	31.9	5.2	174	DNG	1

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 19

NO TREND ANALYSIS REQUESTED

APPENDIX - B

Steam Generator A

Tube Sheet Anomalies

ETL, OXP, SKR, TMR, PTE, NTE & BLG

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: A
LOCATION: ALL
CRITERIA: ETL

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:13:22

*** NO CALLS IN THIS RANGE ***

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: A
LOCATION: ALL
CRITERIA: OXP

PAGE: 1 OF 4
DATE: 08/09/88
TIME: 14:15:21

ROW	COL	HEAT#	LEG	EXTENT			REEL	PROBE	LOCATION	CURRENT					
				REQ	TST	REM				VOLTS	MIL	DEG	%		
1	8		C	F/L	10H	RIT	004	610SM	TEC+	0.9	35.2	—	345	OXP	4
24	8		C	F/L	F/L		004	610SM	TEC+	1.2	20.1	—	345	OXP	4
28	8		C	F/L	F/L		004	610SM	TEC+	15.9	20.4	—	340	OXP	4
19	17		C	F/L	F/L		014	610SM	TEC+	9.7	20.3	—	186	OXP	4
20	18		C	F/L	F/L		016	610SM	TEC+	11.4	25.2	—	187	OXP	4
12	22		C	F/L	F/L		025	610SM	TEH+	7.4	30.9	—	183	OXP	4
26	22		C	F/L	F/L		024	610SM	TEH+	12.8 TO+ 15.2	21.8	—	0	OXP	4
43	23		C	F/L	F/L		029	610SM	TEH+	4.1	23.8	—	171	OXP	4
44	23		C	F/L	F/L		029	610SM	TEH+	2.5 TO+ 6.4	27.2	—	172	OXP	4
13	24		C	F/L	F/L		029	610SM	TEH+	19.3	21.8	—	171	OXP	4
22	26		C	F/L	F/L		032	610SM	TEC+	9.6	21.2	—	171	OXP	4
8	27		C	F/L	F/L		032	610SM	TEH+	8.8	22.0	—	170	OXP	4
9	27		C	F/L	F/L		032	610SM	TEH+	2.1	21.4	—	170	OXP	4
			C	F/L	F/L		032	610SM	TEC+	8.4	21.3	—	170	OXP	4
46	27		C	F/L	F/L		033	610SM	TEH+	2.8	21.1	—	169	OXP	4
10	28		C	F/L	F/L		036	610SM	TEH+	17.0	28.1	—	171	OXP	4
11	28		C	F/L	F/L		036	610SM	TEH+	3.7	20.4	—	171	OXP	4
			C	F/L	F/L		036	610SM	TEH+	16.1	28.6	—	171	OXP	4
12	28		C	F/L	F/L		036	610SM	TEH+	7.7	31.4	—	170	OXP	4
34	28		C	F/L	F/L		033	610SM	TEC+	6.9	22.2	—	170	OXP	4
43	29		C	F/L	F/L		038	610SM	TEH+	4.5	44.7	—	171	OXP	4
44	29		C	F/L	F/L		038	610SM	TEH+	5.8	37.7	—	174	OXP	4
			C	F/L	F/L		038	610SM	TEH+	5.9	37.9	—	173	OXP	4
46	29		C	F/L	F/L		038	610SM	TEH+	2.7	21.3	—	350	OXP	4
9	30		C	F/L	F/L		040	610SM	TEH+	1.5	45.4	—	192	OXP	4
			C	F/L	F/L		040	610SM	TEH+	16.2	20.7	—	189	OXP	4
13	30		C	F/L	F/L		040	610SM	TEH+	2.4	28.6	—	179	OXP	4
			C	F/L	F/L		040	610SM	TEH+	19.3	21.0	—	180	OXP	4
30	30		C	F/L	F/L		038	610SM	TEH+	21.6	24.0	—	350	OXP	4
12	31		C	F/L	F/L		040	610SM	TEC+	1.9	23.9	—	12	OXP	4
29	31		C	F/L	F/L		040	610SM	TEC+	1.8	34.0	—	9	OXP	4
33	31		C	F/L	F/L		040	610SM	TEH+	1.5	23.9	—	185	OXP	4
46	31		C	F/L	F/L		042	610SM	TEC+	19.9	20.6	—	351	OXP	4
29	32		C	F/L	F/L		042	610SM	TEC+	2.3	22.1	—	171	OXP	4
32	32		C	F/L	F/L		042	610SM	TEC+	1.5	21.0	—	169	OXP	4
46	33		C	F/L	F/L		046	610SM	TEH+	3.0	26.8	—	175	OXP	4
44	34		C	F/L	F/L		046	610SM	TEH+	16.8	51.7	—	177	OXP	4
43	35		C	F/L	F/L		047	610SM	TEH+	0.0 TO+ 5.0	21.2	—	187	OXP	4
46	35		C	F/L	F/L		047	610SM	TEH+	0.0 TO+ 4.9	31.6	—	190	OXP	4
9	36		C	F/L	F/L		049	610SM	TEH+	1.1	37.8	—	175	OXP	4
47	39		C	F/L	F/L		054	610SM	TEH+	2.7	27.3	—	192	OXP	4
41	40		C	F/L	F/L		054	610SM	TEH+	12.4	21.9	—	13	OXP	4
46	41		C	F/L	F/L		057	610SM	TEH+	3.1	54.6	—	177	OXP	4
36	51		C	F/L	F/L		074	610SM	TEH+	1.5	32.0	—	176	OXP	4
32	54		C	F/L	F/L		081	610SM	TEC+	4.1 TO+ 7.4	20.0	—	180	OXP	4

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: A
LOCATION: ALL
CRITERIA: OXP

PAGE: 2 OF 4
DATE: 08/09/88
TIME: 14:15:21

ROW	COL	HEAT#	LEG	EXTENT			REEL	PROBE	LOCATION	CURRENT						
				REQ	TST	REM				VOLTS	MIL	DEG	*			
33	54		C	F/L	F/L		081	610SM	TEC+	3.7	TO+	7.1	22.6	180	OXP	4
16	68		H	F/L	F/L		082	610SM	TEH+	22.2			22.0	183	OXP	4
19	69		H	F/L	F/L		082	610SM	TEH+	22.0			29.2	185	OXP	4
24	69		H	F/L	F/L		082	610SM	TEH+	21.9			24.1	183	OXP	4
27	69		H	F/L	F/L		082	610SM	TEH+	22.4			20.8	182	OXP	4
29	69		H	F/L	F/L		082	610SM	TEH+	22.0			21.6	182	OXP	4
41	70		H	F/L	F/L		080	610SM	TEH+	18.1			20.3	3	OXP	4
43	70		H	F/L	F/L		080	610SM	TEH+	0.0	TO+	2.1	22.1	6	OXP	4
22	75		H	F/L	F/L		068	610SM	TEH+	4.3			23.8	4	OXP	4
22	81		H	F/L	F/L		058	610SM	TEH+	5.1			33.8	6	OXP	4
41	83		H	F/L	F/L		055	610SM	TEH+	19.9			31.0	358	OXP	4
45	83		H	F/L	F/L		052	610SM	TEH+	17.7	TO+	21.2	28.9	6	OXP	4
46	83		H	F/L	F/L		052	610SM	TEH+	18.7	TO+	21.1	27.6	0	OXP	4
45	89		H	F/L	F/L		041	610SM	TEH+	0.0	TO+	21.1	59.7	356	OXP	4
27	90		H	F/L	F/L		039	610SM	TEC+	14.3			20.3	8	OXP	4
28	90		H	F/L	F/L		039	610SM	TEH+	15.5			22.8	9	OXP	4
29	90		H	F/L	F/L		039	610SM	TEH+	20.1			22.8	11	OXP	4
31	90		H	F/L	F/L		039	610SM	TEH+	3.0			22.6	5	OXP	4
			H	F/L	F/L		039	610SM	TEH+	16.9			22.9	189	OXP	4
32	90		H	F/L	F/L		039	610SM	TEH+	3.2			32.2	187	OXP	4
43	90		H	F/L	F/L		039	610SM	TEH+	2.9			32.4	5	OXP	4
44	90		H	F/L	F/L		039	610SM	TEC+	5.4			23.8	11	OXP	4
27	91		H	F/L	F/L		037	610SM	TEH+	4.0			26.2	5	OXP	4
31	91		H	F/L	F/L		037	610SM	TEC+	6.1			20.2	9	OXP	4
14	94		H	F/L	F/L		027	610SM	TEH+	3.3			26.6	10	OXP	4
21	95		H	F/L	F/L		030	610SM	TEH+	11.0			20.7	3	OXP	4
39	95		H	F/L	F/L		027	610SM	TEH+	14.4			21.3	183	OXP	4
45	95		H	F/L	F/L		027	610SM	TEH+	19.3			24.2	353	OXP	4
46	95		H	F/L	F/L		027	610SM	TEH+	6.8			22.8	7	OXP	4
18	97		H	F/L	F/L		028	610SM	TEH+	6.4			27.0	2	OXP	4
21	97		H	F/L	F/L		028	610SM	TEC+	17.4			23.6	185	OXP	4
16	98		H	F/L	F/L		026	610SM	TEH+	1.9			20.6	185	OXP	4
18	98		H	F/L	F/L		026	610SM	TEH+	15.0			20.5	0	OXP	4
19	98		H	F/L	F/L		026	610SM	TEH+	11.5			25.2	14	OXP	4
20	98		H	F/L	F/L		026	610SM	TEH+	2.9			22.9	199	OXP	4
25	98		H	F/L	F/L		026	610SM	TEC+	12.8			20.6	0	OXP	4
26	98		H	F/L	F/L		026	610SM	TEC+	11.9			21.3	9	OXP	4
35	98		H	F/L	F/L		026	610SM	TEH+	6.4			20.5	14	OXP	4
20	99		H	F/L	F/L		023	610SM	TEH+	2.2			23.2	325	OXP	4
24	99		H	F/L	F/L		023	610SM	TEH+	1.9			26.0	149	GXP	4
25	99		H	F/L	F/L		023	610SM	TEH+	4.3			21.7	329	OXP	4
			H	F/L	F/L		023	610SM	TEH+	17.1			20.7	151	OXP	4
28	99		H	F/L	F/L		023	610SM	TEH+	3.0			21.1	145	OXP	4
33	99		H	F/L	F/L		023	610SM	TEC+	20.1			20.2	355	OXP	4
3	100		H	F/L	F/L		022	610SM	TEH+	11.9			22.6	7	OXP	4

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: A
LOCATION: ALL
CRITERIA: OXP

PAGE: 3 OF 4
DATE: 08/09/88
TIME: 14:15:21

ROW	COL	HEAT#	LEG	EXTENT				LOCATION	CURRENT				
				REQ	TST	REM	REEL		VOLTS	MIL	DEG	%	
35	100		H	F/L	F/L		022	610SM TEC+	18.8	44.4	7	OXP	4
20	101		H	F/L	F/L		020	610SM TEH+	17.2	20.8	191	OXP	4
30	101		H	F/L	F/L		020	610SM TEH+	6.5	46.7	193	OXP	4
39	101		H	F/L	F/L		022	610SM TEH+	19.4	20.4	184	OXP	4
1	102		H	F/L	11C	RIT	020	610SM TEH+	15.2	28.3	11	OXP	4
3	102		H	F/L	F/L		020	610SM TEH+	15.3	23.3	190	OXP	4
			H	F/L	F/L		020	610SM TEH+	20.5	21.8	11	OXP	4
12	102		H	F/L	F/L		020	610SM TEH+	3.4	23.5	183	OXP	4
23	102		H	F/L	F/L		020	610SM TEC+	12.7	23.1	12	OXP	4
28	102		H	F/L	F/L		018	610SM TEH+	7.2	21.1	8	OXP	4
32	102		H	F/L	F/L		018	610SM TEH+	5.0	20.8	11	OXP	4
35	102		H	F/L	F/L		018	610SM TEH+	6.2	36.0	7	OXP	4
30	103		H	F/L	F/L		018	610SM TEH+	4.3	21.3	190	OXP	4
34	103		H	F/L	F/L		018	610SM TEH+	4.8	20.2	189	OXP	4
20	104		H	F/L	F/L		017	610SM TEH+	7.8	22.2	11	OXP	4
23	104		H	F/L	F/L		017	610SM TEH+	3.4	25.8	188	OXP	4
24	104		H	F/L	F/L		017	610SM TEH+	1.9	26.4	190	OXP	4
37	105		H	F/L	F/L		017	610SM TEC+	19.7	20.4	191	OXP	4
12	106		H	F/L	F/L		015	610SM TEC+	2.0	21.2	9	OXP	4
18	106		H	F/L	F/L		012	610SM TEH+	8.6	23.8	183	OXP	4
32	106		H	F/L	F/L		012	610SM TEC+	6.2	26.1	183	OXP	4
2	107		H	F/L	F/L		012	610SM TEH+	7.7	32.4	2	OXP	4
			H	F/L	F/L		012	610SM TEH+	16.0	23.7	183	OXP	4
3	107		H	F/L	F/L		012	610SM TEH+	7.0	23.9	186	OXP	4
8	107		H	F/L	F/L		012	610SM TEH+	3.2	22.0	3	OXP	4
23	107		H	F/L	F/L		012	610SM TEH+	2.2	25.4	183	OXP	4
26	107		H	F/L	F/L		012	610SM TEH+	3.9	40.0	7	OXP	4
27	107		H	F/L	F/L		012	610SM TEH+	9.0	25.7	185	OXP	4
4	108		H	F/L	F/L		012	610SM TEC+	8.0	30.0	5	OXP	4
3	109		H	F/L	F/L		010	610SM TEH+	3.1	21.5	192	OXP	4
6	109		H	F/L	F/L		010	610SM TEH+	6.1	29.5	15	OXP	4
21	109		H	F/L	F/L		010	610SM TEH+	3.2	28.8	193	OXP	4
22	109		H	F/L	F/L		010	610SM TEH+	5.9	31.3	196	OXP	4
23	109		H	F/L	F/L		010	610SM TEC+	20.0	20.6	190	OXP	4
2	111		H	F/L	F/L		009	610SM TEH+	12.6	26.5	164	OXP	4
3	111		H	F/L	F/L		009	610SM TEH+	10.0	29.4	185	OXP	4
11	111		H	F/L	F/L		009	610SM TEH+	3.9	22.4	186	OXP	4
14	111		H	F/L	F/L		009	610SM TEH-	8.2	24.5	7	OXP	4
1	112		H	F/L	11C	RIT	007	610SM TEH-	6.5	35.2	163	OXP	4
7	112		H	F/L	F/L		007	610SM TEH+	1.8	28.2	158	OXP	4
			H	F/L	F/L		007	610SM TEH+	4.7	24.2	162	OXP	4
11	112		H	F/L	F/L		007	610SM TEH+	14.8	23.3	161	OXP	4
8	113		H	F/L	F/L		007	610SM TEH+	14.6	26.1	345	OXP	4
10	113		H	F/L	F/L		007	610SM TEH+	12.7	22.3	168	OXP	4
10	114		H	F/L	F/L		005	610SM TEH+	2.9 TO+ 9.3	27.8	341	OXP	4

CONAM

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: A
LOCATION: ALL
CRITERIA: OXP

PAGE: 4 OF 4
DATE: 08/09/88
TIME: 14:15:21

ROW	COL	HEAT#	LEG	EXTENT			REEL	PROBE	LOCATION				CURRENT			
				REQ	TST	REM			VOLTS	MIL	DEG	%	CH			
11	114		H	F/L	F/L		005	610SM	TEH+	3.2	TO+	17.2	54.5	344	OXP	4
14	114		H	F/L	F/L		005	610SM	TEH+	2.6	TO+	14.6	35.6	337	OXP	4
15	114		H	F/L	F/L		005	610SM	TEH+	13.8	TO+	18.9	20.5	339	OXP	4
18	114		H	F/L	F/L		005	610SM	TEH+	4.6	TO+	19.2	48.4	336	OXP	4
19	114		H	F/L	F/L		005	610SM	TEH+	13.7	TO+	20.6	32.9	153	OXP	4
19	115		H	F/L	F/L		005	610SM	TEH+	9.1	TO+	13.8	23.6	162	OXP	4
9	116		H	F/L	F/L		005	610SM	TEC+	20.1			30.1	155	OXP	4
4	119		H	F/L	F/L		002	610SM	TEH+	16.7			40.7	171	OXP	4
10	119		H	F/L	F/L		002	610SM	TEH+	14.0			21.5	171	OXP	4

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 134

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: A
LOCATION: ALL
CRITERIA: SKR

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:17:00

ROW	COL	HEAT#	EXTENT				PROBE	LOCATION	CURRENT			
			LEG	REQ	TST	REM			VOLTS	MIL	DEG	%
26	26	C	F/L	F/L		032	610SM	TEC+	0.0 TO+	5.6	20.9	166
											SKR	4

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 1

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: A
LOCATION: ALL
CRITERIA: TMR

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:17:21

ROW	COL	HEAT#	EXTENT						LOCATION	CURRENT				
			LEG	REQ	TST	REM	REEL	PROBE		VOLTS	MIL	DEG	*	CH
7	9	C	F/L	F/L			004	610SM	TSH-	0.3	12.5	—	187	TMR M2
12	9	C	F/L	F/L			004	610SM	TSH-	0.3	20.9	—	9	TMR M2
13	9	C	F/L	F/L			004	610SM	TSH-	0.3	26.0	—	9	TMR M2
12	10	C	F/L	F/L			006	610SM	TSH-	0.3	22.2	—	6	TMR M2
13	10	C	F/L	F/L			006	610SM	TSH-	0.3	22.9	—	2	TMR M2
12	11	C	F/L	F/L			006	610SM	TSH-	0.3	25.6	—	5	TMR M2
13	15	C	F/L	F/L			013	610SM	TSH-	0.4	23.8	—	6	TMR M2
8	34	C	F/L	F/L			046	610SM	TSH-	0.4	23.7	—	0	TMR M2
15	37	C	F/L	F/L			049	610SM	TSH-	0.4	25.1	—	358	TMR M2
26	53	C	F/L	F/L			075	610SM	TSH-	0.3	8.5	—	16	TMR M2
2	59	H	F/L	F/L			094	610SM	TSH-	0.3	20.3	—	12	TMR M2
20	68	H	F/L	F/L			095	610SM	TSH-	0.3	26.1	—	185	TMR M2
6	69	H	F/L	F/L			082	610SM	TSC-	0.3	22.8	—	16	TMR M2
18	74	H	F/L	F/L			070	610SM	TSH-	0.3	21.2	—	186	TMR M2
44	84	H	F/I	F/L			052	610SM	TSC-	0.3	23.4	—	7	TMR M2
10	98	H	F/L	F/L			026	610SM	TSH-	0.4	20.0	—	6	TMR M2
10	99	H	F/L	F/L			023	610SM	TSC-	0.3	16.3	—	6	TMR M2

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 17

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: A
LOCATION: ALL
CRITERIA: PTE

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:17:50

ROW	COL	HEAT#	EXTENT				PROBE	LOCATION	CURRENT			
			LEG	REQ	TST	REM			VOLTS	MIL	DEG	%
35	21	C	F/L	F/L		024	610SM	TEH+ 16.6 TO+ 22.5	18.8	346	PTE	4

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 1

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: A
LOCATION: ALL
CRITERIA: NTE

PAGE: 1 OF 1
DATE: 08/08/88
TIME: 11:11:49

*** NO CALLS IN THIS RANGE ***

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: A
LOCATION: ALL
CRITERIA: BLG

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:18:09

*** NO CALLS IN THIS RANGE ***

APPENDIX - B
Steam Generator B
Tube Sheet Anomalies
ETL, OXP, SKR, TMR, PTE, NTE & BLG

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: B
LOCATION: ALL
CRITERIA: ETL

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:22:39

ROW	COL	HEAT#	EXTENT				PROBE	LOCATION	CURRENT			
			REQ	TST	REM	REEL			VOLTS	MIL	DEG	%
38	54	H	F/L	F/L		038	610SM	TSH+ 0.3	24.7			4
												ETL M2

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 1

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: B
LOCATION: ALL
CRITERIA: OXP

PAGE: 1 OF 4
DATE: 08/09/88
TIME: 14:24:44

ROW	COL	HEAT#	LEG	EXTENT			REEL	PROBE	LOCATION	CURRENT			
				REQ	TST	REM				VOLTS	MIL	DEG	*
5	3		H	F/L	F/L		001	610SM	TEH+ 17.1	27.4	177	OXP	4
6	3		H	F/L	F/L		037	610SM	TEH+ 16.3	26.7	175	OXP	4
			H	F/L	F/L		037	610SM	TEH+ 17.4 TO+ 19.4	21.8	11.5	OXP	4
7	3		H	F/L	F/L		001	610SM	TEH+ 21.0	25.7	56	OXP	4
14	3		H	F/L	F/L		001	610SM	TEH+ 20.2	23.9	2	OXP	4
16	4		H	F/L	F/L		001	610SM	TEH+ 9.4	22.4	2	OXP	4
			H	F/L	F/L		001	610SM	TEH+ 16.2	20.9	359	OXP	4
14	5		H	F/L	F/L		001	610SM	TEH+ 19.6	22.4	3	OXP	4
5	6		H	F/L	F/L		002	610SM	TEC+ 9.7 TO+ 4.5	25.5	183	OXP	4
7	6		H	F/L	F/L		002	610SM	TEC+ 8.0	20.8	3	OXP	4
16	6		H	F/L	F/L		002	610SM	TEH+ 8.4	21.5	185	OXP	4
22	6		H	F/L	F/L		002	610SM	TEH+ 21.6	22.9	3	OXP	4
24	6		H	F/L	F/L		002	610SM	TEH+ 16.6 TO+ 21.7	20.2	184	OXP	4
7	7		H	F/L	F/L		002	610SM	TEC+ 7.1	23.5	2	OXP	4
15	7		H	F/L	F/L		002	610SM	TEH+ 20.4	20.3	182	OXP	4
19	8		H	F/L	F/L		003	610SM	TEH+ 14.7	20.4	175	OXP	4
25	8		H	F/L	F/L		002	610SM	TEH+ 21.3	23.9	5	OXP	4
15	9		H	F/L	F/L		003	610SM	TEC+ 6.5	27.2	185	OXP	4
19	9		H	F/L	F/L		003	610SM	TEH+ 15.6	20.7	177	OXP	4
			H	F/L	F/L		003	610SM	TEC+ 6.3	24.2	180	OXP	4
26	9		H	F/L	F/L		003	610SM	TEH+ 17.6	24.6	181	OXP	4
19	11		H	F/L	F/L		004	610SM	TEH+ 6.6	34.3	5	OXP	4
23	11		H	F/L	F/L		004	610SM	TEH+ 7.0	48.4	5	OXP	4
27	11		H	F/L	F/L		004	610SM	TEH+ 6.7	43.2	5	OXP	4
28	11		H	F/L	F/L		004	610SM	TEH+ 3.0	21.4	182	OXP	4
9	12		H	F/L	F/L		005	610SM	TEC+ 16.3	23.2	180	OXP	4
13	12		H	F/L	F/L		005	610SM	TEC+ 16.3	27.9	183	OXP	4
27	12		H	F/L	F/L		004	610SM	TEH+ 3.9 TO+ 7.4	21.9	183	OXP	4
12	13		H	F/L	F/L		005	610SM	TEH+ 5.4 TO+ 7.5	20.6	183	OXP	4
14	13		H	F/L	F/L		005	610SM	TEH+ 4.7 TO+ 9.0	20.7	184	OXP	4
30	13		H	F/L	F/L		005	610SM	TEH+ 5.1 TO+ 9.4	22.2	183	OXP	4
35	14		H	F/L	F/L		005	610SM	TEH+ 0.5	22.9	0	OXP	4
3	15		H	F/L	F/L		006	610SM	TEC+ 4.6	20.7	3	OXP	4
19	15		H	F/L	F/L		006	610SM	TEH+ 16.9 TO+ 20.0	24.3	184	OXP	4
17	16		H	F/L	F/L		007	610SM	TEC+ 10.0	22.1	183	OXP	4
21	16		H	F/L	F/L		007	610SM	TEC+ 9.5	23.0	175	OXP	4
34	16		H	F/L	F/L		007	610SM	TEH+ 21.3	24.7	3	OXP	4
7	19		H	F/L	F/L		009	610SM	TEC+ 5.7	25.2	8	OXP	4
8	20		H	F/L	F/L		010	610SM	TEC+ 11.5	20.5	186	OXP	4
			H	F/L	F/L		010	610SM	TEC+ 8.7	28.0	7	OXP	4
14	20		H	F/L	F/L		010	610SM	TEH+ 15.7	31.6	0	OXP	2
29	20		H	F/L	F/L		010	610SM	TEC+ 11.7	31.3	189	OXP	4
36	20		H	F/L	F/L		010	610SM	TEC+ 15.5	20.1	6	OXP	4
37	20		H	F/L	F/L		010	610SM	TEC+ 12.4	20.1	189	OXP	4
41	20		H	F/L	F/L		010	610SM	TEH+ 11.6	22.7	188	OXP	4

CONAM

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: B
LOCATION: ALL
CRITERIA: OXP

PAGE: 2 OF 4
DATE: 08/09/88
TIME: 14:24:44

ROW	COL	HEAT#	LEG	EXTENT			REEL	PROBE	LOCATION	CURRENT				
				REQ	TST	REM				VOLTS	MIL	DEG	*	
8	21		H	F/L	F/L		010	610SM	TEC+	9.2	21.7	189	OXP	4
			H	F/L	F/L		010	610SM	TEC+	3.6	25.2	10	OXP	4
17	21		H	F/L	F/L		010	610SM	TEH+	6.3	22.8	10	OXP	4
25	21		H	F/L	F/L		010	610SM	TEH+	14.3	25.1	9	OXP	4
13	22		H	F/L	F/L		011	610SM	TEH+	10.6	22.7	0	OXP	4
17	22		H	F/L	F/L		011	610SM	TEH+	11.5	29.5	360	OXP	4
21	22		H	F/L	F/L		011	610SM	TEH+	11.0	29.5	359	OXP	4
25	22		H	F/L	F/L		011	610SM	TEH+	11.7	26.5	358	OXP	4
27	22		H	F/L	F/L		011	610SM	TEH+	16.3	22.9	179	OXP	4
20	23		H	F/L	F/L		012	610SM	TEC+	17.6	26.6	180	OXP	4
24	23		H	F/L	F/L		012	610SM	TEH+	7.1	43.5	359	OXP	4
			H	F/L	F/L		012	610SM	TEH+	9.0	20.5	0	OXP	4
41	24		H	F/L	F/L		012	610SM	TEC+	10.4	17.2	178	OXP	4
15	26		H	F/L	F/L		014	610SM	TEH+	7.7	20.2	3	OXP	4
29	26		H	F/L	F/L		014	610SM	TEH+	6.8	28.0	183	OXP	4
31	26		H	F/L	F/L		014	610SM	TEH+	10.9 TO+ 13.9	25.5	184	OXP	4
9	28		H	F/L	F/L		016	610SM	TEH+	19.6	39.9	348	OXP	4
18	28		H	F/L	F/L		016	610SM	TEH+	3.3	21.0	167	OXP	4
26	33		H	F/L	F/L		020	610SM	TEC+	7.5	22.2	347	OXP	4
45	33		H	F/L	F/L		020	610SM	TEH+	9.4	22.4	351	OXP	4
47	33		H	F/L	F/L		021	610SM	TEC+	17.2	23.5	349	OXP	4
21	37		H	F/L	F/L		023	610SM	TEC+	5.6	22.7	349	OXP	4
31	38		H	F/L	F/L		024	610SM	TEC+	9.9	21.0	350	OXP	4
24	41		H	F/L	F/L		027	610SM	TEH+	11.4	27.6	349	OXP	4
18	42		H	F/L	F/L		027	610SM	TEC+	8.1	20.6	347	OXP	4
20	42		H	F/L	F/L		027	610SM	TEC+	8.4	31.9	351	OXP	4
48	45		H	F/L	F/L		029	610SM	TEH+	16.1	21.8	169	OXP	4
35	54		H	F/L	F/L		038	610SM	TEC+	2.3	22.3	175	OXP	4
39	54		H	F/L	F/L		038	610SM	TEC+	2.6	42.7	175	OXP	4
40	54		H	F/L	F/L		038	610SM	TEC+	2.0	20.8	174	OXP	4
47	54		H	F/L	F/L		038	610SM	TEC+	2.5	29.3	175	OXP	4
9	55		H	F/L	F/L		039	610SM	TEH+	11.0	23.7	173	OXP	4
13	55		H	F/L	F/L		039	610SM	TEH+	10.3	20.0	173	OXP	4
17	55		H	F/L	F/L		039	610SM	TEH+	3.3 TO+ 13.3	22.6	174	OXP	4
1	57		C	11C	11C		093	610SM	TEC+	13.8	23.6	183	OXP	4
26	57		H	F/L	F/L		040	610SM	TEH+	1.6	20.5	178	OXP	4
20	58		H	F/L	F/L		041	610SM	TEH+	19.0	20.2	353	OXP	4
4	59		H	F/L	F/L		042	610SM	TEC+	19.8	21.7	0	OXP	4
27	63		H	F/L	F/L		044	610SM	TEH+	18.7	21.4	173	OXP	4
37	67		H	F/L	F/L		048	610SM	TEC+	9.3	22.1	174	OXP	4
33	69		H	F/L	F/L		049	610SM	TEH+	16.8	20.1	2	OXP	4
45	69		H	F/L	F/L		049	610SM	TEH+	16.3	25.2	0	OXP	4
			H	F/L	F/L		049	610SM	TEH+	17.5	20.3	2	OXP	4
2	72		H	F/L	F/L		052	610SM	TEH+	1.9	20.7	3	OXP	4
35	72		H	F/L	F/L		051	610SM	TEC+	3.6	24.0	359	OXP	4

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: B
LOCATION: ALL
CRITERIA: OXP

PAGE: 3 OF 4
DATE: 08/09/88
TIME: 14:24:44

ROW	COL	HEAT#	LEG	EXTENT				LOCATION	CURRENT				
				REQ	TST	REM	REEL		VOLTS	MIL	DEG	%	
20	73		H	F/L	F/L		052	610SM TEH+	1.4	20.3	357	OXP	4
34	74		H	F/L	F/L		053	610SM TEH+	3.9	20.7	179	OXP	4
2	78		H	F/L	F/L		057	610SM TEH+	1.9	33.3	359	OXP	4
6	78		H	F/L	F/L		057	610SM TEH+	2.6	38.1	358	OXP	4
10	78		H	F/L	F/L		056	610SM TEH+	2.4	32.5	11	OXP	4
40	78		H	F/L	F/L		056	610SM TEC+	9.6	25.4	191	OXP	4
44	78		H	F/L	F/L		056	610SM TEC+	8.6	41.1	192	OXP	4
48	78		H	F/L	F/L		056	610SM TEC+	9.0	35.4	191	OXP	4
26	79		H	F/L	F/L		057	610SM TEH+	2.1	20.6	356	OXP	4
42	79		H	F/L	F/L		057	610SM TEH+	2.0	27.0	1	OXP	4
43	79		H	F/L	F/L		057	610SM TEH+	4.5	23.0	359	OXP	4
41	82		H	F/L	F/L		059	610SM TEC+	18.2	25.3	357	OXP	4
39	88		H	F/L	F/L		089	610SM TEH+	4.3	20.1	0	OXP	4
4	90		H	F/L	F/L		066	610SM TEH+	2.4	37.6	1	OXP	4
16	90		H	F/L	F/L		066	610SM TEH+	2.4	38.6	359	OXP	4
9	95		H	F/L	F/L		071	610SM TEC+	8.6	21.3	3	OXP	4
25	95		H	F/L	F/L		071	610SM TEC+	7.3	23.3	7	OXP	4
39	96		H	F/L	F/L		073	610SM TEC+	14.6	20.7	14	OXP	4
2	103		H	F/L	F/L		079	610SM TEH+	8.3	21.1	189	OXP	4
24	105		H	F/L	F/L		080	610SM TEH+	5.1 TO+ 7.1	20.6	190	OXP	4
1	107		H	F/L	11C RIT		082	610SM TEH+	1.7 TO+ 10.5	47.7	16	OXP	4
6	107		H	F/L	F/L		082	610SM TEH+	8.3	21.6	13	OXP	4
			H	F/L	F/L		082	610SM TEH+	11.5	19.0	195	OXP	4
16	107		H	F/L	F/L		082	610SM TEH+	5.4	56.6	17	OXP	4
22	108		H	F/L	F/L		083	610SM TEC+	14.1	22.0	185	OXP	4
10	112		H	F/L	F/L		085	610SM TEC+	18.3	22.7	193	OXP	4
			H	F/L	F/L		085	610SM TEC+	12.6	22.5	12	OXP	4
19	112		H	F/L	F/L		085	610SM TEH+	2.1	31.7	13	OXP	4
			H	F/L	F/L		085	610SM TEH+	16.2	22.5	16	OXP	4
20	112		H	F/L	F/L		085	610SM TEH+	2.2	22.8	13	OXP	4
1	113		H	F/L	11C RIT		085	610SM TEH+	5.4	23.6	13	OXP	4
11	113		H	F/L	F/L		085	610SM TEC+	10.3	23.1	14	OXP	4
13	113		H	F/L	F/L		085	610SM TEH+	15.4	20.6	12	OXP	4
1	114		H	F/L	11C RIT		085	610SM TEH+	5.6	23.8	190	OXP	4
9	114		H	F/L	F/L		086	610SM TEC+	16.0	23.1	9	OXP	4
7	115		H	F/L	F/L		086	610SM TEC+	5.8	20.4	9	OXP	4
1	117		H	F/L	11C RIT		088	610SM TEH+	21.1	20.3	8	OXP	4
3	117		H	F/L	F/L		088	610SM TEH+	0.4	20.8	8	OXP	4
9	117		H	F/L	F/L		088	610SM TEH+	1.3	23.4	9	OXP	4
			H	F/L	F/L		088	610SM TEH+	3.0	20.4	183	OXP	4
11	117		H	F/L	F/L		088	610SM TEH+	1.2	21.6	186	OXP	4
14	117		H	F/L	F/L		088	610SM TEC+	1.1	26.0	10	OXP	4
1	118		H	F/L	11C RIT		088	610SM TEH+	2.3	21.6	182	OXP	4
5	118		H	F/L	F/L		088	610SM TEH+	2.8	27.8	13	OXP	4

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: B
LOCATION: ALL
CRITERIA: OXP

PAGE: 4 OF 4
DATE: 08/09/88
TIME: 14:24:44

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 123

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: B
LOCATION: ALL
CRITERIA: SKR

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:26:17

ROW	COL	HEAT#	LEG	EXTENT			REEL	PROBE	LOCATION	CURRENT					
				REQ	TST	REM				VOLTS	MIL	DEG	%	CH	
16	34		H	F/L	F/L		021	610SM	TEH+	3.0	25.4		347	SKR	2
45	42		H	F/L	F/L		028	610SM	TEC+	6.2	27.4		349	SKR	4

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 2

NO TEND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: B
LOCATION: ALL
CRITERIA: TMR

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:26:36

ROW	COL	HEAT#	LEG	EXTENT			PROBE	LOCATION	CURRENT			
				REQ	TST	REM			VOLTS	MIL	DEG	*
5	14	—	H	F/L	F/L	—	006	610SM TSC- 0.3	3.5	—	14	TMR 5
—	—	—	—	—	—	—	—	—	—	—	—	—
—	—	—	—	—	—	—	—	—	—	—	—	—

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 1

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: B
LOCATION: ALL
CRITERIA: PTE

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:26:58

*** NO CALLS IN THIS RANGE ***

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: B
LOCATION: ALL
CRITERIA: NTE

PAGE: 1 OF 1
DATE: 08/08/88
TIME: 11:14:07

ROW	COL	HEAT#	EXTENT			REEL	PROBE	LOCATION	CURRENT			
			LEG	REQ	1ST				VOLTS	MIL	DEG	%
19	25	H	F/L	F/L	—	013	610SM	TSC+ 0.0	3.1	—	353	NTE 1

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: . 1

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: B
LOCATION: ALL
CRITERIA: BLG

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:27:19

*** NO CALLS IN THIS RANGE ***

APPENDIX - B
Steam Generator C
Tube Sheet Anomalies
ETL, OXP, SKR, TMR, PTE, NTE & BLG

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: C
LOCATION: ALL
CRITERIA: ETL

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:52.46

ROW	COL	HEAT#	EXTENT				PROBE	LOCATION	CURRENT			
			REQ	TST	REM	REEL			VOLTS	MIL	DEG	%
3	24	H	F/L	F/L		014	610SM	TSH+	39.1	—	0	ETL

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 1

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: C
LOCATION: ALL
CRITERIA: OXP

PAGE: 1 OF 5
DATE: 08/09/88
TIME: 14:54:27

ROW	COL	HEAT#	LEG	EXTENT			REEL	PROBE	LOCATION	CURRENT						
				REQ	TST	REM				VOLTS	MIL	DEG	*			
1	14		C	11C	11C		097	610SM	TEC+	10.0	22.0	173	OXP	4		
13	14		H	F/L	F/L		007	610SM	TEH+	10.2	20.0	358	OXP	4		
13	19		H	F/L	F/L		010	610SM	TEH+	11.7	25.0	353	OXP	4		
21	19		H	F/L	F/L		010	610SM	TEH+	17.1	23.7	0	OXP	4		
36	19		H	F/L	F/L		010	610SM	TEH+	8.7	20.5	357	OXP	4		
16	20		H	F/L	F/L		011	610SM	TEH+	1.3	25.3	359	OXP	4		
10	21		H	F/L	F/L		011	610SM	TEC+	8.6	19.4	358	OXP	4		
6	23		H	F/L	F/L		013	610SM	TEH+	4.8	20.4	354	OXP	4		
22	24		H	F/L	F/L		014	610SM	TEH+	1.7	43.8	178	OXP	4		
			H	F/L	F/L		014	610SM	TEH+	1.8	29.9	353	OXP	4		
23	24		H	F/L	F/L		014	610SM	TEH+	9.0	20.2	180	OXP	4		
14	31		H	F/L	F/L		021	610SM	TEH+	3.2	28.7	7	OXP	4		
37	32		H	F/L	F/L		021	610SM	TEC+	8.4	24.5	187	OXP	4		
40	32		H	F/L	F/L		021	610SM	TEC+	8.0	28.9	187	OXP	4		
48	32		H	F/L	F/L		021	610SM	TEH+	13.6	20.2	7	OXP	4		
14	37		H	F/L	F/L		026	610SM	TEH+	1.0	20.5	188	OXP	4		
18	37		H	F/L	F/L		026	610SM	TEC+	4.5	TO+	11.5	22.9	7	OXP	4
20	37		H	F/L	F/L		026	610SM	TEC+	12.9	TO+	19.3	20.9	5	OXP	4
43	37		H	F/L	F/L		026	610SM	TEH+	1.9	37.7	9	OXP	4		
2	38		H	F/L	F/L		026	610SM	TEC+	2.7	TO+	6.6	27.5	6	OXP	4
22	38		H	F/L	F/L		027	610SM	TEC+	10.6	20.1	176	OXP	4		
34	38		H	F/L	F/L		027	610SM	TEC+	11.9	27.9	6	OXP	4		
41	38		H	F/L	F/L		027	610SM	TEC+	5.6	20.3	7	OXP	4		
29	39		H	F/L	F/L		028	610SM	TEH+	6.2	TO+	0.0	48.1	7	OXP	4
28	41		H	F/L	F/L		029	610SM	TEC+	3.5	32.1	183	OXP	4		
34	42		H	F/L	F/L		030	610SM	TEH+	2.5	26.1	11	OXP	4		
12	46		H	F/L	F/L		03	610SM	TEH+	1.7	41.7	7	OXP	4		
25	48		H	F/L	F/L		042	610SM	TEC+	6.9	25.6	353	OXP	4		
30	48		H	F/L	F/L		042	610SM	TEC+	6.4	20.7	347	OXP	4		
34	48		H	F/L	F/L		042	610SM	TEC+	8.1	TO+	11.2	22.6	351	OXP	4
37	48		H	F/L	F/L		042	610SM	TEC+	4.3	20.4	164	OXP	4		
41	48		H	F/L	F/L		042	610SM	TEC+	6.6	24.0	346	OXP	4		
44	48		H	F/L	F/L		042	610SM	TEC+	7.2	TO+	9.4	23.9	355	OXP	4
45	48		H	F/L	F/L		036	610SM	TEC+	19.4	19.7	185	OXP	4		
			H	F/L	F/L		036	610SM	TEC+	9.4	23.9	186	OXP	4		
46	48		H	F/L	F/L		036	610SM	TEC+	19.3	TO+	15.9	21.5	185	OXP	4
			H	F/L	F/L		036	610SM	TEC+	9.4	TO+	5.6	20.9	185	OXP	4
47	48		H	F/L	F/L		036	610SM	TEC+	14.9	TO+	17.5	23.4	0	OXP	4
16	49		H	F/L	F/L		036	610SM	TEC+	15.2	TO+	19.2	20.4	5	OXP	4
34	49		H	F/L	F/L		036	610SM	TEC+	5.5	TO+	14.0	20.2	7	OXP	4
45	51		H	F/L	F/L		037	610SM	TEH+	20.2	22.8	5	OXP	4		
12	52		H	F/L	F/L		038	610SM	TEH+	0.7	33.2	6	OXP	4		
13	56		H	F/L	F/L		044	610SM	TEH+	2.2	28.2	171	OXP	4		
35	56		H	F/L	F/L		044	610SM	TEC+	3.5	26.5	350	OXP	4		
6	57		H	F/L	F/L		044	610SM	TEH+	19.9	22.7	353	OXP	4		

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: C
LOCATION: ALL
CRITERIA: OXP

PAGE: 2 OF 5
DATE: 08/09/88
TIME: 14:54:27

ROW	COL	HEAT#	LEG	EXTENT				PROBE	LOCATION	CURRENT				
				REQ	TST	REM	REEL			VOLTS	MIL	DEG	%	CH
26	58		H	F/L	F/L		044	610SM	TEC+	5.3	27.1	350	OXP	4
43	62		H	F/L	F/L		048	610SM	TEC+	8.0	38.0	179	OXP	4
45	62		H	F/L	F/L		048	610SM	TEC+	5.6 TO+ 9.4	22.0	2	OXP	4
19	63		H	F/L	F/L		048	610SM	TEH+	2.6	25.1	182	OXP	4
38	63		H	F/L	F/L		049	610SM	TEH+	17.0	27.8	358	OXP	4
41	63		H	F/L	F/L		049	610SM	TEC+	5.4	32.3	0	OXP	4
42	63		H	F/L	F/L		049	610SM	TEC+	5.6	36.3	180	OXP	4
43	63		H	F/L	F/L		049	610SM	TEC+	9.5	20.8	176	OXP	4
12	64		H	F/L	F/L		049	610SM	TEC+	7.7 TO+ 10.9	24.6	0	OXP	4
43	64		H	F/L	F/L		049	610SM	TEC+	8.7	46.1	181	OXP	4
37	65		H	F/L	F/L		050	610SM	TEC+	11.5	25.0	6	OXP	4
40	65		H	F/L	F/L		050	610SM	TEC+	3.5 TO+ 7.8	22.9	2	OXP	4
41	65		H	F/L	F/L		050	610SM	TEC+	8.2 TO+ 16.9	25.0	0	OXP	4
23	66		H	F/L	F/L		051	610SM	TEC+	2.2	35.3	180	OXP	4
36	66		H	F/L	F/L		050	610SM	TEC+	7.9	38.9	3	OXP	4
37	66		H	F/L	F/L		050	610SM	TEC+	7.4	41.7	179	OXP	4
38	66		H	F/L	F/L		050	610SM	TEH+	3.0	21.5	182	OXP	4
41	66		H	F/L	F/L		050	610SM	TEH+	1.5	25.0	6	OXP	4
42	66		H	F/L	F/L		050	610SM	TEH+	11.4	21.8	359	OXP	4
47	66		H	F/L	F/L		050	610SM	TEC+	13.6 TO+ 18.5	31.4	359	OXP	4
20	67		H	F/L	F/L		051	610SM	TEC+	1.0	30.5	179	OXP	4
35	67		H	F/L	F/L		051	610SM	TEC+	4.4	21.8	178	OXP	4
36	67		H	F/L	F/L		051	610SM	TEC+	4.9	28.8	357	OXP	4
41	67		H	F/L	F/L		051	610SM	TEC+	6.6	30.1	0	OXP	4
47	67		H	F/L	F/L		051	610SM	TEC+	6.2	20.6	355	OXP	4
45	68		H	F/L	F/L		051	610SM	TEH+	1.0	36.2	4	OXP	4
8	69		H	F/L	F/L		052	610SM	TEH+	15.0	20.7	178	OXP	4
38	69		H	F/L	F/L		053	610SM	TEH+	1.7	50.5	3	OXP	4
			H	F/L	F/L		053	610SM	TEH+	17.1	29.7	3	OXP	4
10	70		H	F/L	F/L		053	610SM	TEH+	2.7 TO+ 4.7	26.3	182	OXP	4
13	70		H	F/L	F/L		053	610SM	TEC+	8.3	44.8	182	OXP	4
20	70		H	F/L	F/L		053	610SM	TEC+	14.9	20.1	3	OXP	4
27	70		H	F/L	F/L		053	610SM	TEC+	7.1 TO+ 9.6	25.5	2	OXP	4
28	70		H	F/L	F/L		053	610SM	TEC+	7.6 TO+ 10.5	29.6	359	OXP	4
40	70		H	F/L	F/L		053	610SM	TEC+	6.5	21.3	0	OXP	4
			H	F/L	F/L		053	610SM	TEC+	3.5	25.3	182	OXP	4
41	70		H	F/L	F/L		053	610SM	TEC+	15.1	23.7	0	OXP	4
			H	F/L	F/L		053	610SM	TEC+	12.0	20.9	353	OXP	4
42	70		H	F/L	F/L		053	610SM	TEC+	6.2	22.3	356	OXP	4
46	70		H	F/L	F/L		053	610SM	TEH+	21.6	21.1	358	OXP	4
15	71		H	F/L	F/L		054	610SM	TEH+	21.8	21.9	174	OXP	4
26	71		H	F/L	F/L		054	610SM	TEC+	1.6	21.2	171	OXP	4
28	71		H	F/L	F/L		054	610SM	TEC+	1.4	23.2	180	OXP	4
13	72		H	F/L	F/L		055	610SM	TEC+	2.0	20.6	180	OXP	4
33	72		H	F/L	F/L		055	610SM	TEC+	1.8	38.1	180	OXP	4

CONAM

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: C
LOCATION: ALL
CRITERIA: OXP

PAGE: 3 OF 5
DATE: 08/09/88
TIME: 14:54:27

ROW	COL	HEAT#	LEG	EXTENT				LOCATION	CURRENT				
				REQ	TST	REM	REEL		VOLTS	MIL	DEG	*	
												CH	
13	73		H	F/L	F/L		055	610SM TEH+	8.0	26.9	180	OXP	4
7	74		H	F/L	F/L		057	610SM TEC+	18.0	22.5	0	OXP	4
			H	F/L	F/L		057	610SM TEC+	1.9	38.2	181	OXP	4
45	74		H	F/L	F/L		056	610SM TEH+	1.3	33.8	2	OXP	4
24	75		H	F/L	F/L		057	610SM TEC+	2.5	38.3	179	OXP	4
25	75		H	F/L	F/L		057	610SM TEC+	20.1 TO+ 21.8	24.2	359	OXP	4
38	75		H	F/L	F/L		058	610SM TEH+	1.6	26.2	3	OXP	4
			H	F/L	F/L		058	610SM TEH+	15.7	28.0	3	OXP	4
39	75		H	F/L	F/L		058	610SM TEH+	13.3	29.7	358	OXP	4
40	75		H	F/L	F/L		058	610SM TEH+	12.7	20.7	182	OXP	4
11	76		H	F/L	F/L		059	610SM TEH+	0.0 TO+ 5.0	21.5	357	OXP	4
			H	F/L	F/L		059	610SM TEC+	3.8	24.5	359	OXP	4
21	77		H	F/L	F/L		059	610SM TEC+	9.5	22.1	180	OXP	4
40	77		H	F/L	F/L		059	610SM TEC+	6.6	28.5	177	OXP	4
22	78		H	F/L	F/L		060	610SM TEC+	7.9	28.7	0	OXP	4
23	78		H	F/L	F/L		060	610SM TEC+	2.0	28.1	177	OXP	4
32	78		H	F/L	F/L		060	610SM TEC+	0.0 TO+ 4.1	40.5	181	OXP	4
47	78		H	F/L	F/L		060	610SM TEC+	15.0	26.2	179	OXP	4
12	81		H	F/L	F/L		062	610SM TEC+	18.9	28.0	179	OXP	4
13	81		H	F/L	F/L		062	610SM TFC+	18.3	22.4	174	OXP	4
18	81		H	F/L	F/L		063	610SM TEH+	17.1	44.6	4	OXP	4
26	81		H	F/L	F/L		063	610SM TEC+	8.1	20.5	177	OXP	4
			H	F/L	F/L		063	610SM TEC+	2.7	27.7	176	OXP	4
46	81		H	F/L	F/L		063	610SM TEC+	6.8	25.3	0	OXP	4
47	81		H	F/L	F/L		063	610SM TEC+	11.9	24.1	357	OXP	4
19	82		H	F/L	F/L		064	610SM TEC+	4.1	24.0	178	OXP	4
26	82		H	F/L	F/L		064	610SM TEC+	4.2	25.5	357	OXP	4
14	83		H	F/L	F/L		064	610SM TEC+	4.1	27.0	359	OXP	4
15	83		H	F/L	F/L		064	610SM TEC+	8.2	25.6	177	OXP	4
22	83		H	F/L	F/L		064	610SM TEC+	6.5	24.1	357	OXP	4
18	84		H	F/L	F/L		066	610SM TEC+	3.1 TO+ 9.1	21.7	0	OXP	4
25	84		H	F/L	F/L		065	610SM TEC+	4.7	24.1	177	OXP	4
37	84		H	F/L	F/L		065	610SM TEC+	7.6	30.2	0	OXP	4
41	84		H	F/L	F/L		065	610SM TEC+	8.2	27.5	356	OXP	4
42	84		H	F/L	F/L		065	610SM TEC+	6.6	24.6	357	OXP	4
6	85		H	F/L	F/L		066	610SM TEC+	2.8	23.5	174	OXP	4
13	85		H	F/L	F/L		066	610SM TEC+	2.8	21.9	174	OXP	4
21	85		H	F/L	F/L		066	610SM TEC+	2.7	35.8	179	OXP	4
28	85		H	F/L	F/L		066	610SM TEH+	5.1	21.3	0	OXP	4
38	85		H	F/L	F/L		067	610SM TEH+	9.0 TO+ 18.8	23.1	3	OXP	4
39	85		H	F/L	F/L		067	610SM TEH+	15.4	22.5	358	OXP	4
47	85		H	F/L	F/L		067	610SM TEH+	2.6	21.2	0	OXP	4
			H	F/L	F/L		067	610SM TEC+	6.4	22.2	0	OXP	4
9	86		H	F/L	F/L		067	610SM TEC+	3.5	24.4	0	OXP	4
16	86		H	F/L	F/L		067	610SM TEC+	1.5	21.1	358	OXP	4

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: C
LOCATION: ALL
CRITERIA: OXP

PAGE: 4 OF 5
DATE: 08/09/88
TIME: 14:54:27

ROW	COL	HEAT#	EXTENT					PROBE	LOCATION	CURRENT			
			LEG	REQ	TST	REM	REEL			VOLTS	MIL	DEG	%
20	86		H	F/L	F/L		067	610SM	TEC+	4.1	20.5	173	OXP 4
21	86		H	F/L	F/L		067	610SM	TEC+	5.6	24.4	180	OXP 4
36	86		H	F/L	F/L		067	610SM	TEC+	7.6	23.2	358	OXP 4
37	86		H	F/L	21C RIT		068	610SM	TEH+	4.1	20.9	178	OXP 4
41	86		H	F/L	F/L		068	610SM	TEH+	1.7	26.2	177	OXP 4
			H	F/L	F/L		068	610SM	TEC+	6.0	24.9	359	OXP 4
5	87		H	F/L	F/L		068	610SM	TEC+	7.7 TO+ 11.9	24.9	359	OXP 4
18	87		H	F/L	F/L		068	610SM	TEH+	17.8	33.2	3	OXP 4
20	87		H	F/L	F/L		068	610SM	TEH+	13.7	23.1	358	OXP 4
24	87		H	F/L	F/L		068	610SM	TEH+	21.1	21.9	2	OXP 4
27	87		H	F/L	F/L		068	610SM	TEH+	11.7	30.3	0	OXP 4
28	87		H	F/L	F/L		068	610SM	TEH+	16.8	24.8	0	OXP 4
36	87		H	F/L	F/L		068	610SM	TEH+	20.3	20.4	358	OXP 4
47	87		H	F/L	F/L		068	610SM	TEC+	12.3	30.1	180	OXP 4
29	88		H	F/L	F/L		069	610SM	TEC+	3.4	33.2	0	OXP 4
30	88		H	F/L	F/L		069	610SM	TEC+	7.2	28.4	358	OXP 4
31	88		H	F/L	F/L		069	610SM	TEC+	8.3	24.0	355	OXP 4
33	88		H	F/L	F/L		069	610SM	TEC+	8.2	31.5	353	OXP 4
47	88		H	F/L	F/L		069	610SM	TEC+	4.0	28.3	0	OXP 4
17	89		H	F/L	F/L		070	610SM	TEC+	5.3	20.7	0	OXP 4
43	89		H	F/L	F/L		070	610SM	TEH+	2.5	24.2	178	OXP 4
45	89		H	F/L	F/L		070	610SM	TEH+	2.1	24.3	177	OXP 4
11	90		H	F/L	F/L		070	610SM	TEC+	6.8	32.2	179	OXP 4
12	90		H	F/L	F/L		071	610SM	TEC+	7.7	40.8	177	OXP 4
			H	F/L	F/L		071	610SM	TEC+	6.6	20.2	354	OXP 4
14	90		H	F/L	F/L		071	610SM	TEC+	7.1	21.4	177	OXP 4
16	90		H	F/L	F/L		071	610SM	TEC+	7.8	20.1	177	OXP 4
			H	F/L	F/L		071	610SM	TEC+	5.3	22.8	358	OXP 4
18	90		H	F/L	F/L		071	610SM	TEC+	6.6	21.8	180	OXP 4
19	90		H	F/L	F/L		071	610SM	TEC+	16.2	26.8	359	OXP 4
20	90		H	F/L	F/L		071	610SM	TEC+	7.4	28.3	179	OXP 4
25	90		H	F/L	F/L		071	610SM	TEC+	14.2	24.7	358	OXP 4
34	90		H	F/L	F/L		071	610SM	TEC+	9.5 TO+ 14.5	25.3	0	OXP 4
36	90		H	F/L	F/L		071	610SM	TEC+	10.1 TO+ 18.6	23.5	0	OXP 4
			H	F/L	F/L		071	610SM	TEC+	8.6	21.1	180	OXP 4
			H	F/L	F/L		071	610SM	TEC+	6.9	23.1	179	OXP 4
43	90		H	F/L	F/L		071	610SM	TEC+	5.7	42.6	359	OXP 4
44	90		H	F/L	F/L		071	610SM	TEC+	18.4	24.4	357	OXP 4
45	90		H	F/L	F/L		071	610SM	TEC+	13.8 TO+ 16.5	25.3	357	OXP 4
46	90		H	F/L	F/L		071	610SM	TEC+	5.8	30.7	0	OXP 4
8	91		H	F/L	F/L		072	610SM	TEC+	6.3	27.0	180	OXP 4
9	91		H	F/L	F/L		072	610SM	TEC+	19.2	25.8	180	OXP 4
38	91		H	F/L	F/L		071	610SM	TEC+	15.6	23.4	2	OXP 4
			H	F/L	F/L		071	610SM	TEC+	9.4	26.6	357	OXP 4
39	92		H	F/L	F/L		073	610SM	TEC+	8.9	21.8	174	OXP 4

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: C
LOCATION: ALL
CRITERIA: OXP

PAGE: 5 OF 5
DATE: 08/09/88
TIME: 14:54:27

ROW	COL	HEAT#	LEG	EXTENT			REEL	PROBE	LOCATION	CURRENT						
				REQ	TST	REM				VOLTS	MIL	DEG	%			
40	92		H	F/L	F/L		073	610SM	TEC+	6.5	TO+	13.4	29.8	175	OXP	4
48	92		H	F/L	F/L		073	610SM	TEH+	1.9			20.5	171	OXP	4
18	93		H	F/L	F/L		074	610SM	TEH+	18.4			30.4	354	OXP	4
26	93		H	F/L	F/L		073	610SM	TEC	2.6			35.7	168	OXP	4
32	93		H	F/L	F/L		073	610SM	TEC+	14.3	TO+	22.5	25.2	350	OXP	4
35	93		H	F/L	F/L		073	610SM	TEC+	9.3	TO+	19.7	27.6	174	OXP	4
36	93		H	F/L	F/L		073	610SM	TEC+	14.2			25.3	173	OXP	4
37	93		H	F/L	F/L		073	610SM	TEC+	5.2	TO+	11.3	21.8	173	OXP	4
40	93		H	F/L	F/L		073	610SM	TEC+	8.5			20.8	169	OXP	4
32	94		H	F/L	F/L		074	610SM	TEC+	12.8	TO+	21.7	27.9	183	OXP	4
40	95		H	F/L	F/L		075	610SM	TEC+	15.0			23.3	170	OXP	4
43	99		C	F/L	F/L		098	610SM	TEC+	7.3			23.4	7	OXP	4
9	100		H	F/L	F/L		079	610SM	TEC+	7.7			21.3	160	OXP	4
41	100		H	F/L	F/L		080	610SM	TEH+	1.3	TO+	7.3	20.6	9	OXP	4
1	101		H	F/L	11C RIT		080	610SM	TEH+	1.3			26.2	2	OXP	4
2	101		H	F/L	F/L		080	610SM	TEH+	1.1			21.1	0	OXP	4
4	101		H	F/L	F/L		080	610SM	TEH+	1.2			21.6	2	OXP	4
41	102		C	F/L	F/L		098	610SM	TEC+	16.0			20.6	8	OXP	4
10	109		H	F/L	F/L		086	610SM	TEC+	4.8			22.3	6	OXP	4
28	110		H	F/L	F/L		087	610SM	TEC+	5.0	TO+	11.7	20.5	14	OXP	4
19	113		H	F/L	F/L		088	610SM	TEH+	2.1			23.2	4	OXP	4
26	113		H	F/L	F/L		088	610SM	TEH+	17.9			23.4	7	OXP	4
8	114		H	F/L	F/L		089	610SM	TEC+	8.7			20.8	7	OXP	4
24	114		H	F/L	F/L		089	610SM	TEH+	6.5	TO+	15.7	33.0	4	OXP	4
25	114		H	F/L	F/L		089	610SM	TEH+	3.8	TO+	13.3	25.1	6	OXP	4
8	115		H	F/L	F/L		089	610SM	TEC+	4.9			22.3	3	OXP	4

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 189

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: C
LOCATION: ALL
CRITERIA: SKR

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:56:42

ROW	COL	HEAT#	EXTENT				PROBE	LOCATION	CURRENT			
			LEG	REQ	TST	REM			VOLTS	MIL	DEG	%
21	21		H	F/L	F/L		012	610SM	TEH+	1.4	20.4	0
43	37		H	F/L	F/L		026	610SM	TEH+	17.9	27.7	5
14	69		H	F/L	F/L		052	610SM	TEH+	4.0	22.1	355

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 3

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: C
LOCATION: ALL
CRITERIA: TMR

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:57:01

*** NO CALLS IN THIS RANGE ***

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: C
LOCATION: ALL
CRITERIA: PTE

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:57:20

*** NO CALLS IN THIS RANGE ***

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: C
LOCATION: ALL
CRITERIA: NTE

PAGE: 1 OF 1
DATE: 08/08/88
TIME: 11:18:39

*** NO CALLS IN THIS RANGE ***

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: C
LOCATION: ALL
CRITERIA: BLG

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:57:44

ROW	COL	HEAT#	EXTENT				REEL	PROBE	LOCATION	CURRENT				
			LEG	REQ	TST	REM				VOLTS	MIL	DEG	*	CH
35	49		H	F/L	F/L		036	610SM	TSH+ 0.9	3.6			3	BLG 1

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 1

NO TREND ANALYSIS REQUESTED

APPENDIX - B
Steam Generator D
Tube Sheet Anomalies
ETL, OXP, SKR, TMR, PTE, NTE & BLG

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: D
LOCATION: ALL
CRITERIA: ETL

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 15:02:48

ROW	COL	HEAT#	LEG	EXTENT			REEL	PROBE	LOCATION	CURRENT			
				REQ	TST	REM				VOLTS	MIL	DEG	%
12	94		H	F/L	F/L		083	610SM	TSC+ 0.4	9.7	40	ETL	5

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 1

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: D
LOCATION: ALL
CRITERIA: OXP

PAGE: 1 OF 6
DATE: 08/10/88
TIME: 12:25:27

ROW	COL	HEAT#	EXTENT				REEL	PROBE	LOCATION	CURRENT				
			LEG	REQ	TST	REM				VOLTS	MIL	DEG	%	CH
2	1	H	F/L	F/L			005	610SM	TEC+	3.3	26.0	178	OXP	4
8	1	H	F/L	F/L			001	610SM	TEH+	0.0 TO+ 20.9	94.2	182	OXP	4
2	2	H	F/L	F/L			005	610SM	TEH+	2.0	20.2	0	OXP	4
3	2	H	F/L	F/L			005	610SM	TEC+	2.0	20.9	359	OXP	4
2	4	H	F/L	F/L			005	610SM	TEH+	2.3	104.4	6	OXP	4
		H	F/L	F/L			005	610SM	TEH+	9.4	26.5	356	OXP	4
11	6	H	F/L	F/L			002	610SM	TEC+	5.3 TO+ 16.4	30.5	2	OXP	4
16	6	H	F/L	F/L			002	610SM	TEH+	2.9	98.6	5	OXP	4
19	6	H	F/L	F/L			002	610SM	TEH+	1.3 TO+ 9.8	69.0	180	OXP	4
22	6	H	F/L	F/L			002	610SM	TEC+	2.1	64.9	4	OXP	4
24	6	H	F/L	F/L			002	610SM	TEH+	10.3	20.5	0	OXP	4
2	7	H	F/L	F/L			005	610SM	TEC+	3.3	76.5	183	OXP	4
5	7	H	F/L	F/L			002	610SM	TEH+	1.9	47.7	3	OXP	4
7	7	H	F/L	F/L			003	610SM	TEH+	1.8 TO+ 6.3	82.8	3	OXP	4
8	7	H	F/L	F/L			003	610SM	TEH+	1.9	63.3	6	OXP	4
		H	F/L	F/L			003	610SM	TEH+	20.5	36.8	0	OXP	4
11	7	H	F/L	F/L			003	610SM	TEH+	4.5	33.6	4	OXP	4
19	8	H	F/L	F/L			003	610SM	TEC+	16.3	25.9	182	OXP	4
		H	F/L	F/L			003	610SM	TEC+	1.9	69.2	184	OXP	4
1	9	C	11C	11C			038	610SM	TEC+	0.7 TO+ 4.8	39.6	5	OXP	4
4	9	H	F/L	F/L			003	610SM	TEC+	1.9	31.9	359	OXP	4
5	9	H	F/L	F/L			003	610SM	TEC+	2.0	24.0	0	OXP	4
7	9	H	F/L	F/L			003	610SM	TEC+	2.6	22.3	0	OXP	4
2	10	H	F/L	F/L			005	610SM	TEH+	1.5 TO+ 7.2	46.2	3	OXP	4
4	10	H	F/L	F/L			004	610SM	TEC+	1.5 TO+ 7.1	31.1	4	OXP	4
12	10	H	F/L	F/L			004	610SM	TEC+	1.8	56.3	181	OXP	4
13	10	H	F/L	F/L			004	610SM	TEC+	19.6	21.5	0	OXP	4
28	10	H	F/L	F/L			004	610SM	TEH+	1.7	74.8	5	OXP	4
		H	F/L	F/L			004	610SM	TEH+	5.4	30.2	0	OXP	4
30	10	H	F/L	F/L			004	610SM	TEC+	11.9	21.8	183	OXP	4
		H	F/L	F/L			004	610SM	TEC+	1.6 TO+ 11.5	20.4	183	OXP	4
11	11	H	F/L	F/L			004	610SM	TEC+	3.2 TO+ 8.6	27.5	182	OXP	4
21	11	H	F/L	F/L			004	610SM	TEH+	1.4	46.4	2	OXP	4
22	11	H	F/L	F/L			004	610SM	TEC+	2.1	22.7	2	OXP	4
26	11	H	F/L	F/L			005	610SM	TEH+	1.1	64.6	4	OXP	4
		H	F/L	F/L			005	610SM	TEH+	21.5	16.4	357	OXP	4
27	11	H	F/L	F/L			005	610SM	TEH+	2.0	61.9	5	OXP	4
		H	F/L	F/L			005	610SM	TEH+	13.9	25.8	0	OXP	4
5	12	H	F/L	F/L			005	610SM	TEH+	1.6	49.3	0	OXP	4
11	12	H	F/L	F/L			005	610SM	TEC+	1.5 TO+ 10.1	34.2	359	OXP	4
16	12	H	F/L	F/L			005	610SM	TEH+	1.0 TO+ 6.5	58.8	2	OXP	4
17	12	H	F/L	F/L			005	610SM	TEC+	1.9 TO+ 7.9	37.9	3	OXP	4
22	12	H	F/L	F/L			005	610SM	TEC+	5.5	36.9	181	OXP	4
24	12	H	F/L	F/L			005	610SM	TEH+	1.3	35.7	5	OXP	4
2	13	H	F/L	F/L			005	610SM	TEC+	1.2	79.4	181	OXP	4

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: D
LOCATION: ALL
CRITERIA: OXP

PAGE: 2 OF 6
DATE: 08/10/88
TIME: 12:25:27

ROW	COL	HEAT#	LEG	EXTENT				LOCATION	CURRENT			
				REQ	TST	REM	REEL		VOLTS	MIL	DEG	*
2	13		H	F/L	F/L		006	610SM TEC+	1.2	29.4	181	OXP 4
19	13		H	F/L	F/L		006	610SM TEC+	0.0 TO+ 10.9	38.0	182	OXP 4
22	14		H	F/L	F/L		006	610SM TEH+	4.7	38.6	1	OXP 4
34	14		H	F/L	F/L		006	610SM TFH+	0.0 TO+ 8.1	32.8	2	OXP 4
34	15		H	F/L	F/L		007	610SM TEH+	1.7	51.2	2	OXP 4
4	16		H	F/L	F/L		008	610SM TEC+	7.3	32.7	177	OXP 4
			H	F/L	F/L		008	610SM TEC+	2.5	92.7	187	OXP 4
13	16		H	F/L	F/L		008	610SM TEC+	1.3	60.9	3	OXP 4
8	18		H	F/L	F/L		009	610SM TEH+	2.7	49.2	2	OXP 4
11	18		H	F/L	F/L		009	610SM TEC+	10.0	34.1	180	OXP 4
			H	F/L	F/L		009	610SM TEC+	1.9	50.9	3	OXP 4
16	18		H	F/L	F/L		009	610SM TEH+	1.1	40.7	2	OXP 4
			H	F/L	F/L		009	610SM TEH+	4.9	20.2	0	OXP 4
1	18		H	F/L	F/L		009	610SM TEC+	6.7	36.0	180	OXP 4
			H	F/L	F/L		009	610SM TEC+	1.8	58.2	182	OXP 4
22	18		H	F/L	F/L		009	610SM TEC+	6.2	68.3	184	OXP 4
24	18		H	F/L	F/L		009	610SM TEH+	1.0	42.8	1	OXP 4
			H	F/L	F/L		009	610SM TEH+	9.8	21.7	358	OXP 4
19	19		H	F/L	F/L		009	610SM TEC+	11.1	20.5	177	OXP 4
			H	F/L	F/L		009	610SM TEC+	3.4	20.9	351	OXP 4
34	20		H	F/L	F/L		010	610SM TEH+	6.2	2.5	180	OXP 4
1	21	C	11C	11C			038	610SM TEC+	0.0 TO+ 2.8	25.3	3	OXP 4
8	21		H	F/L	F/L		011	610SM TEH+	0.1 TO+ 4.0	26.7	1	OXP 4
15	21		H	F/L	F/L		0.1	610SM TEC+	0.0 TO+ 7.3	39.4	183	OXP 4
30	22		H	F/L	F/L		012	610SM TEC+	0.0 TO+ 2.2	28.9	357	OXP 4
39	22		H	F/L	F/L		012	610SM TEC+	0.0 TO+ 18.1	21.8	183	OXP 4
			H	F/L	F/L		011	610SM TEC+	0.0 TO+ 18.0	21.5	180	OXP 4
7	23		H	F/L	F/L		012	610SM TEC+	0.0 TO+ 16.6	23.9	175	OXP 4
26	23		H	F/L	F/L		013	610SM TEH+	1.0	34.9	2	OXP 4
			H	F/L	F/L		013	610SM TEH+	21.0	28.2	0	OXP 4
32	24		H	F/L	F/L		013	610SM TEH+	15.6	20.3	3	OXP 4
2	25		H	F/L	F/L		014	610SM TEC+	6.2	23.9	176	OXP 4
22	26		H	F/L	F/L		015	610SM TEH+	4.6	36.0	355	OXP 4
40	26		H	F/L	F/L		015	610SM TEH+	2.8	22.1	5	OXP 4
			H	F/L	F/L		015	610SM TEH+	13.1	25.0	0	OXP 4
41	26		H	F/L	F/L		015	610SM TEH+	13.8	27.7	177	OXP 4
46	26		H	F/L	F/L		015	610SM TEH+	3.0	23.1	0	OXP 4
1	27	C	11C	11C			038	610SM TEC+	2.6	48.9	6	OXP 4
8	27		H	F/L	F/L		016	610SM TEH+	5.5	20.1	0	OXP 4
15	27		H	F/L	F/L		016	610SM TEC+	0.0 TO+ 9.8	26.1	182	OXP 4
16	27		H	F/L	F/L		016	610SM TEH+	2.5	25.9	0	OXP 4
44	27		H	F/L	F/L		017	610SM TEH+	1.5	49.3	3	OXP 4
			H	F/L	F/L		017	610SM TEH+	6.0	22.0	0	OXP 4
45	27		H	F/L	F/L		017	610SM TEC+	8.2	20.1	182	OXP 4
8	30		H	F/L	F/L		019	610SM TEH+	2.1	77.2	2	OXP 4

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: D
LOCATION: ALL
CRITERIA: OXP

PAGE: 3 OF 6
DATE: 08/10/88
TIME: 12:25:27

ROW	COL	HEAT#	LEG	EXTENT		REEL	PROBE	LOCATION	CURRENT				
				REQ	TST				VOLTS	MIL	DEG	%	CH
2	31		H	F/L	F/L	019	610SM	TEC+	0.0 TO+	6.8	33.5	178	OXP 4
38	31		H	F/L	F/L	020	610SM	TEC+	2.5		88.6	185	OXP 4
31	32		H	F/L	F/L	020	610SM	TEH+	15.1		21.0	0	OXP 4
15	33		H	F/L	F/L	021	610SM	TEC+	5.2		20.7	180	OXP 4
			H	F/L	F/L	021	610SM	TEC+	1.9		54.3	184	OXP 4
35	33		H	F/L	F/L	022	610SM	TEH+	1.6		50.9	2	OXP 4
			H	F/L	F/L	022	610SM	TEH+	4.5		20.1	0	OXP 4
45	33		H	F/L	F/L	022	610SM	TEC+	7.4		33.4	182	OXP 4
			H	F/L	F/L	022	610SM	TEC+	1.1		57.6	185	OXP 4
7	35		H	F/L	F/L	023	610SM	TEC+	1.0 TO+	15.9	27.1	180	OXP 4
32	36	P	F/L	F/L		024	610SM	TEH+	2.4		42.9	4	OXP 4
			H	F/L	F/L	024	610SM	TEH+	20.8		34.5	0	OXP 4
34	40		H	F/L	F/L	028	610SM	TEC+	6.2		25.3	180	OXP 4
2	41		H	F/L	F/L	029	610SM	TEC-	1.5 TO+	18.2	24.5	180	OXP 4
10	41		H	F/L	F/L	029	610SM	TEH+	8.4 TO+	20.4	20.3	0	OXP 4
11	41		H	F/L	F/L	029	610SM	TEH+	9.6		24.7	2	OXP 4
46	42		H	F/L	F/L	030	610SM	TEC+	2.4		44.8	182	OXP 4
4	45		H	F/L	F/L	033	610SM	TEH+	1.6		25.0	180	OXP 4
15	45		H	F/L	F/L	032	610SM	TEC+	0.0 TO+	14.2	27.6	177	OXP 4
20	46		H	F/L	F/L	033	610SM	TEH+	1.6		28.0	0	OXP 4
25	46		H	F/L	F/L	033	610SM	TEC+	4.2		20.5	184	OXP 4
34	46		H	F/L	F/L	033	610SM	TEC+	4.9		33.6	5	OXP 4
			H	F/L	F/L	033	610SM	TEC+	1.9		29.9	185	OXP 4
37	46		H	F/L	F/L	033	610SM	TEC+	21.8		21.4	4	OXP 4
2	47		H	F/L	F/L	035	610SM	TEC+	19.1		26.3	180	OXP 4
			H	F/L	F/L	035	610SM	TEC+	3.7		71.1	182	OXP 4
2	49		H	F/L	F/L	037	610SM	TEC+	0.1 TO+	2.4	49.5	0	OXP 4
15	51		H	F/L	F/L	039	610SM	TEH+	1.9		25.7	6	OXP 4
4	52		H	F/L	F/L	039	610SM	TEH+	1.5		21.5	9	OXP 4
6	52		H	F/L	F/L	039	610SM	TEH+	1.6		30.8	10	OXP 4
15	52		H	F/L	F/L	039	610SM	TEH+	1.7		22.7	9	OXP 4
25	52		H	F/L	F/L	040	610SM	TEC+	0.7 TO+	4.9	41.9	3	OXP 4
32	52		H	F/L	F/L	040	610SM	TEC+	11.3 TO+	16.1	20.3	179	OXP 4
30	53		H	F/L	F/L	040	610SM	TEC+	0.7 TO+	6.6	22.4	2	OXP 4
5	54		H	F/L	F/L	041	610SM	TEC+	0.3 TO+	3.3	24.3	187	OXP 4
2	55		H	F/L	F/L	042	610SM	TEC+	20.8		21.1	169	OXP 4
13	55		H	F/L	F/L	042	610SM	TEC+	1.3 TO+	6.0	35.8	1	OXP 4
3	58		H	F/L	F/L	044	610SM	TEC+	1.4		52.6	352	OXP 4
25	58		H	F/L	F/L	045	610SM	TEC+	0.0 TO+	4.8	48.0	194	OXP 4
32	58		H	F/L	F/L	045	610SM	TEC+	0.0 TO+	3.1	24.6	191	OXP 4
30	59		H	F/L	F/L	045	610SM	TEC+	6.2 TO+	8.8	28.3	190	OXP 4
			H	F/L	F/L	045	610SM	TEC+	0.3 TO+	1.8	23.7	196	OXP 4
15	60		H	F/L	F/L	047	610SM	TEH+	15.0 TO+	19.3	21.8	177	OXP 4
3	61		H	F/L	F/L	047	610SM	TEC+	3.7		28.6	179	OXP 4
13	61		H	F/L	F/L	047	610SM	TEC+	5.3		23.1	178	OXP 4

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: D
LOCATION: ALL
CRITERIA: OXP

PAGE: 4 OF 6
DATE: 08/10/88
TIME: 12:25:27

ROW	COL	HEAT#	LEG	EXTENT			REEL	PROBE	LOCATION	CURRENT				
				REQ	TST	REM				VOLTS	MIL	DEG	%	
16	63		H	F/L	F/L		049	610SM	TEC+	1.3	79.0	197	OXP	4
30	63		H	F/L	F/L		050	610SM	TEC+	1.0	27.1	175	OXP	4
27	64		H	F/L	F/T		052	610SM	TEC+	1.7 TO+ 19.3	29.4	190	OXP	4
35	64		H	F/L	F/L		050	610SM	TEH+	2.0	53.1	358	OXP	4
			H	F/L	F/L		050	610SM	TEH+	4.9	23.2	0	OXP	4
			H	F/L	F/L		050	610SM	TEH+	16.5	20.7	354	OXP	4
47	65		H	F/L	F/L		053	610SM	TEC+	5.8	26.1	180	OXP	4
43	66		H	F/L	F/L		053	610SM	TEH+	16.0	24.2	358	OXP	4
			H	F/L	F/L		053	610SM	TEH+	19.5	22.4	355	OXP	4
33	67		H	F/L	F/L		054	610SM	TEH+	0.0 TO+ 2.6	93.6	357	OXP	4
			H	F/L	F/L		054	610SM	TEH+	2.5 TO+ 4.8	63.3	358	OXP	4
16	69		H	F/L	F/L		055	610SM	TEC+	2.6 TO+ 0.0	36.6	197	OXP	4
30	69		H	F/L	F/L		055	610SM	TEC+	3.4	37.6	197	OXP	4
			H	F/L	F/L		055	610SM	TEC+	1.0	24.9	19	OXP	4
45	69		H	F/L	F/L		056	610SM	TEC+	2.3	25.9	351	OXP	4
3	70		H	F/L	F/L		057	610SM	TEC+	4.0 TO+ 21.3	33.7	191	OXP	4
			H	F/L	F/L		057	610SM	TEC+	0.1 TO+ 3.8	61.4	197	OXP	4
27	70		H	F/L	F/L		056	610SM	TEC+	2.6	34.2	359	OXP	4
35	70		H	F/L	F/T		056	610SM	TEH+	0.2 TO+ 15.6	73.7	357	OXP	4
46	71		H	F/L	F/L		058	610SM	TEC+	7.9	22.5	180	OXP	4
			H	F/L	F/L		058	610SM	TEC+	2.7	22.8	3	OXP	4
			H	F/L	F/L		058	610SM	TEC+	1.2	73.2	183	OXP	4
47	71		H	F/L	F/L		058	610SM	TEC+	5.6	24.8	180	OXP	4
43	72		H	F/L	F/L		058	610SM	TEH+	18.7	32.5	1	OXP	4
27	73		H	F/L	F/L		059	610SM	TEC+	5.9	21.0	0	OXP	4
			H	F/L	F/L		059	610SM	TEC+	1.1	78.2	182	OXP	4
28	73		H	F/L	F/L		059	610SM	TEC+	0.0 TO+ 6.1	30.2	0	OXP	4
33	73		H	F/L	F/L		059	610SM	TEH+	2.0	125.7	3	OXP	4
			H	F/L	F/L		059	610SM	TEH+	4.2 TO+ 20.0	31.8	178	OXP	4
43	73		H	F/L	F/L		059	610SM	TEC+	3.4	25.8	176	OXP	4
30	75		H	F/L	F/L		061	610SM	TEC+	0.0 TO+ 3.7	30.6	189	OXP	4
3	76		H	F/L	F/L		062	610SM	TEC+	20.2	41.7	196	OXP	4
4	76		H	F/L	F/L		062	610SM	TEC+	15.1	32.9	19	OXP	4
23	77		H	F/L	F/L		062	610SM	TEH+	9.7	27.2	18	OXP	4
44	77		H	F/L	F/L		063	610SM	TEH+	17.9	20.4	358	OXP	4
43	78		H	F/L	F/L		063	610SM	TEH+	15.6	21.1	180	OXP	4
2	79		H	F/L	F/L		063	610SM	TEC+	0.3 TO+ 19.1	27.3	173	OXP	4
46	83		H	F/L	F/L		067	610SM	TEH+	6.7	21.1	197	OXP	4
30	84		H	F/L	F/L		068	610SM	TEH+	16.6	42.6	10	OXP	4
38	86		H	F/L	F/L		070	610SM	TEH+	0.0 TO+ 4.6	33.3	195	OXP	4
3	87		H	F/L	F/L		073	610SM	TEC+	6.2	24.2	3	OXP	4
22	87		H	F/L	F/L		071	610SM	TEH+	10.7	20.0	165	OXP	4
27	87		H	F/L	F/L		071	610SM	TEH+	9.0	20.8	164	OXP	4
2	88		H	F/L	F/L		095	610SM	TEC+	6.1	33.9	197	OXP	4
			H	F/L	F/L		075	610SM	TEC+	6.0	33.6	193	OXP	4

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STFAM GENERATOR: D
LOCATION: ALL
CRITERIA: OXP

PAGE: 5 OF 6
DATE: 08/10/88
TIME: 12:25:27

ROW	COL	HEAT#	LEG	EXTENT				PROBE	LOCATION	CURRENT				
				REQ	TST	REM	REEL			VOLTS	MIL	DEG	*	CH
20	89		H	F/L	F/L		075	610SM	TEH+	7.9	21.2	195	OXP	4
27	89		H	F/L	F/L		075	610SM	TEH+	6.6 TO+ 9.2	20.1	193	OXP	4
43	89		H	F/L	F/L		075	610SM	TFH+	8.9	20.7	193	OXP	4
26	90		H	F/L	F/L		077	610SM	TEH+	10.0	20.0	168	OXP	4
43	90		H	F/L	F/L		077	610SM	TEH+	9.4	22.8	353	OXP	4
1	91		H	F/L	11C	RIT	079	610SM	TEH+	8.6 TO+ 11.2	20.3	163	OXP	4
20	91		H	F/L	F/L		079	610SM	TEH+	8.3	22.5	166	OXP	4
18	92		H	F/L	F/L		081	610SM	TEC+	1.8	43.7	198	OXP	4
45	92		H	F/L	F/L		081	610SM	TEC+	2.6 TO+ 0.5	30.8	196	OXP	4
46	92		H	F/L	F/L		081	610SM	TEC+	1.0	49.6	197	OXP	4
7	94		H	F/L	F/L		083	610SM	TEC+	1.7	23.8	182	OXP	4
9	97		H	F/L	F/L		088	610SM	TEC+	7.4 TO+ 21.0	19.3	15	OXP	4
15	97		H	F/L	F/L		088	610SM	TEC+	11.3 TO+ 8.6	20.1	195	OXP	4
27	98		H	F/L	F/L		089	610SM	TEC+	9.3 TO+ 6.9	21.9	194	OXP	4
32	98		H	F/L	F/L		089	610SM	TEC+	9.8	21.9	194	OXP	4
23	99		H	F/L	F/L		091	610SM	TEC+	2.0	32.0	18	OXP	4
32	100		H	F/L	F/L		091	610SM	TEC+	15.5	29.5	184	OXP	4
39	101	C	F/L	F/L			092	610SM	TEC+	14.4 TO+ 17.8	20.2	193	OXP	4
9	103	C	F/L	F/L			087	610SM	TEC+	4.0 TO+ 6.6	25.0	189	OXP	4
10	103	C	F/L	F/L			087	610SM	TEC+	5.4	22.2	9	OXP	4
23	105	C	F/L	F/L			085	610SM	TEC+	0.3 TO+ 2.4	46.6	8	OXP	4
35	107	C	F/L	F/L			082	610SM	TEH+	0.0 TO+ 2.1	28.9	188	OXP	4
2	108	C	F/L	F/L			080	610SM	TEH+	18.6 TO+ 20.1	28.3	192	OXP	4
3	109	C	F/L	F/L			078	610SM	TEC+	20.9	21.0	12	OXP	4
		C	F/L	F/L			078	610SM	TEC+	2.6	38.9	7	OXP	4
23	111	C	F/L	F/L			076	610SM	TEC+	0.3 TO+ 5.6	25.3	353	OXP	4
2	112	C	F/L	F/L			076	610SM	TEC+	5.5 TO+ 14.4	22.4	350	OXP	4
2	113	C	F/L	F/L			074	610SM	TEC+	11.5	21.1	10	OXP	4
3	113	C	F/L	F/L			074	610SM	TEH+	15.3	21.3	193	OXP	4
		C	F/L	F/L			074	610SM	TEC+	12.1	23.5	15	OXP	4
5	113	C	F/L	F/L			074	610SM	TEH+	1.2	23.7	189	OXP	4
9	113	C	F/L	F/L			074	610SM	TEC+	2.6	26.8	187	OXP	4
10	113	C	F/L	F/L			074	610SM	TEC+	12.3	24.9	196	OXP	4
1	114	C	F/L	11C	RIT		046	610SM	TEC+	12.1	25.2	349	OXP	4
		C	F/L	11C	RIT		074	610SM	TEC+	6.6	21.1	195	OXP	4
		C	F/L	11C	RIT		046	610SM	TEC+	6.4	29.8	180	OXP	4
		C	F/L	11C	RIT		074	610SM	TEC+	1.1	54.5	16	OXP	4
8	114	C	F/L	F/L			074	610SM	TEH+	0.8	33.2	191	OXP	4
		C	F/L	F/L			074	610SM	TEH+	1.5	22.8	191	OXP	4
16	115	C	F/L	F/L			072	610SM	TEH+	7.1 TO+ 9.3	22.4	186	OXP	4
1	117	C	F/L	11C	RIT		046	610SM	TEC+	1.6	23.1	355	OXP	4
1	118	C	F/L	11C	RIT		069	610SM	TEC+	0.3 TO+ 1.6	45.4	353	OXP	4
		C	F/L	11C	RIT		046	610SM	TEC+	1.1	40.8	356	OXP	4
1	120	C	F/L	11C	RIT		069	610SM	TEC+	13.3	22.6	358	OXP	4
		C	F/L	11C	RIT		046	610SM	TEC+	13.1	21.3	350	OXP	4

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: D
LOCATION: ALL
CRITERIA: OXP

PAGE: 6 OF 6
DATE: 08/10/88
TIME: 12:25:27

ROW	COL	HEAT#	EXTENT					LOCATION	CURRENT					
			LEG	REQ	TST	REM	REEL		VOLTS	MIL	DEG	%		
1	120		C	F/L	11C	RIT	046	610SM	TEC+	1.2	34.4	359	OXP	4
			C	F/L	11C	RIT	069	610SM	TEC+	1.1	45.9	2	OXP	4

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 181

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PRC. ST, UNIT 2

STEAM GENERATOR: D
LOCATION: ALL
CRITERIA: SKR

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 15:06:49

ROW	COL	HEAT#	LEG	EXTENT			PROBE	LOCATION	CURRENT				
				REQ	TST	REM			VOLTS	MIL	DEG	%	
7	29		H	F/L	F/L		018	610SM TEC+	16.6 TO+ 22.5	21.0	176	SKR	4
3	58		H	F/L	F/L		044	610SM TEC+	20.4	28.8	180	SKR	4
			H	F/L	F/L		044	610SM TEC+	18.0	22.4	0	SKR	4

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 2

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: D
LOCATION: ALL
CRITERIA: TMR

PAGE: 1 OF 1
DATE: 08/05/87
TIME: 15:07:15

ROW	COL	HEAT#	LEG	EXTENT			REEL	PROBE	LOCATION	CURRENT			
				REQ	TST	REM				VOLTS	MIL	DEG	*
35	36		H	F/L	F/L		024	610SM	TSH- 0.3	8.9			8 TMR M2
35	65		H	F/L	F/L		052	610SM	TSH- 0.3	24.7			3 TMR M2
9	95		H	F/L	F/L		086	610SM	TSH- 0.3	13.2			3 TMR M2

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 3

NO TREND ANALYSIS REQUESTED

CONAM

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: D
LOCATION: ALL
CRITERIA: PTE

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 15:07:37

ROW	COL	HEAT#	LEG	EXTENT	REQ	TST	REM	REEL	PROBE	LOCATION		CURRENT				
										VOLTS	MIL	DEG	%	CH		
29	66	H	F/L	F/L				053	6105M	TEL	-	0.0 TO + 22.1	13.5	0	PTE	4

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 1

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: D
LOCATION: ALL
CRITERIA: NTE

PAGE: 1 OF 1
DATE: 08/08/88
TIME: 11:23:06

ROW	COL	HEAT#	EXTENT				REEL	PROBE	LOCATION	CURRENT				
			LEG	REQ	TST	REM				VOLTS	MIL	DEG	*	CH
29	13		H	F/L	F/L		006	610SM	TSH+ 0.0	11.3	315	NTE	4	

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 1

NO TREND ANALYSIS REQUESTED

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: D
LOCATION: ALL
CRITERIA: BLG

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 15:07:56

*** NO CALLS IN THIS RANGE ***

APPENDIX - C
Steam Generator A
Tubes Removed From Service

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: A
LOCATION: ALL
CRITERIA: PLG

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:12:52

ROW	COL	HEAT#	LEG	EXTENT				PROBE	LOCATION	CURRENT			
				REQ	TST	REM	REEL			VOLTS	MIL	DEG	*
3	20		C	F/L									PLG
21	20		C	F/L									PLG
31	20		C	F/L									PLG
34	20		C	F/L									PLG
35	20		C	F/L									PLG
21	34		C	F/L									PLG
31	34		C	F/L									PLG
3	40		C	F/L					M				PLG
3	61		H	F/L									PLG
9	66		H	F/L									PLG
3	81		H	F/L									PLG
21	87		H	F/L									PLG
31	87		H	F/L									PLG
3	101		H	F/L									PLG
21	101		H	F/L									PLG
31	101		H	F/L									PLG

NUMBER OF SES SELECTED FROM CURRENT OUTAGE: 16

NO TREND ANALYSIS REQUESTED

APPENDIX - C
Steam Generator B
Tubes Removed From Service

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: B
LOCATION: ALL
CRITERIA: PLG

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:22:03

ROW	COL	HEAT#	LEG	EXTENT				LOCATION	CURRENT			
				REQ	TST	REM	REEL		VOLTS	MIL	DEG	*
3	20		H	F/L								PLG
21	20		H	F/L								PLG
31	20		H	F/L								PLG
21	34		H	F/L								PLG
31	34		H	I/L								PLG
3	40		H	F/L								PLG
3	60		H	F/L								PLG
3	81		H	F/L								PLG
21	87		H	F/L								PLG
31	87		H	F/L								PLG
3	101		H	F/L								PLG
21	101		H	F/L								PLG
31	101		H	F/L								PLG

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 13

NO TREND ANALYSIS REQUESTED

APPENDIX - C
Steam Generator C
Tubes Removed From Service

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: C
LOCATION: ALL
CRITERIA: PLG

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 14:52:14

ROW	COL	HEAT#	LEG	EXTENT				LOCATION	CURRENT			
				REQ	TST	REM	REEL		VOLTS	MIL	DEG	*
3	20		H	F/L								PLG
21	20		H	F/L								PLG
31	20		H	F/L								PLG
31	21		H	F/L								PLG
3	24		C	F/L								PLG
21	34		H	F/L								PLG
31	34		H	F/L								PLG
3	40		H	F/L								PLG
40	40		H	F/L								PLG
3	49		H	F/L								PLG
4	49		H	F/L								PLG
5	49		H	F/L								PLG
3	50		H	F/L								PLG
4	50		H	F/L								PLG
5	50		H	F/L								PLG
3	61		H	F/L								PLG
			H	F/L								PLG
3	81		H	F/L								PLG
21	87		H	F/L								PLG
31	87		H	F/L								PLG
3	101		H	F/L								PLG
21	101		H	F/L								PLG
31	101		H	F/L								PLG

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 22

NO TREND ANALYSIS REQUESTED

APPENDIX - C
Steam Generator D
Tubes Removed From Service

CUMULATIVE REPORT
04/87, SOUTH TEXAS PROJECT, UNIT 2

STEAM GENERATOR: D
LOCATION: ALL
CRITERIA: PLG

PAGE: 1 OF 1
DATE: 08/09/88
TIME: 15:02:20

ROW	COL	HEAT#	LEG	EXTENT				LOCATION	CURRENT			
				REQ	TST	REM	REEL		VOLTS	MIL.	DEG	%
3	20		H	F/L								PLG
21	20		H	F/L								PLG
31	20		H	F/L								PLG
48	27		H	F/L								PLG
			C	F/L								PLG
21	34		H	F/L								PLG
31	34		H	F/L								PLG
3	40		H	F/L								PLG
3	60		H	F/L								PLG
3	81		H	F/L								PLG
21	87		H	F/L								PLG
31	87		H	F/L								PLG
2	95		H	F/L								PLG
3	101		C	F/L								PLG
21	101		C	F/L								PLG
31	101		C	F/L								PLG

NUMBER OF TUBES SELECTED FROM CURRENT OUTAGE: 15

NO TREND ANALYSIS REQUESTED

APPENDIX - D

Steam Generator A

Form NIS-1 "Owner's Report for Inservice Inspection"

FORM NJS-1 OWNER'S REPORT FOR INSERVICE INSPECTIONS

As required by the Provisions of the ASME Code Rules

I. Owner Houston Lighting & Power Company, Electric Tower P.O. Box 1700,
Houston, Texas 77001

1. Owner South Texas Project Electric Generating Station (Name and Address of Owner)
2. Plant Bay City, Texas 77414 (Name and Address of Plant)

3 Plant Unit 2 4 Owner Certificate of Authorization (if required) N.A.

5. Commercial Service Date N.A. 6. National Board Number for Unit N.A.

7. Components Inspected

Component or Appurtenance	Manufacturer or Installer	Manufacturer or Installer Serial No.		National Board No.
Steam Generator A 1R122NSG201A	Westinghouse	2151		29

Note: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-1 (Back)

8. Examination Dates 04/09/87 to 09/29/87 9. Inspection Interval from --- to PSI

10. Abstract of Examinations. Include a list of examinations and a statement concerning status of work required for current interval. See Supplement Sheet

11. Abstract of Conditions Noted. See Supplement Sheet

12. Abstract of Corrective Measures Recommended and Taken. See Supplement Sheet


We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Certificate of Authorization No. (if applicable) N.A. Expiration Date N.A.
Date August 18 1988 Signed Houston Lighting & Power Company By D. J. Murphy
Owner

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Texas and employed by Lumbermens Mutual Casualty Long Grove, Ill., have inspected the components described in this Owner's Report during the period 4-9-87 to 8-19-88, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the inspection plan and as required by the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.


Inspector's Signature
B. R. Russell
Date 8-19- 1988

Commissions Tex 826
National Board, State, Province, and Endorsements

*27 January 8/18/88
Crossed 8-19-88*

SUPPLEMENT
for
STEAM GENERATOR A
1R122NSG201A

1. Owner Houston Lighting & Power Company; Electric Tower, P.O. Box 1700,
Houston, Texas 77001
(Name and Address of Owner)
2. Plant South Texas Project Electric Generating Station;
P.O. Box 308, Bay City, Texas 77414
(Name and Address of Plant)
3. Plant Unit 2 4. Owner Certificate of Authorization (if required) N.A.
5. Commercial Service Date N/A 6. National Board Number for Unit N/A

ABSTRACT OF EXAMINATIONS

The Section XI Category B-Q Item No. B16.20 volumetric examination was completed in the entire length of all tubes not removed from service from tube end to tube end.

ABSTRACT OF CONDITIONS NOTED

No flaw was noted with a depth greater than or equal to 20% of the nominal tube wall thickness.

ABSTRACT OF CORRECTIVE MEASURES RECOMMENDED AND TAKEN

No corrective measures were recommended or taken because of defects unacceptable to Section XI requirements.

APPENDIX - D

Steam Generator B

Form NIS-1 "Owner's Report for Inservice Inspection"

FORM NIS-1 OWNER'S REPORT FOR INSERVICE INSPECTIONS

As required by the Provisions of the ASME Code Rules

1. Owner Houston Lighting & Power Company; Electric Tower, P.O. Box 1700
Houston, Texas 77001

2. Plant South Texas Project Electric Generating Station, P.U. Box 308
Bay City, Texas 77414

3. Plant Unit 2 4. Owner Certificate of Authorization (if required) N.A.

5. Commercial Service Date N.A. 6. National Board Number for Unit N.A.

7. Components Inspected

Component or Appurtenance	Manufacturer or Installer	Manufacturer or Installer Serial No.		National Board No.
Steam Generator 8 1R122NSG201B	Westinghouse	2152		30

Note: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-1 (Back)

8. Examination Dates 04/09/87 to 09/29/87 9. Inspection Interval from --- to PSI

10. Abstract of Examinations. Include a list of examinations and a statement concerning status of work required for current interval. See Supplement Sheet

11. Abstract of Conditions Noted See Supplement Sheet

12. Abstract of Corrective Measures Recommended and Taken See Supplement Sheet


We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Certificate of Authorization No. (if applicable) N.A. Expiration Date N.A.
Date August 18 1988 Signed Houston Lighting & Power Company By R. R. Russell
Owner

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Texas and employed by Lumbermens Mutual Casualty Long Grove, ILL. have inspected the components described in this Owner's Report during the period 4-9-87 to 8-19-88, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the inspection plan and as required by the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.


Inspector's Signature
B. R. Russell
Date 8-19- 1988

Commission # 826
National Board, State, Province, and Endorsements

RJ Survey 8/8/88
Dlosson 8-19-88

SUPPLEMENT
for
STEAM GENERATOR B
1R122NSG201B

1. Owner Houston Lighting & Power Company; Electric Tower, P.O. Box 1700,
Houston, Texas 77001
(Name and Address of Owner)
2. Plant South Texas Project Electric Generating Station;
P.O. Box 308, Bay City, Texas 77414
(Name and Address of Plant)
3. Plant Unit 2 4. Owner Certificate of Authorization (if required) N.A.
5. Commercial Service Date N/A 6. National Board Number for Unit N/A

ABSTRACT OF EXAMINATIONS

The Section XI Category B-Q Item No. B16.20 volumetric examination was completed in the entire length of all tubes not removed from service from tube end to tube end.

ABSTRACT OF CONDITIONS NOTED

No flaw was noted with a depth greater than or equal to 20% of the nominal tube wall thickness.

ABSTRACT OF CORRECTIVE MEASURES RECOMMENDED AND TAKEN

No corrective measures were recommended or taken because of defects unacceptable to Section XI requirements.

APPENDIX - D

Steam Generator C

Form NIS-1 "Owner's Report for Inservice Inspection"

FORM NIS-1 OWNER'S REPORT FOR INSERVICE INSPECTIONS

As required by the Provisions of the ASME Code Rules

Houston Lighting & Power Company; Electric Tower, P.O. Box 1700,
1 Owner Houston, Texas 77001

1. Owner South Texas Project (Name and Address of Owner)
South Texas Project Electric Generating Station, P.O. Box 308,
2. Plant Bay City, Texas 77414 (Name and Address of Plant)

3 Plant Unit 2 4. Owner Certificate of Authorization (if required) N.A.

5. Commercial Service Date N.A. 6. National Board Number for Unit N.A.

7. Components Inspected

Component or Appurtenance	Manufacturer or Installer	Manufacturer or Installer Serial No.		National Board No.
Steam Generator C 1R122NSG201C	Westinghouse	2153		31

Note: Supplemental sheets in form 25% or sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 10 in this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at top of this form.

FORM NIS-1 (Back)

8. Examination Dates 04/09/87 to 09/29/87 9. Inspection Interval from --- to PSI
10. Abstract of Examinations. Include a list of examinations and a statement concerning status of work required for current interval. See Supplement Sheet
11. Abstract of Conditions Noted See Supplement Sheet
12. Abstract of Corrective Measures Recommended and Taken See Supplement Sheet

We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Certificate of Authorization No. (if applicable) N.A. Expiration Date N.A.
 Date August 18 19 88 Signed Houston Lighting & Power Company By B.R. Russell
 Owner

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Texas and employed by Lumbermens Mutual Casualty Long Grove, Ill. have inspected the components described in this Owner's Report during the period 4-9-87 to 8-19-88, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the inspection plan and as required by the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.


 Inspector's Signature B.R. Russell
 Date 8-19- 19 88

Commission No. Tex 826
 National Board, State, Province, and Endorsements

D. Savuly 8/18/88
DR 8-1988

SUPPLEMENT
for
STEAM GENERATOR C
1R122NSG201C

1. Owner Houston Lighting & Power Company; Electric Tower, P.O. Box 1700,
Houston, Texas 77001
(Name and Address of Owner)
2. Plant South Texas Project Electric Generating Station;
P.O. Box 308, Bay City, Texas 77414
(Name and Address of Plant)
3. Plant Unit 2 4. Owner Certificate of Authorization (if required) N.A.
5. Commercial Service Date N/A 6. National Board Number for Unit N/A

ABSTRACT OF EXAMINATIONS

The Section X Category B-Q Item No. B16.20 volumetric examination was completed in the entire length of all tubes not removed from service from tube end to tube end.

ABSTRACT OF CONDITIONS NOTED

No flaw was noted with a depth greater than or equal to 20% of the nominal tube wall thickness.

ABSTRACT OF CORRECTIVE MEASURES RECOMMENDED AND TAKEN

No corrective measures were recommended or taken because of defects unacceptable to Section XI requirements. (One (1) tube was plugged because the tube sheet expansion extended above the tube sheet secondary face.)

APPENDIX - D

Steam Generator D

Form NIS-1 "Owner's Report for Inservice Inspection"

FORM NIS-1 OWNER'S REPORT FOR INSERVICE INSPECTIONS

As required by the Provisions of the ASME Code Rules

Houston Lighting & Power Company; Electric Tower P.O. Box 1700

1. Owner Houston, Texas 77001

South Texas Project Electric Generating Station

2. Plant P.O. Box 308 Bay City, Texas 77414
(Name and Address of Plant)

3. Plant Unit 2 4. Owner Certificate of Authorization (if required) N.A.

5. Commercial Service Date N.A. 6. National Board Number for Unit N.A.

7. Components Inspected

Note: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-1 (Back)

8. Examination Dates 04/09/87 to 09/29/87 9. Inspection Interval from --- to PSI
10. Abstract of Examinations. Include a list of examinations and a statement concerning status of work required for current interval. See Supplement Sheet
11. Abstract of Conditions Noted See Supplement Sheet
12. Abstract of Corrective Measures Recommended and Taken See Supplement Sheet


We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Certificate of Authorization No. (if applicable) N.A. Expiration Date N.A.
Date August 18 1988 Signed Houston Lighting & Power Company By L. R. Steury
Owner

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Texas and employed by Lumbermens Mutual Casualty Long Grove, ILL. have inspected the components described in this Owner's Report during the period 4-9-87 to 8-19-88, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the inspection plan and as required by the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.


B. R. Russell Signature
Commissioner #826
National Board, State, Province, and Endorsements
Date 8-19- 1988

*Log Review 8/18/78
G. D. Lasseter 8/18/78*

SUPPLEMENT
for
STEAM GENERATOR D
1R122N3G201D

1. Owner Houston Lighting & Power Company; Electric Tower, P.O. Box 1700,
Houston, Texas 77001
(Name and Address of Owner)
2. Plant South Texas Project Electric Generating Station;
P.O. Box 308, Bay City, Texas 77414
(Name and Address of Plant)
3. Plant Unit 2 4. Owner Certificate of Authorization (if required) N.A.
5. Commercial Service Date N/A 6. National Board Number for Unit N/A

ABSTRACT OF EXAMINATIONS

The Section XI Category B-Q Item No. Bl6.20 volumetric examination was completed in the entire length of all tubes not removed from service from tube end to tube end.

ABSTRACT OF CONDITIONS NOTED

No flaw was noted with a depth greater than or equal to 20% of the nominal tube wall thickness.

ABSTRACT OF CORRECTIVE MEASURES RECOMMENDED AND TAKEN

No corrective measures were recommended or taken because of defects unacceptable to Section XI requirements.