

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station Northeast Nuclear Energy Company P.O. Pox 128 Waterford, CT 06385-0128 (860) 447-1791 Fax (860) 444-4277

The Northeast Utilities System

SEP 2 5 1998

Docket No. 50-336 B17462

Je 22

Re: 10 CFR 50.73(a)(2)(ii)

U.S. Nuclear Regulatory Commission Document Control Desk Washington, DC 20555

Millstone Nuclear Power Station Unit No. 2
Licensee Event Report 98-019-00
Potential Inability to Close Auxiliary Feedwater Regulator Valves
After a High Energy Line Break

This letter forwards Licensee Event Report (LER) 98-019-00, documenting two conditions, the first of which was discovered at Millstone Nuclear Power Station, Unit No. 2, on August 26, 1998. This LER is being submitted pursuant to 10 CFR 50.73(a)(2)(ii)(B).

The Northeast Nuclear Energy Company (NNECO) commitments made within this letter are included in Attachment 1.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

J. A. Price

Director - Millstone Unit No. 2

cc: see page 2

9810020032 980925 PDR ADUCK 05000336 S PDR U.S. Nuclear Regulatory Commission B17462\Page 2

Attachments: 1. List of Regulatory Commitments

2. LER 98-019-00

cc: H. J. Miller, Region I Administrator

D. G. McDonald, Jr., NRC Senior Project Manager, Millstone Unit No. 2 D. P. Beaulieu, Senior Resident Inspector, Millstone Unit No. 2

E. V. Imbro, Millstone ICAVP Inspections

Attachment 1 Millstone Nuclear Power Station, Unit No. 2 Commitments

U.S. Nuclear Regulatory Commission B17462\Attachment 1\Page 1

Attachment 1

Regulatory Commitment Enclosure List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document.

REGULATORY COMMITMENT	COMMITTED DATE OR OUTAGE
B17462.01: Prior to entering Mode 3 from the current outage, the auxiliary feedwater system will be upgraded, as required, to ensure compatibility with analyzed HELB conditions.	Prior to entering Mode 3 from current outage

Attachment 2 Millstone Nuclear Power Station, Unit No. 2 LER 98-019-00