



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

SEP 02 1988

Docket No. 50-461

Illinois Power Company
ATTN: Mr. W. C. Gerstner
Executive Vice President
500 South 27th Street
Decatur, IL 62525

Gentlemen:

Your letters of May 15 and September 10, 1986, and March 2, 1987, pertaining to Clinton, contained your response to IEB 85-03, "Motor-Operated Valve Common Mode Failures During Plant Transients Due to Improper Switch Settings". The review of these responses led to the issuance of a request for additional information on March 25, 1988, and response by you on May 16, 1988. Review of this additional information indicates that your selection of the applicable safety-related valves, the valves' maximum differential pressures and your program to assure valve operability requested by action item e. of the bulletin is now acceptable.

The results of our inspections to verify proper implementation of this program and the review of the final response required by action item f. of the bulletin will be addressed in forthcoming inspection reports.

Edward G. Greenman

Edward G. Greenman, Director
Division of Reactor Projects

See Attached Distribution

8809090181 880902
PDR ADOCK 05000461
Q PDC

IEH

10

SEP 02 1988

Distribution

cc: D. P. Hall, Vice President
R. D. Freeman, Manager,
Nuclear Station
Engineering Department
~~DCD/DCB (RIDS)~~
Licensing Fee Management Branch
Resident Inspector, RIII
Richard Hubbard
J. W. McCaffrey, Chief, Public
Utilities Division
H. S. Taylor, Quality Assurance
Division, Sargent & Lundy
Engineers
David Rosenblatt, Governor's
Office of Consumer Services
Sheldon Zabel, Esquire,
Schiff, Hardin, & Waite
L. Larson, Project Manager,
General Electric Company
Chairman of DeWitt County
Illinois Department of
Nuclear Safety
D. Schopfer, Project Manager,
Sargent & Lundy Engineers
R. J. Kiessel, NRR
J. A. Stevens, NRR