February 28, 1986

O. D. KINGSLEY, JR. VICE PRESIDENT NUCLEAR OPERATIONS

> U. S. Nuclear Regulatory Commission Office of Nuclear Reactor Regulation Washington, D. C. 20555

Attention: Mr. Harold R. Denton, Director

Dear Mr. Denton:

SUBJECT: Grand Gulf Nuclear Station

Unit 1

Docket No. 50-416 License No. NPF-29

File: 0260/0840/L-860.0

Proposed Amendment to the Operating

License (PCOL-86/03)

AECM-86/0067

Mississippi Power and Light (MP&L) is submitting by this letter two proposed changes to the Grand Gulf Technical Specifications and Facility Operating License NPF-29. These proposed technical specification changes result from recent design changes.

The first design change added a more accessible containment isolation valve, E12-F394, which is designated in Technical Specification Table 3.6.4-1 as the RHR to Head Spray Valve. The technical specification change for the revised designation of this valve was approved by the NRC on November 8, 1985 as Amendment 7 to Facility Operating License No. NPF-29 and contained a requirement for MP&L to revise the maximum closing time of valve E12-F394 within 90 days after completion of the second ASME Section XI closure time test. This test to determine closure time was completed on November 30, 1985. It is therefore proposed that Table 3.6.4-1 be revised and that the footnote marked "##" on Technical Specification Page 3/4 6-30 be deleted.

The second technical specification change is to allow a design change providing for the addition of sprinklers to area IA424 and is submitted to satisfy an MP&L commitment to add these sprinklers.

In accordance with the provisions of 10 CFR 50.30, three (3) signed originals and forty (40) copies of the requested amendment are enclosed. The attachment provides the complete technical justification and discussion to support the requested amendment. This amendment has been reviewed and accepted by the Plant Safety Review Committee (PSRC) and the Safety Review Committee (SRC).

Based on the guidelines presented in 10 CFR 50.92, it is the opinion of MP&L that this proposed amendment involves no significant hazards considerations.

8603030323 860228 PDR ADDCK 05000416

In accordance with the requirements of 10 CFR 170.21, we have determined that the application fee is \$150. A remittance of \$150 is attached to this letter.

Yours Fruly,

ODK: dmm

Attachments: GGNS PCOL-86/03

cc: Mr. T. H. Cloninger (w/a)

Mr. R. B. McGehee (w/a)

Mr. N. S. Reynolds (w/a)

Mr. H. L. Thomas (w/o)

Mr. R. C. Butcher (w/a)

Mr. James M. Taylor, Director (w/a) Office of Inspection & Enforcement U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Dr. J. Nelson Grace, Regional Administrator (w/a) U. S. Nuclear Regulatory Commission Region II 101 Marietta St., N. W., Suite 2900 Atlanta, Georgia 30323

Dr. Alton B. Cobb (w/a) State Health Officer State Board of Health Box 1700 Jackson, Mississippi 39205