

April 28, 1988

Docket No. 50-440

DISTRIBUTION:

| | |
|---------------------|------------------|
| <u>Docket Files</u> | NRC & Local PDRS |
| PDIII-3 r/f | KPerkins |
| GHolahan | PKreutzer |
| TColburn | DLynch |
| OGC-WF1 | EJordan |
| JPartlow | ACRS(10) |
| PDIII-3 Gray Files | |

Mr. Alvin Kaplan, Vice President
 Nuclear Group
 The Cleveland Electric Illuminating
 Company
 10 Center Road
 Perry, Ohio 44081

Dear Mr. Kaplan:

SUBJECT: PROPOSED REVISION OF SECTION 3.3.2 OF THE PERRY TECHNICAL SPECIFICATIONS (TAC NO. 57130)

In your letter dated February 8, 1988 (PY-CEI/NRR-0765L), you requested an amendment to Facility Operating License NPF-58 for the Perry Nuclear Power Plant, Unit 1. In the course of our review of your request, we have identified a need for additional information. This additional information is related to your basis for the proposed values of the RHR/RCIC steamline flow-high trip setpoint and allowable value. Our request for additional information (RAI) is presented in the attachment to this letter.

In responding, you may answer either in narrative form or in specific responses to each of the four items in the RAI. If you have any questions on this matter, please contact me promptly at 301-492-3023.

The information requested in this letter affects fewer than 10 respondents; therefore OMB clearance is not required under Pub. L. 96-511.

Sincerely,

/s/

M. D. Lynch, Senior Project Engineer
 Project Directorate III-3
 Division of Reactor Projects - III,
 IV, V and Special Projects

Attachment:
 As stated

cc: See next page

8805130220 880428
 PDR ADOCK 05000440
 P PDR

MDL
 Office: SPE/PDIII-3
 Surname: MDLynch/tg
 Date: 04/29/88

for
 PM/PDIII-3
 TColburn
 4/28/88

MDL
 PD/PDIII-3
 for KPerkins
 04/29/88

Mr. Alvin Kaplan
The Cleveland Electric
Illuminating Company

Perry Nuclear Power Plant
Unit 1

cc:
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N.W.
Washington, D.C. 20037

Mr. James W. Harris, Director
Division of Power Generation
Ohio Department of Industrial
Relations
P.O. Box 825
Columbus, Ohio 43216

David E. Burke
The Cleveland Electric
Illuminating Company
P.O. Box 5000
Cleveland, Ohio 44101

The Honorable Lawrence Logan
Mayor, Village of Perry
4203 Harper Street
Perry, Ohio 44081

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
Parmlly at Center Road
Perry, Ohio 44081

The Honorable Robert V. Orosz
Mayor, Village of North Perry
North Perry Village Hall
4778 Lockwood Road
North Perry Village, Ohio 44081

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43216

Frank P. Weiss, Esq.
Assistant Prosecuting Attorney
105 Main Street
Lake County Administration Center
Painesville, Ohio 44077

Radiological Health Program
Ohio Department of Health
1224 Kinnear Road
Columbus, Ohio 43212

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Ohio Environmental Protection
Agency
361 East Broad Street
Columbus, Ohio 43266-0558

Terry J. Lodge, Esq.
618 N. Michigan Street
Suite 105
Toledo, Ohio 43624

Mr. Phillip S. Haskell, Chairman
Perry Township Board of Trustees
Box 65
4171 Main Street
Perry, Ohio 44081

John G. Cardinal, Esq.
Prosecuting Attorney
Ashtabula County Courthouse
Jefferson, Ohio 44047

State of Ohio
Public Utilities Commission
180 East Broad Street
Columbus, Ohio 43266-0573

Eileen M. Buzzelli
The Cleveland Electric
Illuminating Company
P. O. Box 97 E-210
Perry, Ohio 44081

Mr. Murray R. Edelman
Centerior Energy
6200 Oaktree Blvd.
Independence, Ohio 44131

REQUEST FOR ADDITIONAL INFORMATION

PERRY NUCLEAR POWER PLANT

DOCKET NO. 50-440

1. Describe the relevant portion of the startup test program which was the basis for your proposed revision of the RHR/RCIC Steamline Flow-High Trip Setpoint in Item 6.C of Table 3.3.2-2 of the Perry Technical Specifications. State the value of the mass steam flow measured in the startup test as a percentage of the full power value.
2. Describe how you extrapolate the value measured in Item 1 above to the stated basis for isolating the reactor heat removal (RHR) system (i.e., 125 percent of the total maximum RCIC and RHR steam condensing steam flow).
3. Describe the possible errors, both random and systematic, in the measured value of the subject parameter. Describe how you treat these errors when extrapolating from the mass steam flow measured in the startup test to your design basis of 125 percent.
4. Describe what adjustments you make in the extrapolated value of the subject parameter to arrive at your proposed values of the trip setpoint and the allowable value in Table 3.3.2-2. In your discussion, demonstrate the conservatism of the proposed values.

In addition, if you choose to answer in narrative form, we request for the sake of completeness that you describe the nature of the parameter used as the RHR/RCIC Steamline Flow-High Trip Setpoint (e.g., a pressure drop). Include in this discussion, a description of how and where the value of this parameter is measured during normal operation of the plant.