

May 4, 1988

Docket No. 50-285

Mr. R. L. Andrews  
Division Manager - Nuclear Production  
Omaha Public Power District  
1623 Harney Street  
Omaha, Nebraska 68102

Dear Mr. Andrews:

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - AMENDMENT NO. 113 TO FACILITY  
OPERATING LICENSE NO. DPR-40 (TAC NO. 67165)

The Commission has issued the enclosed Amendment No. 113 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications partially granting your application dated February 8, 1988.

The amendment would allow the licensee to use annual average (rather than real-time) meteorological dispersion factors to calculate doses, and corrects and clarifies some parts of Technical Specifications 2.9.1 and 5.9.4. However, the requested changes for removing instantaneous release and removal of the radioactive effluent reports according to Regulatory Guide 1.21 was not approved by the staff. A notice of denial for these changes will be published in the Federal Register.

A copy of our related Safety Evaluation is enclosed. The notice of issuance will be included in the Commission's next Bi-weekly Federal Register notice.

Sincerely,

/s/  
Anthony Bournia, Project Manager  
Project Directorate - IV  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 113 to DPR-40
2. Safety Evaluation

cc w/enclosures:  
See next page

8805160084 880504  
PDR ADOCK 05000285  
P PDR

DISTRIBUTION:

<u>Docket File</u>	JPartlow	NRC PDR	TBarnhart (4)
Local PDR	Wanda Jones	PD4 Reading	EButcher
PNoonan (3)	ACRS (10)	ABournia	GPA/PA
JCalvo	ARM/LFMB	OGC-Rockville	DHagan
EJordan	Plant File	LRubenstein	

DOCUMENT NAME: FC AMENDMENT TAC 67165

\*See previous concurrences:

PD4/LA*	PD4/PM*	OGC-Rockville*	PD4/D JHC
PNoonan	ABournia:sr		JCalvo
04/21/88	04/21/88	04/27/88	05/4/88

Docket No. 50-285

Mr. R. L. Andrews  
Division Manager - Nuclear Production  
Omaha Public Power District  
1623 Harney Street  
Omaha, Nebraska 68102

Dear Mr. Andrews:

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - AMENDMENT NO. TO FACILITY  
OPERATING LICENSE NO. DPR-40 (TAC NO. 67165)

The Commission has issued the enclosed Amendment No. to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications in response to your application dated February 8, 1988.

The amendment would allow the licensee to use annual average (rather than real-time) meteorological dispersion factors to calculate doses, and corrects and clarifies some parts of Technical Specifications 2.9.1 and 5.9.4. However, the requested changes for removing instantaneous release and removal of the radioactive effluent reports according to Regulatory Guide 1.21 was not approved by the staff.

A copy of our related Safety Evaluation is enclosed. The notice of issuance will be included in the Commission's next Bi-weekly Federal Register notice.

Sincerely,

Anthony Bournia, Project Manager  
Project Directorate - IV  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. to DPR-40
- 2. Safety Evaluation

cc w/enclosures:  
See next page

DISTRIBUTION:

Docket File	JPartlow	NRC PDR	TBarnhart (4)
Local PDR	Wanda Jones	PD4 Reading	EButcher
PNoonan (3)	ACRS (10)	ABournia	GPA/PA
JCalvo	ARM/LFMB	OGC-Rockville	DHagan
EJordan	Plant File		

DOCUMENT NAME: FC AMENDMENT TAC 67165

\*See previous concurrences:

PD4/LA*	PD4/PM*	OGC-Rockville	PD4/D
PNoonan	ABournia:sr	<i>B. Bournia</i>	JCalvo
04/21/88	04/21/88	04/27/88 <i>subject</i>	04/ /88

*To include in  
notice of issuance  
from that 2 of 4 changes were found unacceptable*

Docket No. 50-285

Mr. R. L. Andrews  
Division Manager - Nuclear Production  
Omaha Public Power District  
1623 Harney Street  
Omaha, Nebraska 68102

Dear Mr. Andrews:

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - AMENDMENT NO. TO FACILITY  
OPERATING LICENSE NO. DPR-40 (TAC NO. 67165)

The Commission has issued the enclosed Amendment No. to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications in response to your application dated February 8, 1988.

The amendment would allow the licensee to use annual average (rather than real-time) meteorological dispersion factors to calculate doses, and corrects and clarifies some parts of Technical Specifications 2.9.1 and 5.9.4.

A copy of our related Safety Evaluation is enclosed. The notice of issuance will be included in the Commission's next Bi-weekly Federal Register notice.

Sincerely,

Anthony Bournia, Project Manager  
Project Directorate - IV  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. to DPR-40
2. Safety Evaluation

cc w/enclosures:  
See next page

DISTRIBUTION:

Docket File	JPartlow	NRC PDR	TBarnhart (4)
Local PDR	Wanda Jones	PD4 Reading	EButcher
PNoonan (3)	ACRS (10)	ABournia	GPA/PA
JCalvo	ARM/LFMB	OGC-Rockville	DHagan
EJordan	Plant File		

DOCUMENT NAME: FC AMENDMENT TAC 67165

PD4/LA PNoonan 04/21/88	<sup>AB</sup> PD4/PM ABournia:sr 04/21/88	OGC-Rockville 04/ /88	PD4/D JCalvo 04/ /88
-------------------------------	--	--------------------------	----------------------------



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

May 4, 1988

Docket No. 50-285

Mr. R. L. Andrews  
Division Manager - Nuclear Production  
Omaha Public Power District  
1623 Harney Street  
Omaha, Nebraska 68102

Dear Mr. Andrews:

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - AMENDMENT NO.113 TO FACILITY  
OPERATING LICENSE NO. DPR-40 (TAC NO. 67165)

The Commission has issued the enclosed Amendment No.113 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications partially granting your application dated February 8, 1988.

The amendment would allow the licensee to use annual average (rather than real-time) meteorological dispersion factors to calculate doses, and corrects and clarifies some parts of Technical Specifications 2.9.1 and 5.9.4. However, the requested changes for removing instantaneous release and removal of the radioactive effluent reports according to Regulatory Guide 1.21 was not approved by the staff. A notice of denial for these changes will be published in the Federal Register.

A copy of our related Safety Evaluation is enclosed. The notice of issuance will be included in the Commission's next Bi-weekly Federal Register notice.

Sincerely,

*Anthony Bournia*

Anthony Bournia, Project Manager  
Project Directorate - IV  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No.113 to DPR-40
2. Safety Evaluation

cc w/enclosures:  
See next page

Mr. R. L. Andrews  
Omaha Public Power District

Fort Calhoun Station  
Unit No. 1

cc:

Harry H. Voigt, Esq.  
LeBoeuf, Lamb, Leiby & MacRae  
1333 New Hampshire Avenue, NW  
Washington, D.C. 20036

Mr. Jack Jensen, Chairman  
Washington County Board  
of Supervisors  
Blair, Nebraska 68008

Mr. Phillip Harrell, Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 309  
Fort Calhoun, Nebraska 68023

Mr. Charles B. Brinkman, Manager  
Washington Nuclear Operations  
C-E Power Systems  
7910 Woodmont Avenue  
Bethesda, Maryland 20814

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
Office of Executive Director  
for Operations  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Harold Borchert, Director  
Division of Radiological Health  
Department of Health  
301 Centennial Mall, South  
P.O. Box 95007  
Lincoln, Nebraska 68509

W. G. Gates, Manager  
Fort Calhoun Station  
P. O. Box 399  
Fort Calhoun, Nebraska 68023