

September 2, 1988

Docket No. 50-267

Mr. R. O. Williams, Jr.
Vice President, Nuclear Operations
Public Service Company of Colorado
Post Office Box 840
Denver, Colorado 80201-0840

Dear Mr. Williams:

SUBJECT: FIRE DOOR RATINGS FOR RECORD STORAGE FACILITY
(TAC NO. 61578)

We have reviewed your letter dated August 18, 1988 concerning the ratings for fire doors at the Fort St. Vrain Records Center. We concur that the requirement for a 4-hour rating is not necessary and is potentially difficult to implement. Therefore, we accept your proposed commitment to a 3-hour fire rating for the structure, doors, frames and hardware. However, this rating should not be compromised for other purposes, such as installation of security devices.

Sincerely,

/s/
Kenneth L. Heitner, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects

cc: See next page

DISTRIBUTION

Docket File
L. Rubenstein
OGC-Rockville
ACRS (10)

NRC PDR
J. Calvo
E. Jordan
PD4 Plant File

Local PDR
P. Noonan
B. Grimes

PD4 Reading
K. Heitner
C. McCracken

PD4/LAC
PNoonan
8/31/88

PD4/PM
KHeitner:sr
8/31/88

WAL
PD4/D
JCalvo
9/2/88

DF 9/2
ECHB
CMcCracken
9/2/88

JFOI
1/0

8809130050 880902
PDR ADOCK 05000267
FDC

September 2, 1988

Docket No. 50-267

Mr. R. O. Williams, Jr.
Vice President, Nuclear Operations
Public Service Company of Colorado
Post Office Box 840
Denver, Colorado 80201-0840

Dear Mr. Williams:

SUBJECT: FIRE DOOR RATINGS FOR RECORD STORAGE FACILITY
(TAC NO. 61578)

We have reviewed your letter dated August 18, 1988 concerning the ratings for fire doors at the Fort St. Vrain Records Center. We concur that the requirement for a 4-hour rating is not necessary and is potentially difficult to implement. Therefore, we accept your proposed commitment to a 3-hour fire rating for the structure, doors, frames and hardware. However, this rating should not be compromised for other purposes, such as installation of security devices.

Sincerely,

/s/
Kenneth L. Heitner, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects

cc: See next page

DISTRIBUTION

Docket File
L. Rubenstein
OGC-Rockville
ACRS (10)

NRC PDR
J. Calvo
E. Jordan
PD4 Plant File

Local PDR
P. Noonan
B. Grimes

PD4 Reading
K. Heitner
C. McCracken

PD4/L: *[Signature]*
PNoor:am
8/31/88

PD4/PM *2H*
KHeitner:sr
8/31/88

[Signature]
PD4/D
JCalvo
9/2/88

[Signature]
ECHB
C'cCracken
9/2/88



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

September 2, 1988

Docket No. 50-267

Mr. R. O. Williams, Jr.
Vice President, Nuclear Operations
Public Service Company of Colorado
Post Office Box 840
Denver, Colorado 80201-0840

Dear Mr. Williams:

SUBJECT: FIRE DOOR RATINGS FOR RECORD STORAGE FACILITY
(TAC NO. 61578)

We have reviewed your letter dated August 18, 1988 concerning the ratings for fire doors at the Fort St. Vrain Records Center. We concur that the requirement for a 4-hour rating is not necessary and is potentially difficult to implement. Therefore, we accept your proposed commitment to a 3-hour fire rating for the structure, doors, frames and hardware. However, this rating should not be compromised for other purposes, such as installation of security devices.

Sincerely,

A handwritten signature in cursive script that reads "Kenneth L. Heitner".

Kenneth L. Heitner, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects

cc: See next page

Mr. R. O. Williams, Jr.
Public Service Company of Colorado

Fort St. Vrain

cc:
Mr. D. W. Warembourg, Manager
Nuclear Engineering Division
Public Service Company
of Colorado
P. O. Box 840
Denver, Colorado 80201-0840

Albert J. Hazle, Director
Radiation Control Division
Department of Health
4210 East 11th Avenue
Denver, Colorado 80220

Mr. David Alberstein, 14/159A
GA Technologies, Inc.
Post Office Box 85608
San Diego, California 92138

Mr. R. O. Williams, Jr., Acting Manager
Nuclear Production Division
Public Service Company of Colorado
16805 Weld County Road 19-1/2
Platteville, Colorado 80651

Mr. H. L. Brey, Manager
Nuclear Licensing and Fuel Division
Public Service Company of Colorado
P. O. Box 840
Denver, Colorado 80201-0840

Mr. P. F. Tomlinson, Manager
Quality Assurance Division
Public Service Company of Colorado
16805 Weld County Road 19-1/2
Platteville, Colorado 80651

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 640
Platteville, Colorado 80651

Mr. R. F. Walker
Public Service Company of Colorado
Post Office Box 840
Denver, Colorado 80201-0840

Kelley, Stansfield & O'Donnell
Public Service Company Building
Room 900
550 15th Street
Denver, Colorado 80202

Commitment Control Program
Coordinator
Public Service Company of Colorado
2420 W. 26th Ave. Suite 100-D
Denver, Colorado 80211

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Chairman, Board of County Commissioners
of Weld County, Colorado
Greeley, Colorado 80631

Regional Representative
Radiation Programs
Environmental Protection Agency
1 Denver Place
999 18th Street, Suite 1300
Denver, Colorado 80202-2413