

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

General Offices • Selden Street, Berlin, Connecticut

P.O. BOX 270
HARTFORD, CONNECTICUT 06141-0270
(203) 665-5000

September 2, 1988

Docket No. 50-336

B'3016

Re: TMI Action Item II.D.1

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:


Millstone Nuclear Power Station, Unit No. 2
Torque Switch Set Points of
MOVs 2-RC-403 and 2-RC-405 (TAC #44595)

In an August 18, 1988⁽¹⁾ letter, Northeast Nuclear Energy Company (NNECO) responded to an NRC Staff request for documentation on setpoints of the subject valves. Page 3 of that letter contained an error. In the second paragraph; the third sentence contains the phrase, "a stem force of 76.5 foot-pounds." This phrase should read "a stem force of 3619 pounds."

We regret any inconvenience this error may have caused.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY


E. J. Mrocza
Senior Vice President

cc: W. T. Russell, Region I Administrator
D. H. Jaffe, NRC Project Manager, Millstone Unit Nos. 2 and 3
W. J. Raymond, Senior Resident Inspector, Millstone Unit Nos. 1, 2, and 3
P. Habighorst, Resident Inspector, Millstone Unit No. 2

(1) E. J. Mrocza letter to U.S. Nuclear Regulatory Commission, dated August 18, 1988, "Torque Switch Set Points of MOVs 2-RC-403 and 2-RC-405."

8809130269 880902
PDR ADOCK 05000336
PDC

A046
/10